

CONDITIONS IMPOSED: USE OF TORCH / ROOFS OR BUILDINGS

- 1) Shall provide at least one portable fire extinguisher with a minimum 4-A rating, two portable fire extinguishers with a minimum 2-A rating each, or a water hose connected to the water supply on the premises where such burning is done.
- 2) In ALL cases, the person doing the burning shall remain on the premises one (1) hour after the torch or flame producing device is utilized.
- 3) Subjected to inspection for approval.
- 4) **PERMIT SHALL BE POSTED ON JOB SITE.**

ADMINISTRATIVE APPEAL RIGHTS

Pursuant to N.J.A.C. 5:70-2 et seq., if you wish to contest the validity of this order you may file an appeal with the Hudson County Construction Board of Appeals within (15) fifteen days of the receipt to this notice. A letter requesting an Administrative Hearing and Application must be sent to: Hudson Count Construction Board of Appeals
595 Newark Avenue
Jersey City, NJ 07302

The fee for an appeal is \$100.00 _____, the application for appeal must be in writing, set forth:

- a) Your name
- b) Address of the building or site
- c) Specific section of the regulation in question
- d) Nature of appeal
- e) Any appended documents that you consider useful

A copy of this application for appeal must also be sent to:

*Hoboken Fire Department, Fire Prevention Office,
201 Jefferson Street
3rd floor,
Hoboken, NJ 07030
Attention: Fire Marshal*

CONDITIONS IMPOSED: FOOD TRUCKS, TRAILERS & CARTS.

1) **FIRE EXTINGUISHERS REQUIRED:**

If producing grease vapors a CLASS K extinguisher will required & mounted.
Minimum of a 1-5lb ABC type fire extinguisher required & mounted.
Food carts must also have a minimum of a 1-5lb ABC fire extinguisher mounted.

2) **HOOD SUPPRESSION SYSTEM:**

If vendor is creating any grease vapors, it is required a hood system, in accordance with NFPA 96 standard.

3) **PROPANE STORAGE & APPLIANCES:**

Propane hoses must be checked for leaks, all cylinders must be placed in a storage cabinet if mounted on the outside of vehicle. Also a "NO SMOKING" sign posted in plain view of the public. *PROPER SIGNAGE THROUGHOUT*

4) **GENERATOR:**

If mounted in the vehicle, must be checked for fuel leaks or sparks from exhaust. Also ensure exhaust does not back up into truck.

5) **SMOKE & CARBON MONOXIDE DETECTORS:**

Smoke detectors must be placed between the cooking area and drivers cab.
*note, it does not have to be operating while the vendor is cooking.
Carbon monoxide detectors must be mounted between cooking area & drivers cab. Also, Food trailers must mount the CO detector inside between the area that the generator is mounted or placed on the ground.

6) **PROPANE GAS SENSOR:**

A Propane gas sensor must be mounted in the area of the propane cylinders and inside of the cooking area. Carts need to have the gas sensor near cylinder.

ADMINISTRATIVE APPEAL RIGHTS

Pursuant to N.J.A.C. 5:70-2 et seq., if you wish to contest the validity of this order you may file an appeal with the Hudson County Construction Board of Appeals within (15) fifteen days of the receipt to this notice. A letter requesting an Administrative Hearing and Application must be sent to: Hudson County Construction Board of Appeals

595 Newark Avenue
Jersey City, NJ 07302

The fee for an appeal is \$100.00. the application for appeal must be in writing, set forth:

- a) Your name
- b) Address of the building or site
- c) Specific section of the regulation in question
- d) Nature of appeal
- e) Any appended documents that you consider useful

A copy of this application for appeal must also be sent to:

*Hoboken Fire Department, Fire Prevention Office,
201 Jefferson Street
3rd floor,
Hoboken, NJ 07030
Attention: Fire Marshal*

CONDITIONS IMPOSED: FIREWORKS

- 1) Comply with IFC-NJ 2006 Ch. 33 and NFPA 495,1123,1126
- 2) Evidence of insurance, approvals from the city and coast guard, if needed.
- 3) A complete diagram of everything in the area of firework discharge/fallout; the location of all buildings, streets and the lines showings public restriction.
- 4) Only the kind of explosive specified in permit shall be kept or stored.
- 5) Fireworks must be discharged and operated in accordance with manufacturer's directions and specifications.
- 6) Proof of insurance readily available for inspection at site.
- 7) Storage or Discharging of fireworks, Type 3(\$331), N.J.A.C. 5:70-2.7.
- 8) Qualified person in charge of ALL firework activity shall be at least 21 years of age and demonstrate knowledge of all safety precautions.
- 9) Misfires shall be reported to the supervisor and proper safeguards in accordance of NFPA 495.
- 10) Proper clearance. No spectators, vehicles and buildings within the display site.
- 11) Separation distance shall be twice the fallout radius. Display fired upwind. Minimum distance of 75ft depending on mortar size and fallout radius.
- 12) Barricades shall be in place separating audience from display, minimum of 75ft or specified by Fire Official.
- 13) Portable fire extinguishers on scene. 4 or more extinguishers.
- 14) Smoking is prohibited within 25 feet of pyrotechnics.
- 15) Subjected to inspection for approval
- 16) Permit shall be posted on job site.

ADMINISTRATIVE APPEAL RIGHTS

Pursuant to N.J.A.C. 5:70-2 et seq., if you wish to contest the validity of this order you may file an appeal with the Hudson County Construction Board of Appeals within (15) fifteen days of the receipt to this notice. A letter requesting an Administrative Hearing and Application must be sent to: Hudson Count Construction Board of Appeals

595 Newark Avenue
Jersey City, NJ 07302

The fee for an appeal is \$100.00 _____, the application for appeal must be in writing, set forth:

- a) Your name
- b) Address of the building or site
- c) Specific section of the regulation in question
- d) Nature of appeal
- e) Any appended documents that you consider useful

A copy of this application for appeal must also be sent to:

*Hoboken Fire Department, Fire Prevention Office,
201 Jefferson Street
3rd floor,
Hoboken, NJ 07030
Attention: Fire Marshal*

CONDITIONS IMPOSED: COOKING/OPEN FLAME PUBLIC

- 1) SHALL HAVE IN A STATE OF READINESS A MINIMUM OF ONE PORTABLE FIRE EXTINGUISHER RATED WITH A CLASSIFICATION OF 20:BC.
- 2) SHALL PREVENT THE ACCIDENTAL DISCHARGE AND FALLING OF ALL GAS CYLINDERS.
- 3) SHALL REMOVE, ALL REFUSE, GARBAGE, COMBUSTIBLES, AND FLAMMABLES AT THE END OF EACH BUSINESS DAY.
- 4) SHALL KEEP ALL COMBUSTIBLES AND FLAMMABLES AWAY FROM IGNITION SOURCES.
- 5) SHALL NOT UTILIZE ANY OPEN FLAME DEVICES UNDER ANY OVERHANGS.
- 6) SUBJECT TO INSPECTION TO ASSURE THAT THE USE AND ACTIVITY FOR WHICH APPLICATION IS MADE COMPLIES WITH THE PROVISIONS OF THE CONDITIONS IMPOSED AND THE PROVISIONS OF THE N.J. UNIFORM FIRE CODE.

ADMINISTRATIVE APPEAL RIGHTS

Pursuant to N.J.A.C. 5:70-2 et seq., if you wish to contest the validity of this order you may file an appeal with the Hudson County Construction Board of Appeals within (15) fifteen days of the receipt to this notice. A letter requesting an Administrative Hearing and Application must be sent to: Hudson County Construction Board of Appeals

595 Newark Avenue
Jersey City, NJ 07302

The fee for an appeal is \$100.00, the application for appeal must be in writing, set forth:

- a) Your name
- b) Address of the building or site
- c) Specific section of the regulation in question
- d) Nature of appeal
- e) Any appended documents that you consider useful

A copy of this application for appeal must also be sent to:

*Hoboken Fire Department, Fire Prevention Office,
201 Jefferson Street
3rd floor,
Hoboken, NJ 07030
Attention: Fire Marshal*