



6, Nelson Close,
Shepshed,
Loughborough,
Leics.

LE12 9TH

Tel: 01509 562182 Mob: 07879644474


E-mail: sales@excelpat.co.uk

Web: www.excelpat.co.uk

Portable Appliance Test Results For

**Fixfire.
Systems House,
Old Station Close,
Shepshed.
LE12 9NJ**

3rd August 2020





6, Nelson Close, Shepshed, Loughborough, Leics. LE12 9TH
 Tel: 01509 562182 Mob: 07879644474
 E-mail: sales@excelpat.co.uk
 Website: www.excelpat.co.uk

Test Results for Fixfire, Systems House, Old Station Close, Shepshed. LE12 9NJ

Date Tested - 3rd August 2020

Test Engineer - C Ogilvie C & G Certificate Ref 120208/2377-12/065711/FWO8749/M/05/08/67

Prefix	ID No	Description	Location	Type	Continuity Result (Ω)	Insulation Result (m Ω)	Polarity Status	Fuse (Amps)	Status	Tested By
EX	303501	SLOW COOKER	BAKERITE AREA	CLASS1	0.09	>20	-	-	PASS	C OGILVIE
EX	303502	IEC LEAD	BAKERITE AREA	CLASS1	0.08	>20	PASS	13	PASS	C OGILVIE
EX	303503	TWIN HOT PLATE	BAKERITE AREA	CLASS1	0.03	>20	-	13	PASS	C OGILVIE
EX	303504	415V OVEN	BAKERITE AREA	CLASS1	VISUAL	VISUAL	-	-	PASS	C OGILVIE
EX	303505	FRYER	BAKERITE AREA	CLASS1	0.04	>20	-	13	PASS	C OGILVIE
EX	303506	FRIDGE	BAKERITE AREA	CLASS1	0.09	>20	-	13	PASS	C OGILVIE
EX	303507	FOOD MIXER	BAKERITE AREA	CLASS2	-	>20	-	13	PASS	C OGILVIE
EX	303508	FOOD MULTI MIXER	BAKERITE AREA	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	303509	SCALES	BAKERITE AREA	CLASS1	0.07	>20	-	-	PASS	C OGILVIE
EX	303510	IEC LEAD	BAKERITE AREA	CLASS1	0.06	>20	PASS	13	PASS	C OGILVIE
EX	303511	FRIDGE	BAKERITE AREA	CLASS1	0.06	>20	-	13	PASS	C OGILVIE
EX	303512	MICROSCOPE	BAKERITE AREA	CLASS1	0.09	>20	-	-	PASS	C OGILVIE
EX	303513	IEC LEAD	BAKERITE AREA	CLASS1	0.08	>20	PASS	3	PASS	C OGILVIE
EX	303514	SCALES	BAKERITE AREA	CLASS1	0.08	>20	-	-	PASS	C OGILVIE
EX	303515	IEC LEAD	BAKERITE AREA	CLASS1	0.07	>20	PASS	5	PASS	C OGILVIE
EX	303516	HEAT SEALER	BAKERITE AREA	CLASS1	0.11	>20	-	5	PASS	C OGILVIE
EX	303517	VACUUM CLEANER	BAKERITE AREA	CLASS2	-	>20	-	13	PASS	C OGILVIE
EX	303518	BAG SEALER	BAKERITE AREA	CLASS1	0.11	>20	-	3	PASS	C OGILVIE
EX	303519	FILLING UNIT	BAKERITE AREA	CLASS1	0.08	>20	-	5	PASS	C OGILVIE
EX	303520	415V MIXER	BAKERITE AREA	CLASS1	VISUAL	VISUAL	-	-	PASS	C OGILVIE
EX	303521	TRUCK CHARGER	WAREHOUSE	CLASS1	N/A	>20	-	13	PASS	C OGILVIE
EX	303522	PRESSURE WASHER	WAREHOUSE	CLASS1	0.11	>20	-	13	PASS	C OGILVIE
EX	303523	110V TRANSFORMER	WAREHOUSE	CLASS1	0.07	>20	-	13	PASS	C OGILVIE
EX	303524	110V VACUUM CLEANER	WAREHOUSE	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303525	SHREDDER	OFFICE AREA	CLASS1	N/A	>20	-	5	PASS	C OGILVIE
EX	303526	POWER SUPPLY UNIT	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303527	IEC LEAD	OFFICE AREA	CLASS1	0.04	>20	PASS	3	PASS	C OGILVIE
EX	303528	POWER SUPPLY UNIT	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303529	POWER LEAD	OFFICE AREA	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	303530	MONITOR	OFFICE AREA	CLASS1	0.09	>20	-	-	PASS	C OGILVIE
EX	303531	IEC LEAD	OFFICE AREA	CLASS1	0.08	>20	PASS	5	PASS	C OGILVIE
EX	303532	PHOTOCOPIER	OFFICE AREA	CLASS1	0.07	>20	-	-	PASS	C OGILVIE
EX	303533	IEC LEAD	OFFICE AREA	CLASS1	0.06	>20	PASS	13	PASS	C OGILVIE
EX	303534	AC ADAPTER	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303535	AC ADAPTER	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303536	MONITOR	OFFICE AREA	CLASS1	0.08	>20	-	-	PASS	C OGILVIE
EX	303537	IEC LEAD	OFFICE AREA	CLASS1	0.07	>20	PASS	5	PASS	C OGILVIE
EX	303538	MONITOR	OFFICE AREA	CLASS1	0.08	>20	-	-	PASS	C OGILVIE
EX	303539	IEC LEAD	OFFICE AREA	CLASS1	0.07	>20	PASS	5	PASS	C OGILVIE
EX	303540	AC ADAPTER	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303541	AC ADAPTER	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE



6, Nelson Close, Shepshed, Loughborough, Leics. LE12 9TH
 Tel: 01509 562182 Mob: 07879644474
 E-mail: sales@excelpat.co.uk
 Website: www.excelpat.co.uk

Test Results for Fixfire, Systems House, Old Station Close, Shepshed. LE12 9NJ
 Date Tested - 3rd August 2020
 Test Engineer - C Ogilvie C & G Certificate Ref 120208/2377-12/065711/FWO8749/M/05/08/67

Prefix	ID No	Description	Location	Type	Continuity Result (Ω)	Insulation Result (m Ω)	Polarity Status	Fuse (Amps)	Status	Tested By
EX	303542	POWER SUPPLY UNIT	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303543	IEC LEAD	OFFICE AREA	CLASS1	0.06	>20	PASS	3	PASS	C OGILVIE
EX	303544	TOASTER	KITCHEN AREA	CLASS1	0.07	>20	-	13	PASS	C OGILVIE
EX	303545	MICROWAVE	KITCHEN AREA	CLASS1	0.04	>20	-	13	PASS	C OGILVIE
EX	303546	WATER HEATER	KITCHEN AREA	CLASS1	0.04	>20	-	13	PASS	C OGILVIE
EX	303547	DISHWASHER	KITCHEN AREA	CLASS1	0.07	>20	-	13	PASS	C OGILVIE
EX	303548	WATER HEATER	KITCHEN AREA	CLASS1	0.09	>20	-	13	PASS	C OGILVIE
EX	303549	FRIDGE/FREEZER	KITCHEN AREA	CLASS1	0.09	>20	-	13	PASS	C OGILVIE
EX	303550	4 GANG EXTENSION	OFFICE AREA	CLASS1	0.03	>20	PASS	10	PASS	C OGILVIE
EX	303551	AC ADAPTER	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303552	MONITOR	OFFICE AREA	CLASS1	0.07	>20	-	-	PASS	C OGILVIE
EX	303553	IEC LEAD	OFFICE AREA	CLASS1	0.06	>20	PASS	5	PASS	C OGILVIE
EX	303554	MONITOR	OFFICE AREA	CLASS1	0.06	>20	-	-	PASS	C OGILVIE
EX	303555	IEC LEAD	OFFICE AREA	CLASS1	0.05	>20	PASS	5	PASS	C OGILVIE
EX	303556	POWER SUPPLY UNIT	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303557	IEC LEAD	OFFICE AREA	CLASS1	0.04	>20	PASS	3	PASS	C OGILVIE
EX	303558	TELEVISION	OFFICE AREA	CLASS1	0.06	>20	-	-	PASS	C OGILVIE
EX	303559	IEC LEAD	OFFICE AREA	CLASS1	0.05	>20	PASS	10	PASS	C OGILVIE
EX	303560	COMPUTER/PC	OFFICE AREA	CLASS1	0.10	>20	-	-	PASS	C OGILVIE
EX	303561	IEC LEAD	OFFICE AREA	CLASS1	0.04	>20	PASS	-	PASS	C OGILVIE
EX	303562	IEC LEAD	OFFICE AREA	CLASS1	0.05	>20	PASS	5	PASS	C OGILVIE
EX	303563	AC ADAPTER	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303564	POWER SUPPLY UNIT	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303565	POWER LEAD	OFFICE AREA	CLASS2	-	>20	-	5	PASS	C OGILVIE
EX	303566	MONITOR	OFFICE AREA	CLASS1	0.07	>20	-	-	PASS	C OGILVIE
EX	303567	IEC LEAD	OFFICE AREA	CLASS1	0.06	>20	PASS	5	PASS	C OGILVIE
EX	303568	MONITOR	OFFICE AREA	CLASS1	0.06	>20	-	-	PASS	C OGILVIE
EX	303569	IEC LEAD	OFFICE AREA	CLASS1	0.05	>20	PASS	5	PASS	C OGILVIE
EX	303570	4 GANG EXTENSION	OFFICE AREA	CLASS1	0.03	>20	PASS	13	PASS	C OGILVIE
EX	303571	MONITOR	OFFICE AREA	CLASS1	0.07	>20	-	-	PASS	C OGILVIE
EX	303572	IEC LEAD	OFFICE AREA	CLASS1	0.06	>20	PASS	5	PASS	C OGILVIE
EX	303573	AC ADAPTER	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303574	MONITOR	OFFICE AREA	CLASS1	0.08	>20	-	-	PASS	C OGILVIE
EX	303575	IEC LEAD	OFFICE AREA	CLASS1	0.07	>20	PASS	5	PASS	C OGILVIE
EX	303576	MONITOR	OFFICE AREA	CLASS1	0.06	>20	-	-	PASS	C OGILVIE
EX	303577	IEC LEAD	OFFICE AREA	CLASS1	0.05	>20	PASS	5	PASS	C OGILVIE
EX	303578	COMPUTER/PC	OFFICE AREA	CLASS1	0.05	>20	-	-	PASS	C OGILVIE
EX	303579	IEC LEAD	OFFICE AREA	CLASS1	0.04	>20	PASS	10	PASS	C OGILVIE
EX	303580	COMPUTER/PC	OFFICE AREA	CLASS1	0.08	>20	-	-	PASS	C OGILVIE
EX	303581	IEC LEAD	OFFICE AREA	CLASS1	0.07	>20	PASS	5	PASS	C OGILVIE



6, Nelson Close, Shepshed, Loughborough, Leics. LE12 9TH
 Tel: 01509 562182 Mob: 07879644474
 E-mail: sales@excelpat.co.uk
 Website: www.excelpat.co.uk

Test Results for Fixfire, Systems House, Old Station Close, Shepshed. LE12 9NJ
 Date Tested - 3rd August 2020
 Test Engineer - C Ogilvie C & G Certificate Ref 120208/2377-12/065711/FWO8749/M/05/08/67

Prefix	ID No	Description	Location	Type	Continuity Result (Ω)	Insulation Result (m Ω)	Polarity Status	Fuse (Amps)	Status	Tested By
EX	303582	MONITOR	OFFICE AREA	CLASS1	0.07	>20	-	-	PASS	C OGILVIE
EX	303583	IEC LEAD	OFFICE AREA	CLASS1	0.06	>20	PASS	5	PASS	C OGILVIE
EX	303584	MONITOR	OFFICE AREA	CLASS1	0.08	>20	-	-	PASS	C OGILVIE
EX	303585	IEC LEAD	OFFICE AREA	CLASS1	0.07	>20	PASS	5	PASS	C OGILVIE
EX	303586	AC ADAPTER	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303587	IEC LEAD	OFFICE AREA	CLASS1	0.07	>20	PASS	5	PASS	C OGILVIE
EX	303588	IEC LEAD	OFFICE AREA	CLASS1	0.06	>20	PASS	5	PASS	C OGILVIE
EX	303589	MONITOR	OFFICE AREA	CLASS1	0.06	>20	-	-	PASS	C OGILVIE
EX	303590	IEC LEAD	OFFICE AREA	CLASS1	0.05	>20	PASS	5	PASS	C OGILVIE
EX	303591	MONITOR	OFFICE AREA	CLASS1	0.05	>20	-	-	PASS	C OGILVIE
EX	303592	AC ADAPTER	OFFICE AREA	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	303593	HEATER	OFFICE AREA	CLASS1	0.06	>20	-	13	PASS	C OGILVIE

FAILED APPLIANCES SUMMARY

Prefix	ID No	Description	Location	Type	Status	Reason
--------	-------	-------------	----------	------	--------	--------

Notes on Testing Frequency

As stated in the IET Code of Practice for In-service Inspection and Testing of Electrical Equipment 4th Edition.
 The Date on which the Test/Inspection took place should be stated on the label. The Date for re-testing should not be on the label.
 The Duty-Holder should determine the date for the next inspection and/or tests based on a risk based assessment.