



6, Nelson Close,
Shepshed,
Loughborough,
Leics.

LE12 9TH

Tel: 01509 562182 Mob: 07879644474


E-mail: sales@excelpat.co.uk

Web: www.excelpat.co.uk

Portable Appliance Test Results For

**Fixfire.
Mayflower House,
Bodmin Road,
Coventry,
CV2 5DB.**

25th February 2021





6, Nelson Close, Shepshed, Loughborough, Leics. LE12 9TH
 Tel: 01509 562182 Mob: 07879644474
 E-mail: sales@excelpat.co.uk
 Website: www.excelpat.co.uk

Test Results for Fixfire, Mayflower House, Bodmin Road, Coventry. CV2 5DB

Date Tested - 25th February 2021

Test Engineer - C Ogilvie C & G Certificate Ref 120208/2377-12/065711/FWO8749/M/05/08/67

Prefix	ID No	Description	Location	Type	Continuity Result (Ω)	Insulation Result (m Ω)	Polarity Status	Fuse (Amps)	Status	Tested By
EX	324399	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324400	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324401	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324402	IEC LEAD	ENGINEERS	CLASS1	0.07	>20	PASS	3	PASS	C OGILVIE
EX	324403	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324404	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324405	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324406	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324407	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324408	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324409	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324410	POWER LEAD	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324411	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324412	AC ADAPTER	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324413	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324414	IEC LEAD	ENGINEERS	CLASS1	0.05	>20	PASS	3	PASS	C OGILVIE
EX	324415	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324416	IEC LEAD	ENGINEERS	CLASS1	0.06	>20	PASS	3	PASS	C OGILVIE
EX	324417	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324418	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324419	AC ADAPTER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324420	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324421	POWER LEAD	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324422	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324423	IEC LEAD	ENGINEERS	CLASS1	0.07	>20	PASS	3	PASS	C OGILVIE
EX	324424	VACUUM CLEANER	STORES	CLASS2	-	>20	-	13	PASS	C OGILVIE
EX	324425	BATTERY CHARGER	STORES	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324426	POWER LEAD	STORES	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324427	AC ADAPTER	STORES	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324428	VACUUM CLEANER	STORES	CLASS2	-	>20	-	13	PASS	C OGILVIE
EX	324429	BATTERY CHARGER	STORES	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324430	BATTERY CHARGER	STORES	CLASS2	-	>20	-	5	PASS	C OGILVIE
EX	324431	BATTERY CHARGER	STORES	CLASS2	-	>20	-	13	PASS	C OGILVIE
EX	324432	BATTERY CHARGER	STORES	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324433	BATTERY CHARGER	STORES	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324434	BATTERY CHARGER	STORES	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324435	BATTERY CHARGER	STORES	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324436	VACUUM CLEANER	STORES	CLASS2	-	>20	-	13	PASS	C OGILVIE
EX	324437	110V TRANSFORMER	STORES	CLASS1	0.04	>20	-	13	PASS	C OGILVIE
EX	324438	110V TRANSFORMER	STORES	CLASS1	0.09	>20	-	13	PASS	C OGILVIE



6, Nelson Close, Shepshed, Loughborough, Leics. LE12 9TH
 Tel: 01509 562182 Mob: 07879644474
 E-mail: sales@excelpat.co.uk
 Website: www.excelpat.co.uk

Test Results for Fixfire, Mayflower House, Bodmin Road, Coventry. CV2 5DB

Date Tested - 25th February 2021

Test Engineer - C Ogilvie C & G Certificate Ref 120208/2377-12/065711/FWO8749/M/05/08/67

Prefix	ID No	Description	Location	Type	Continuity Result (Ω)	Insulation Result (m Ω)	Polarity Status	Fuse (Amps)	Status	Tested By
EX	324440	110V FLOODLIGHT	STORES	CLASS1	0.06	>20	-	-	PASS	C OGILVIE
EX	324441	VACUUM CLEANER	STORES	CLASS2	-	>20	-	13	PASS	C OGILVIE
EX	324442	VACUUM CLEANER	STORES	CLASS2	-	>20	-	13	PASS	C OGILVIE
EX	324443	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324444	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324445	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324446	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324447	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324448	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324449	POWER LEAD	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324450	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324451	IEC LEAD	ENGINEERS	CLASS1	0.07	>20	PASS	3	PASS	C OGILVIE
EX	324452	4 GANG EXTENSION REEL 10M	ENGINEERS	CLASS1	0.19	>20	PASS	10	PASS	C OGILVIE
EX	324453	AC ADAPTER	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324454	110V CHOPSAW	STORES	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324455	VACUUM CLEANER	ENGINEERS	CLASS2	-	>20	-	13	PASS	C OGILVIE
EX	324456	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324457	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324458	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324459	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324460	POWER LEAD	ENGINEERS	CLASS2	-	>20	-	13	PASS	C OGILVIE
EX	324461	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324462	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324463	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324464	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324465	POWER LEAD	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324466	POWER LEAD	ENGINEERS	CLASS2	-	>20	-	5	PASS	C OGILVIE
EX	324467	VACUUM CLEANER	TOOL ROOM	CLASS2	-	>20	-	10	PASS	C OGILVIE
EX	324468	DESK LIGHT	TOOL ROOM	CLASS1	0.08	>20	-	3	PASS	C OGILVIE
EX	324469	2 GANG EXTENSION	TOOL ROOM	CLASS1	0.07	>20	PASS	13	PASS	C OGILVIE
EX	324470	PILLAR DRILL	TOOL ROOM	CLASS1	0.11	>20	-	13	PASS	C OGILVIE
EX	324471	DREMEL	TOOL ROOM	CLASS1	N/A	>20	-	3	PASS	C OGILVIE
EX	324472	POWER SUPPLY UNIT	TOOL ROOM	CLASS2	-	>20	-	5	PASS	C OGILVIE
EX	324473	BENCH GRINDER	TOOL ROOM	CLASS1	0.05	>20	-	3	PASS	C OGILVIE
EX	324474	EXTRACTOR UNIT	TOOL ROOM	CLASS1	0.08	>20	-	5	PASS	C OGILVIE
EX	324502	GLUE GUN	TOOL ROOM	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324503	GLUE GUN	TOOL ROOM	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324504	415V TRANSFORMER	TOOL ROOM	CLASS1	0.18	>20	-	13	PASS	C OGILVIE
EX	324505	415V PILLAR DRILL	TOOL ROOM	CLASS1	0.05	>20	-	-	PASS	C OGILVIE
EX	324506	BENCH DRILL	TOOL ROOM	CLASS1	0.06	>20	-	5	PASS	C OGILVIE



6, Nelson Close, Shepshed, Loughborough, Leics. LE12 9TH
 Tel: 01509 562182 Mob: 07879644474
 E-mail: sales@excelpat.co.uk
 Website: www.excelpat.co.uk

Test Results for Fixfire, Mayflower House, Bodmin Road, Coventry. CV2 5DB

Date Tested - 25th February 2021

Test Engineer - C Ogilvie C & G Certificate Ref 120208/2377-12/065711/FWO8749/M/05/08/67

Prefix	ID No	Description	Location	Type	Continuity Result (Ω)	Insulation Result (m Ω)	Polarity Status	Fuse (Amps)	Status	Tested By
EX	324507	KETTLE	CANTEEN	CLASS1	0.05	>20	-	-	PASS	C OGILVIE
EX	324508	KETTLE BASE	CANTEEN	CLASS1	0.04	>20	-	13	PASS	C OGILVIE
EX	324509	MICROWAVE	CANTEEN	CLASS1	0.05	>20	-	13	PASS	C OGILVIE
EX	324510	COFFEE MACHINE	CANTEEN	CLASS1	N/A	>20	-	13	PASS	C OGILVIE
EX	324511	FRIDGE	CANTEEN	CLASS1	0.09	>20	-	13	PASS	C OGILVIE
EX	324512	KETTLE	KITCHEN	CLASS1	0.06	>20	-	-	PASS	C OGILVIE
EX	324513	KETTLE BASE	KITCHEN	CLASS1	0.05	>20	-	13	PASS	C OGILVIE
EX	324514	TOASTER	KITCHEN	CLASS1	0.05	>20	-	13	PASS	C OGILVIE
EX	324515	FRIDGE/FREEZER	KITCHEN	CLASS1	0.07	>20	-	13	PASS	C OGILVIE
EX	324516	MICROWAVE	KITCHEN	CLASS1	0.03	>20	-	13	PASS	C OGILVIE
EX	324517	OVEN/HOB	KITCHEN	CLASS1	0.07	>20	-	13	PASS	C OGILVIE
EX	324518	DISHWASHER	KITCHEN	CLASS1	0.09	>20	-	13	PASS	C OGILVIE
EX	324519	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324520	IEC LEAD	ENGINEERS	CLASS1	0.07	>20	PASS	5	PASS	C OGILVIE
EX	324521	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324522	IEC LEAD	ENGINEERS	CLASS1	0.05	>20	PASS	5	PASS	C OGILVIE
EX	324523	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324524	IEC LEAD	ENGINEERS	CLASS1	0.06	>20	PASS	3	PASS	C OGILVIE
EX	324525	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324526	POWER LEAD	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324527	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324528	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324529	IEC LEAD	ENGINEERS	CLASS1	0.05	>20	PASS	3	PASS	C OGILVIE
EX	324530	PUMP	FLOW SOLDERING ROOM	CLASS1	0.09	>20	-	13	PASS	C OGILVIE
EX	324531	6 GANG EXTENSION	FLOW SOLDERING ROOM	CLASS1	0.05	>20	PASS	13	PASS	C OGILVIE
EX	324532	EXTRACTOR UNIT	FLOW SOLDERING ROOM	CLASS2	-	>20	-	2	PASS	C OGILVIE
EX	324533	SOLDERING UNIT	FLOW SOLDERING ROOM	CLASS1	0.08	>20	-	-	PASS	C OGILVIE
EX	324534	IEC LEAD	FLOW SOLDERING ROOM	CLASS1	0.07	>20	PASS	13	PASS	C OGILVIE
EX	324535	IEC LEAD	FLOW SOLDERING ROOM	CLASS1	0.06	>20	PASS	3	PASS	C OGILVIE
EX	324536	EXTRACTOR UNIT	FLOW SOLDERING ROOM	CLASS1	0.11	>20	-	-	PASS	C OGILVIE
EX	324537	IEC LEAD	FLOW SOLDERING ROOM	CLASS1	0.10	>20	PASS	10	PASS	C OGILVIE
EX	324585	PEDESTAL FAN	FLOW SOLDERING ROOM	CLASS1	N/A	>20	-	3	PASS	C OGILVIE
EX	324538	4 GANG EXTENSION	WORKSHOP	CLASS1	0.09	>20	PASS	13	PASS	C OGILVIE
EX	324539	AC ADAPTER	WORKSHOP	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324540	TIMER COUNTER UNIT	WORKSHOP	CLASS1	0.09	>20	-	-	PASS	C OGILVIE
EX	324541	IEC LEAD	WORKSHOP	CLASS1	0.08	>20	PASS	5	PASS	C OGILVIE
EX	324542	AMPLIFIER UNIT	WORKSHOP	CLASS1	0.09	>20	-	-	PASS	C OGILVIE
EX	324543	IEC LEAD	WORKSHOP	CLASS1	0.08	>20	PASS	13	PASS	C OGILVIE
EX	324544	IEC LEAD	WORKSHOP	CLASS1	0.06	>20	PASS	13	PASS	C OGILVIE
EX	324545	AC ADAPTER	WORKSHOP	CLASS2	-	>20	-	-	PASS	C OGILVIE



6, Nelson Close, Shepshed, Loughborough, Leics. LE12 9TH
 Tel: 01509 562182 Mob: 07879644474
 E-mail: sales@excelpat.co.uk
 Website: www.excelpat.co.uk

Test Results for Fixfire, Mayflower House, Bodmin Road, Coventry. CV2 5DB

Date Tested - 25th February 2021

Test Engineer - C Ogilvie C & G Certificate Ref 120208/2377-12/065711/FWO8749/M/05/08/67

Prefix	ID No	Description	Location	Type	Continuity Result (Ω)	Insulation Result (m Ω)	Polarity Status	Fuse (Amps)	Status	Tested By
EX	324546	MASTER CONTROL UNIT	WORKSHOP	CLASS1	0.08	>20	-	5	PASS	C OGILVIE
EX	324547	IEC LEAD	WORKSHOP	CLASS1	0.08	>20	PASS	5	PASS	C OGILVIE
EX	324548	12 GANG BENCH EXTENSION	WORKSHOP	CLASS1	0.09	>20	PASS	13	PASS	C OGILVIE
EX	324549	4 GANG EXTENSION	WORKSHOP	CLASS1	0.06	>20	PASS	13	PASS	C OGILVIE
EX	324550	POWER SUPPLY UNIT	WORKSHOP	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324551	IEC LEAD	WORKSHOP	CLASS1	0.06	>20	PASS	3	PASS	C OGILVIE
EX	324552	ULTRA CURVE PROLINE UNIT	WORKSHOP	CLASS1	0.09	>20	-	-	PASS	C OGILVIE
EX	324553	IEC LEAD	WORKSHOP	CLASS1	0.08	>20	PASS	10	PASS	C OGILVIE
EX	324554	AMPLIFIER UNIT	WORKSHOP	CLASS1	0.07	>20	-	5	PASS	C OGILVIE
EX	324555	BATTERY CHARGER	WORKSHOP	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324556	POWER SUPPLY UNIT	WORKSHOP	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324557	IEC LEAD	WORKSHOP	CLASS1	0.08	>20	PASS	5	PASS	C OGILVIE
EX	324558	BATTERY CHARGER	WORKSHOP	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324559	POWER LEAD	WORKSHOP	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324560	AMPLIFIER UNIT	WORKSHOP	CLASS1	0.08	>20	-	-	PASS	C OGILVIE
EX	324561	TRANSFORMER	WORKSHOP	CLASS1	0.09	>20	-	13	PASS	C OGILVIE
EX	324562	POWER SUPPLY UNIT	WORKSHOP	CLASS1	0.11	>20	-	3	PASS	C OGILVIE
EX	324563	POWER SUPPLY UNIT	WORKSHOP	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324564	POWER SUPPLY UNIT	WORKSHOP	CLASS1	0.18	>20	-	3	PASS	C OGILVIE
EX	324565	POWER SUPPLY UNIT	WORKSHOP	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324566	GLUE GUN	WORKSHOP	CLASS2	-	>20	-	13	PASS	C OGILVIE
EX	324567	DESK LIGHT	WORKSHOP	CLASS1	0.09	>20	-	3	PASS	C OGILVIE
EX	324568	FAN	WORKSHOP	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324569	POWER SUPPLY UNIT	WORKSHOP	CLASS1	0.09	>20	-	3	PASS	C OGILVIE
EX	324570	IEC LEAD	WORKSHOP	CLASS1	0.07	>20	PASS	5	PASS	C OGILVIE
EX	324571	4 GANG EXTENSION	WORKSHOP	CLASS1	0.04	>20	PASS	13	PASS	C OGILVIE
EX	324572	LABEL PRINTER	WORKSHOP	CLASS1	0.11	>20	-	-	PASS	C OGILVIE
EX	324573	IEC LEAD	WORKSHOP	CLASS1	0.10	>20	PASS	13	PASS	C OGILVIE
EX	324574	AC ADAPTER	WORKSHOP	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324575	COMPUTER/PC	WORKSHOP	CLASS1	VISUAL	VISUAL	-	-	PASS	C OGILVIE
EX	324576	IEC LEAD	WORKSHOP	CLASS1	VISUAL	VISUAL	-	-	PASS	C OGILVIE
EX	324577	4 GANG EXTENSION	WORKSHOP	CLASS1	VISUAL	VISUAL	-	-	PASS	C OGILVIE
EX	324578	NETWORK SWITCH	WORKSHOP	CLASS1	VISUAL	VISUAL	-	-	PASS	C OGILVIE
EX	324579	IEC LEAD	WORKSHOP	CLASS1	VISUAL	VISUAL	-	-	PASS	C OGILVIE
EX	324580	COMPUTER/PC	WORKSHOP	CLASS1	0.07	>20	-	-	PASS	C OGILVIE
EX	324581	IEC LEAD	WORKSHOP	CLASS1	0.06	>20	PASS	13	PASS	C OGILVIE
EX	324582	MONITOR	WORKSHOP	CLASS1	0.07	>20	-	-	PASS	C OGILVIE
EX	324583	IEC LEAD	WORKSHOP	CLASS1	0.06	>20	PASS	13	PASS	C OGILVIE
EX	324584	4 GANG EXTENSION	WORKSHOP	CLASS1	VISUAL	VISUAL	-	-	PASS	C OGILVIE
EX	324586	DESK LIGHT	WORKSHOP	CLASS1	0.06	>20	-	3	PASS	C OGILVIE



6, Nelson Close, Shepshed, Loughborough, Leics. LE12 9TH
 Tel: 01509 562182 Mob: 07879644474
 E-mail: sales@excelpat.co.uk
 Website: www.excelpat.co.uk

Test Results for Fixfire, Mayflower House, Bodmin Road, Coventry. CV2 5DB

Date Tested - 25th February 2021

Test Engineer - C Ogilvie C & G Certificate Ref 120208/2377-12/065711/FWO8749/M/05/08/67

Prefix	ID No	Description	Location	Type	Continuity Result (Ω)	Insulation Result (m Ω)	Polarity Status	Fuse (Amps)	Status	Tested By
EX	324587	PUMP	WORKSHOP	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324588	DESK LIGHT	WORKSHOP	CLASS1	0.06	>20	-	3	PASS	C OGILVIE
EX	324589	MICROSCOPE	WORKSHOP	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324590	IEC LEAD	WORKSHOP	CLASS1	0.05	>20	PASS	13	PASS	C OGILVIE
EX	324591	VACUUM CLEANER	WORKSHOP	CLASS2	-	>20	-	13	PASS	C OGILVIE
EX	324592	EXTRACTOR UNIT	WORKSHOP	CLASS1	0.13	>20	-	-	PASS	C OGILVIE
EX	324593	IEC LEAD	WORKSHOP	CLASS1	0.12	>20	PASS	3	PASS	C OGILVIE
EX	324594	PEDESTAL FAN	WORKSHOP	CLASS1	N/A	>20	-	3	PASS	C OGILVIE
EX	324595	IEC LEAD	WORKSHOP	CLASS1	0.08	>20	PASS	5	PASS	C OGILVIE
EX	324596	SOLDERING UNIT	WORKSHOP	CLASS1	N/A	>20	-	-	PASS	C OGILVIE
EX	324597	IEC LEAD	WORKSHOP	CLASS1	0.06	>20	PASS	10	PASS	C OGILVIE
EX	324598	AIR CONDITIONING UNIT	WORKSHOP	CLASS1	N/A	>20	-	13	PASS	C OGILVIE
EX	324599	LIGHT BOX	WORKSHOP	CLASS1	0.14	>20	-	3	PASS	C OGILVIE
EX	324600	8 GANG BENCH EXTENSION	WORKSHOP	CLASS1	0.11	>20	PASS	13	PASS	C OGILVIE
EX	324601	4 GANG EXTENSION REEL 12M	WORKSHOP	CLASS1	0.19	>20	PASS	13	PASS	C OGILVIE
EX	324602	POWER SUPPLY UNIT	WORKSHOP	CLASS2	-	>20	-	13	PASS	C OGILVIE
EX	324603	4 GANG IEC EXTENSION	WORKSHOP	CLASS1	0.07	>20	PASS	-	PASS	C OGILVIE
EX	324604	IEC LEAD	WORKSHOP	CLASS1	0.06	>20	PASS	13	PASS	C OGILVIE
EX	324605	COMPUTER/PC	WORKSHOP	CLASS1	0.06	>20	-	-	PASS	C OGILVIE
EX	324606	IEC LEAD	WORKSHOP	CLASS1	0.05	>20	PASS	-	PASS	C OGILVIE
EX	324607	MONITOR	WORKSHOP	CLASS1	0.08	>20	-	-	PASS	C OGILVIE
EX	324608	IEC LEAD	WORKSHOP	CLASS1	0.07	>20	PASS	-	PASS	C OGILVIE
EX	324609	CONTROL UNIT	WORKSHOP	CLASS1	0.09	>20	-	-	PASS	C OGILVIE
EX	324610	IEC LEAD	WORKSHOP	CLASS1	0.08	>20	PASS	-	PASS	C OGILVIE
EX	324611	PEDESTAL FAN	WORKSHOP	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324612	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324613	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324614	IEC LEAD	ENGINEERS	CLASS1	0.07	>20	PASS	3	PASS	C OGILVIE
EX	324615	AC ADAPTER	STORES	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324616	AC ADAPTER	STORES	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324617	AC ADAPTER	STORES	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324618	POWER SUPPLY UNIT	STORES	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324619	POWER LEAD	STORES	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324620	HEAT GUN	STORES	CLASS2	-	>20	-	10	PASS	C OGILVIE
EX	324621	AC ADAPTER	STORES	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324622	IEC LEAD	WORKSHOP	CLASS1	0.06	>20	PASS	3	PASS	C OGILVIE
EX	324623	6 GANG EXTENSION	WORKSHOP	CLASS1	0.07	>20	PASS	13	PASS	C OGILVIE
EX	324624	EXTRACTOR UNIT	WORKSHOP	CLASS1	0.09	>20	-	-	PASS	C OGILVIE
EX	324625	IEC LEAD	WORKSHOP	CLASS1	0.08	>20	PASS	10	PASS	C OGILVIE
EX	324626	SOLDERING UNIT	WORKSHOP	CLASS2	-	>20	-	3	PASS	C OGILVIE



6, Nelson Close, Shepshed, Loughborough, Leics. LE12 9TH
 Tel: 01509 562182 Mob: 07879644474
 E-mail: sales@excelpat.co.uk
 Website: www.excelpat.co.uk

Test Results for Fixfire, Mayflower House, Bodmin Road, Coventry. CV2 5DB

Date Tested - 25th February 2021

Test Engineer - C Ogilvie C & G Certificate Ref 120208/2377-12/065711/FWO8749/M/05/08/67

Prefix	ID No	Description	Location	Type	Continuity Result (Ω)	Insulation Result (m Ω)	Polarity Status	Fuse (Amps)	Status	Tested By
EX	324627	EXTRACTOR UNIT	WORKSHOP	CLASS1	0.09	>20	-	-	PASS	C OGILVIE
EX	324628	IEC LEAD	WORKSHOP	CLASS1	0.08	>20	PASS	3	PASS	C OGILVIE
EX	324629	SOLDERING UNIT	WORKSHOP	CLASS1	N/A	>20	-	-	PASS	C OGILVIE
EX	324630	IEC LEAD	WORKSHOP	CLASS1	0.08	>20	PASS	10	PASS	C OGILVIE
EX	324631	SOLDERING UNIT	WORKSHOP	CLASS1	N/A	>20	-	-	PASS	C OGILVIE
EX	324632	IEC LEAD	WORKSHOP	CLASS1	0.08	>20	PASS	3	PASS	C OGILVIE
EX	324633	MICROSCOPE	WORKSHOP	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324634	POWER LEAD	WORKSHOP	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324635	6 GANG EXTENSION	WORKSHOP	CLASS1	0.05	>20	PASS	13	PASS	C OGILVIE
EX	324636	6 GANG EXTENSION	WORKSHOP	CLASS1	0.03	>20	PASS	13	PASS	C OGILVIE
EX	324637	DESK LIGHT	WORKSHOP	CLASS1	0.09	>20	-	3	PASS	C OGILVIE
EX	324638	HEAT GUN	WORKSHOP	CLASS2	-	>20	-	10	PASS	C OGILVIE
EX	324639	MAGNIFYING LAMP	WORKSHOP	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324640	HEAT SEALER	PACKING ROOM	CLASS1	0.05	>20	-	3	PASS	C OGILVIE
EX	324641	SCALES	PACKING ROOM	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324642	POWER LEAD	PACKING ROOM	CLASS2	-	>20	-	5	PASS	C OGILVIE
EX	324643	4 GANG EXTENSION	WORKSHOP	CLASS1	0.05	>20	PASS	13	PASS	C OGILVIE
EX	324644	DESK LIGHT	WORKSHOP	CLASS1	0.07	>20	-	3	PASS	C OGILVIE
EX	324645	PATERNOSTER WORKSTATION	WORKSHOP	CLASS1	0.09	>20	-	3	PASS	C OGILVIE
EX	324646	PATERNOSTER WORKSTATION	WORKSHOP	CLASS1	0.12	>20	-	3	PASS	C OGILVIE
EX	324647	PATERNOSTER WORKSTATION	WORKSHOP	CLASS1	0.10	>20	-	3	PASS	C OGILVIE
EX	324648	6 GANG EXTENSION	WORKSHOP	CLASS1	0.09	>20	PASS	13	PASS	C OGILVIE
EX	324649	4 GANG EXTENSION	WORKSHOP	CLASS1	0.05	>20	PASS	13	PASS	C OGILVIE
EX	324650	4 GANG EXTENSION	WORKSHOP	CLASS1	0.04	>20	PASS	13	PASS	C OGILVIE
EX	324651	POWER SUPPLY UNIT	WORKSHOP	CLASS2	-	>20	-	2	PASS	C OGILVIE
EX	324652	SOLDERING UNIT	WORKSHOP	CLASS1	N/A	>20	-	-	PASS	C OGILVIE
EX	324653	IEC LEAD	WORKSHOP	CLASS1	0.06	>20	PASS	5	PASS	C OGILVIE
EX	324654	SOLDERING UNIT	WORKSHOP	CLASS1	N/A	>20	-	-	PASS	C OGILVIE
EX	324655	IEC LEAD	WORKSHOP	CLASS1	0.04	>20	PASS	13	PASS	C OGILVIE
EX	324656	DESOLDERING GUN	WORKSHOP	CLASS1	0.08	>20	-	3	PASS	C OGILVIE
EX	324657	SOLDERING UNIT	WORKSHOP	CLASS1	N/A	>20	-	-	PASS	C OGILVIE
EX	324658	IEC LEAD	WORKSHOP	CLASS1	0.07	>20	PASS	3	PASS	C OGILVIE
EX	324659	HEAT GUN	WORKSHOP	CLASS2	-	>20	-	10	PASS	C OGILVIE
EX	324660	POWER SUPPLY UNIT	WORKSHOP	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324661	SOLDERING UNIT	WORKSHOP	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324662	DESK LIGHT	WORKSHOP	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324663	EXTRACTOR UNIT	WORKSHOP	CLASS1	0.08	>20	-	-	PASS	C OGILVIE
EX	324664	IEC LEAD	WORKSHOP	CLASS1	0.07	>20	PASS	3	PASS	C OGILVIE
EX	324665	MAGNIFYING LAMP	WORKSHOP	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324666	SOLDERING UNIT	WORKSHOP	CLASS2	-	>20	-	5	PASS	C OGILVIE



6, Nelson Close, Shepshed, Loughborough, Leics. LE12 9TH
 Tel: 01509 562182 Mob: 07879644474
 E-mail: sales@excelpat.co.uk
 Website: www.excelpat.co.uk

Test Results for Fixfire, Mayflower House, Bodmin Road, Coventry. CV2 5DB

Date Tested - 25th February 2021

Test Engineer - C Ogilvie C & G Certificate Ref 120208/2377-12/065711/FWO8749/M/05/08/67

Prefix	ID No	Description	Location	Type	Continuity Result (Ω)	Insulation Result (mΩ)	Polarity Status	Fuse (Amps)	Status	Tested By
EX	324667	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324668	IEC LEAD	ENGINEERS	CLASS1	0.06	>20	PASS	3	PASS	C OGILVIE
EX	324669	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324670	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324671	AC ADAPTER	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324672	POWER LEAD	ENGINEERS	CLASS2	FAIL	FAIL	FAIL	FAIL	FAIL	C OGILVIE
EX	324673	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324674	POWER LEAD	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324675	POWER SUPPLY UNIT	ENGINEERS	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324676	IEC LEAD	ENGINEERS	CLASS1	0.07	>20	PASS	3	PASS	C OGILVIE
EX	324677	4 GANG EXTENSION REEL 10M	ENGINEERS	CLASS1	0.19	>20	PASS	10	PASS	C OGILVIE
EX	324678	AC ADAPTER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324679	BATTERY CHARGER	ENGINEERS	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324680	POWER SUPPLY UNIT	STORES	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324681	POWER LEAD	STORES	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324682	AC ADAPTER	STORES	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324683	POWER SUPPLY UNIT	STORES	CLASS2	-	>20	-	-	PASS	C OGILVIE
EX	324684	POWER LEAD	STORES	CLASS2	-	>20	-	3	PASS	C OGILVIE
EX	324685	IEC LEAD	STORES	CLASS1	0.06	>20	PASS	3	PASS	C OGILVIE
EX	324686	4 GANG EXTENSION REEL 10M	STORES	CLASS1	0.18	>20	PASS	10	PASS	C OGILVIE

FAILED APPLIANCES SUMMARY

Prefix	ID No	Description	Location	Type	Status	Reason	REPLACED
EX	324672	POWER LEAD	ENGINEERS	CLASS2	FAIL	Wires Exposed	REPLACED

Notes on Testing Frequency

As stated in the IET Code of Practice for In-service Inspection and Testing of Electrical Equipment 4th Edition.
 The Date on which the Test/Inspection took place should be stated on the label. The Date for re-testing should not be on the label.
 The Duty-Holder should determine the date for the next inspection and/or tests based on a risk based assessment.