

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Schweigen Pty Ltd
8 / 3-4 Anzed Court
Mulgrave VIC 3170
Australi

Test Number : 18-005737
Issue Date : 19/10/2018
Print Date : 1/11/2018

Sample Description Insulated flexible ducting
Colour : Black/Yellow/Silver

UL 181.16-2013

Static Load Test - Air Duct

Sample Tested	Core Tested
Diameter of Duct Tested	300 mm
Weight of Duct Tested	0.7818 Kg
Weight Used to Load Specimen	1.9545 Kg
Spacing for Supports	1500 mm

Observations made during visual examination : No damage observed

Compliance to AS/NZS 4254.1-2012 Clause 2.4.2(d) Complies

Load applied for 24 hours

146628

31094

Page 1 of 1

© Australian Wool testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

- Chemical Testing
- Mechanical Testing
- Performance & Approvals Testing

: Accreditation No. 983
: Accreditation No. 985
: Accreditation No. 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc. (Hons)
MANAGING DIRECTOR