

# Fire Extinguisher Inspection

Record NFPA 10 compliant monthly inspections and multi-year maintenance data. Immediately see inspections remotely from your team of inspectors. Find the digital version of this form and more at <https://www.fulcrumapp.com/apps/fire-extinguisher-inspection>.

---

## General information

Address Street Address \_\_\_\_\_

City, State, Zip \_\_\_\_\_

Property manager \_\_\_\_\_

Contact number or email address \_\_\_\_\_

Installation Questions \_\_\_\_\_

\_\_\_\_\_

Interior Extinguisher?  Yes  No

---

## Interior Extinguisher Inspection


Serial Number  
Barcode



▶ Mounted in an easily accessible place, no debris or material stacked in front of it.

Yes  No

Photo of interior extinguisher



- ▶ Safety pin is in place and intact. Nothing else should be used in place of the pin.  
 Yes     No
- ▶ Label is clear and extinguisher type and instructions can be read easily.  
 Yes     No
- ▶ Handle is intact and not bent or broken.  
 Yes     No
- ▶ Pressure gauge is in the green and is not damaged or showing “recharge”.  
 Yes     No
- ▶ Discharge hoses/nozzle is in good shape and not clogged, cracked, or broken.  
 Yes     No
- ▶ Extinguisher was turned upside down at least three times (shaken).  
 Yes     No

- ▶ Extinguisher was turned upside down at least three times (shaken).  
 Yes     No
- ▶ Exterior Extinguisher?  
 Yes     No

---

## Exterior Extinguisher Inspection

Serial Number  
Barcode

- ▶ Discharge Hose/nozzle is in good shape and not clogged, cracked, or broken.  
 Yes     No

Photo of exterior  
extinguisher

**Attach Key Photos Here**

With Fulcrum, photos you take with your phone automatically get included with the rest of your data.

- ▶ It is mounted in an easily accessible area, with nothing stacked around it.  
 Yes       No
  
- ▶ Safety Pin is in place and not damaged.  
 Yes       No
  
- ▶ Pressure gauge is in the green and is not damaged or showing “recharge”.  
 Yes       No
  
- ▶ Label is readable and displays the type of extinguisher and the instructions for use.  
 Yes       No
  
- ▶ It is not rusty, or has any type of corrosion build up.  
 Yes       No
  
- ▶ Extinguisher was turned upside down at least three times. (shaken)  
 Yes       No
  
- ▶ The location of the extinguisher is easily identifiable. (signs)  
 Yes       No

---

## Certification

▶ Passed?

Yes     No

Name of inspector

Please print

\_\_\_\_\_

Signature

\_\_\_\_\_

Date

\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Time

\_\_\_\_\_ : \_\_\_\_\_ **AM / PM**



Fulcrum is a mobile app creation platform that lets you digitize checklists like this easily — and automate related workflows! — without writing any code.

Check us out at [fulcrumapp.com/checklists](https://fulcrumapp.com/checklists)