







Test Report SL52035261863501TX Date:July 13,2020 Page 1 of 5

ZHEJIANG HONGYU MEDICAL COMMODITY CO., LTD

NO.668 CHANHUA ROAD FOTANG TOWN INDUSTRIAL FUNCTIONAL AREA 322002 YIWU CITY, ZHEJIANG PROVINCE PEOPLE'S REPUBLIC OF CHINA

The following sample(s) was/were submitted and identified on behalf of the client as:

Sample Description : (A)Medical face mask

SGS Internal Ref No. : SHHL2006525620MD

Sample Color : (A)Blue

Manufacturer : ZHEJIANG HONGYU MEDICAL COMMODITY CO., LTD

Country of Origin : China

Supplier : ZHEJIANG HONGYU MEDICAL COMMODITY CO., LTD

Roll/ Lot No. : 20061801

Other Information : Request Age Grading:2 years

Test Performed : Selected test(s) as requested by applicant

Sample Receiving Date : Jun 30, 2020

Testing Period : Jun 30, 2020 - Jul 13, 2020

Test Result(s) : Unless otherwise stated the results shown in this test report refer only to the

sample(s) tested, for further details, please refer to the following page(s).

Signed for and on behalf of SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd Testing Center

.

Sara Guo (Account Executive)

Helen Xuan (Authorized Signatory)



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's esponsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or, email: CN.Doccheck@sgs.com



Test Report

SL52035261863501TX

Date:July 13,2020

Page 2 of 5

Test Result

<u>Standard Specification for Performance of Materials Used in Medical Face Masks</u> (ASTM F2100-19)

Section 6.1 Bacterial filtration efficiency (BFE)

(ASTM F2101-19)

Sample: A

(BFE), %

Conditioning Parameters : Minimum of 4 hours at 21±5°C and 85±5% R.H.

Dimensions of test specimen : 110 mm x 110 mm

Test Area : ~60 cm²
Test Side : Inside
Flow Rate : 28.3 l/min
Positive Control Average : 1990.5 CFU
Negative Monitor Count : < 1 CFU

1# 2# 3# 4# 5# 99.9 99.9 99.9 99.9

Remark: Performance Requirement: Level 1≥95%, Level 2≥98%, Level 3≥98%



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions/Terms

3stBuilding,No.889,Yishan Road,Xuhui District Shanghai,China 200233 中国・上海・徐汇区宜山路889号3号楼 邮编: 200233 t (86-21) 61402666 t (86-21) 61402666

f (86–21) 64958763 f (86–21) 64958763 www.sgsgroup.com.cn e sgs.china@sgs.com



Test Report SL52035261863501TX Date:July 13,2020 Page 3 of 5

Section 6.1 Differential Pressure

(EN 14683 :2019+AC:2019 Annex C)

Sample: A

Test Side : Randomly test in different location (1 around and 4 away from the centric

point) on each of the 5 masks

Pre-Conditioning : Minimum of 4 hours at 21±5°C (70±10°F) and 85±5% R.H.

Test Area : 4.9 cm² Flow Rate : 8 l/min

Specimen No.	Test Area No.	Different Pressure for each tested area (mm H ₂ O/cm ²)	The average value for each test specimen (mm H ₂ O/cm ²)		
	1-1	3.63	, , , , , , , , , , , , , , , , , , ,		
	1-2	4.08			
1	1-3	4.06	3.9		
	1-4	3.76			
	1-5	3.77			
	2-1	3.89			
	2-2	3.87			
2	2-3	3.65	3.8		
	2-4	3.98			
	2-5	3.80			
	3-1	3.80			
3	3-2	3.65	3.7		
	3-3	3.75			
	3-4	3.61			
	3-5	3.80			
4	4-1	3.45			
	4-2	3.26			
	4-3	3.69	3.7		
	4-4	4.26			
	4-5	3.79	1		
5	5-1	3.80			
	5-2	3.94			
	5-3	3.58	3.7		
	5-4	3.52			
	5-5	3.67			

Remark:

- 1) Performance Requirement: Level 1 Barrier: <5.0mm H₂O/cm², Level 2 Barrier: <6.0 mm H₂O/cm², Level 3 Barrier: <6.0 mm H₂O/cm²
- 2) The number of specimens that shall be tested is minimum 5, but can be greater and shall be increased if necessary to allow for an AQL (Acceptable Quality Level) of 4%.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions/Terms

3stBuilding,No.889,Yishan Road,Xuhui District Shanghai,China 200233 中国・上海・徐汇区宜山路889号3号楼 邮编: 200233 t (86-21) 61402666 t (86-21) 61402666

f (86-21) 64958763

www.sgsgroup.com.cn e sgs.china@sgs.com



SL52035261863501TX Date:July 13,2020 Page 4 of 5 **Test Report**

Section 6.1 Resistance to Penetration by Synthetic Blood

(ASTM F1862/F1862M-2017)

Sample: A

Pressure 80mmHg

Penetration	on inside sur	face					
1#	2#	3#	4#	5#	6#	7#	8#
Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
9#	10#	11#	12#	13#	14#	15#	16#
Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
17#	18#	19#	20#	21#	22#	23#	24#
Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
25#	26#	27#	28#	29#	30#	31#	32#
Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Number of P	ass:		32				
Overall result:			Acceptable				

Remark:

- 1) Performance Requirement Level 1 Barrier: 80mmHg, Level 2 Barrier: 120mmHg, Level 3 Barrier: 160mmHg
- Distance of the medical face mask target area surface to the tip of cannula is 30.5cm.
- Condition and Test temperature (21±5)° C, relative humidity (85±5)%
- An acceptable quality limit of 4.0% is met for a single sampling plan when 29 or more of the 32 tested specimens show pass results

Section 6.2 Flammability

(16 CFR Part 1610 - 2008)

Sample Α Fabric Surface Smooth Test Specimen Direction Length

	As Received		
	Burn Code		
(1)	IBE		
(2)	IBE		
(3)	IBE		
(4)	IBE		
(5)	IBE		

Flammability Classification: Class 1

Requirement: Class 1 for Level 1/ Level 2/ Level 3

Conclusion: Pass

Remarks

Class 1 Normal Flammability

Class 1 textiles exhibit normal flammability and are acceptable for use in clothing.

Burn Code Description:

Ignited, but extinguished IBE



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's esponsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or, email: CN.Doccheck@sgs.com

3rdBuilding,No.889,Yishan Road,Xuhui District Shanghai,China 200233 t (86-21) 61402666 f (86-21) 64958763

中国・上海・徐汇区宜山路889号3号楼 邮编: 200233

t (86-21) 61402666 f (86-21) 64958763 e sgs.china@sgs.com



Test Report

SL52035261863501TX

Page 5 of 5



Date:July 13,2020



The statement of conformity in this test report is only based on measured values by the laboratory and does not take their uncertainties into consideration.

End of Report



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions/Terms

3rdBuilding,No.889,Yishan Road,Xuhui District Shanghai,China 200233 中国 • 上海 • 徐汇区宜山路889号3号楼 邮编: 200233 t (86-21) 61402666 t (86-21) 61402666 f (86–21) 64958763 f (86–21) 64958763 www.sgsgroup.com.cn e sgs.china@sgs.com