



April 2nd, 2022

Declaration of operational compliance between Tigo's TS4 Module Platform and Sungrow Inverters.

Tigo and Sungrow are pleased to announce that the following inverters from Sungrow:

SG5.0RT	SG10RT	SG15RT	SG17RT	SG20RT
SG30CX	SG33CX	SG40CX	SG50CX	SG100CX
SH5.0RT	SH6.0RT	SH8.0RT	SH10RT	

can be used successfully in combination with the following TS4 product families from Tigo in APAC regions:

TS4-A-O

TS4-A-S

Additionally, the following Sungrow inverters,

SG36CX-US

SG60CX-US

are **PVRSS certified for rapid shutdown** with Tigo models:

TS4-A-F

TS4-A-2F

Tigo and Sungrow have conducted testing and validated the effective performance of the systems together within standard testing environments. All inverters were evaluated with Tigo firmware 8.01 or earlier where noted. Warranties from Sungrow and Tigo will remain valid if the design, installation, and operation requirements are followed for each product.

Contact Tigo Support with any questions regarding Tigo's TS4 Platform equipment: support@tigoenergy.com or (408)-402-0802.

Tigo Energy, Inc.

655 Campbell Technology Pkwy, Ste 150
Campbell, CA 95008

Clark Cogan, Product Manager

Print Name and Title

Signature and Date
April 2, 2022

Sungrow

No. 1699 Xiyou Rd., New & High
Technology Industrial Development Zone,
Hefei, P. R. China., 230088

Regional Product Manager , Chuya Xu

Print Name and Title

Signature and Date
April 2, 2022