



A Bureau Veritas Group Company

# LEVEL II ENERGY AUDIT

## SACRAMENTO CITY UNIFIED SCHOOL DISTRICT

5735 47<sup>th</sup> Avenue  
Sacramento, California 95824

## DLR GROUP

1050 20<sup>th</sup> Street, Suite 250  
Sacramento, California 95971



## ZERO NET ENERGY ASHRAE LEVEL II AUDIT

### CAPITOL COLLEGIATE ACADEMY

2118 Meadowview Road  
Sacramento, California 95832

#### PREPARED BY:

EMG / A Bureau Veritas Company  
10461 Mill Run Circle, Suite 1100  
Owings Mills, Maryland 21117  
800.733.0660  
[www.emgcorp.com](http://www.emgcorp.com)

#### EMG CONTACT:

Kaustubh Anil Chabukswar  
Program Manager  
800.733.0660 x7512  
[kachabukswar@emgcorp.com](mailto:kachabukswar@emgcorp.com)

#### EMG PROJECT #:

136988.19R000-071.268

#### DATE OF REPORT:

October 25, 2019

#### ONSITE DATE:

September 26-27, 2019



engineering | environmental | capital planning | project management

A Bureau Veritas Group Company



[www.EMGcorp.com](http://www.EMGcorp.com) | 800.733.0660

# TABLE OF CONTENTS

<b>Certification .....</b>	<b>1</b>
<b>1. Executive Summary .....</b>	<b>2</b>
1.1. Energy Conservation Measures .....	2
<b>2. Introduction .....</b>	<b>8</b>
<b>3. Facility Overview and Existing Conditions .....</b>	<b>9</b>
3.1. Building Occupancy and Point of Contact .....	9
3.2. Building Heating, Ventilating and Air-Conditioning (HVAC) .....	9
3.3. Lighting .....	10
<b>4. Utility Analysis .....</b>	<b>11</b>
4.1. Electricity .....	12
4.2. Natural Gas .....	14
4.3. Water and Sewer .....	16
<b>5. Renewable Energy Discussions .....</b>	<b>18</b>
5.1. Rooftop Solar Photovoltaic Feasibility .....	18
<b>6. Operations and Maintenance Plan .....</b>	<b>20</b>
<b>7. Appendices .....</b>	<b>22</b>
Appendix A: .....	Glossary of Terms
Appendix B: .....	Mechanical Equipment Inventory
Appendix C: .....	Lighting System Schedule
Appendix D: .....	ECM Checklist
Appendix E: .....	ECM Calculations
Appendix F: .....	Solar PV

## Certification

---

EMG has completed an Energy Audit of Capitol Collegiate Academy located at 2118 Meadowview Road in Sacramento, California 95832. EMG visited the site on September 26-27, 2019.

The assessment was performed at the Client's request using methods and procedures consistent with ASHRAE Level II Energy Audit and using methods and procedures as outlined in EMG's Proposal.

This report has been prepared for and is exclusively for the use and benefit of the Client identified on the cover page of this report. The purpose for which this report shall be used shall be limited to the use as stated in the contract between the client and EMG.

This report, or any of the information contained therein, is not for the use or benefit of, nor may it be relied upon by any other person or entity, for any purpose without the advance written consent of EMG. Any reuse or distribution without such consent shall be at the client's or recipient's sole risk, without liability to EMG.

Estimated installation costs are based on EMG's experience on similar projects and industry standard cost estimating tools including *RS Means and Whitestone CostLab*. In developing the installed costs, EMG also considered the area correction factors for labor rates for Sacramento, California 95832. Since actual installed costs may vary widely for particular installation based on labor and material rates at time of installation, EMG does not guarantee installed cost estimates and shall in no event be liable should actual installed costs vary from the estimated costs herein. We strongly encourage the owner to confirm these cost estimates independently. EMG does not guarantee the costs savings estimated in this report. EMG shall in no event be liable should the actual energy savings vary from the savings estimated herein.

EMG certifies that EMG has no undisclosed interest in the subject property and that EMG's employment and compensation are not contingent upon the findings or estimated costs to remedy any deficiencies due to deferred maintenance and any noted component or system replacements.

Any questions regarding this report should be directed to Kaustubh Anil Chabukswar at 800.733.0660, ext. 7512.

**Prepared by:** Rashad Alnial  
Energy Auditor  
Project Manager



**Reviewed by:**

---

Al Diefert  
Technical Report Reviewer  
For  
Kaustubh Anil Chabukswar, CEM CRM  
Program Manager

## 1. Executive Summary

The purpose of this Energy Audit is to provide Sacramento City Unified School District and Capitol Collegiate Academy with a baseline of energy usage and the relative energy efficiency of the facility and specific recommendations for Energy Conservation Measures. Information obtained from these analyses may be used to support a future application to an Energy Conservation Program, Federal and Utility grants towards energy conservation, support performance contracting, justify a municipal bond funded improvement program, or as a basis for replacement of equipment or systems.

Building #	Structures Assessed	Building Type	EMG Calculated Area (SF)	Estimated Occupancy
1	Classrooms 1 to 4	School Building	5,535	75-100
2	Restrooms	School Building	451	1-6
3	Classrooms 6 to 10	School Building	5,294	75-100
4	Administration	School Building	2,155	25-50
5	Kindergarten	School Building	2,847	25-50
6	Multipurpose	School Building	4,720	75-100
7	Portable Classrooms 11 to 15	School Building	4,800	75-100
8	Portable Classrooms 34 and 35	School Building	1,800	20-40
9	Portable Clinic	School Building	900	5-10
10	Portable Classrooms	School Building	1,920	20-40
11	Head Start	School Building	1,440	20-40

The study included a review of the building's construction features, historical energy and water consumption and costs, review of the building envelope, HVAC equipment, heat distribution systems, lighting, and the building's operational and maintenance practices.

### 1.1. Energy Conservation Measures

EMG has identified three Energy Conservation Measures (ECMs) for this property. The savings for each measure is calculated using standard engineering methods followed in the industry, and detailed calculations for ECM are provided in Appendix for reference. A 10% discount in energy savings was applied to account for the interactive effects amongst the ECMs. In addition to the consideration of the interactive effects, EMG has applied a 15% contingency to the implementation costs to account for potential cost overruns during the implementation of the ECMs.

The following table summarizes the recommended ECMs in terms of description, investment cost, energy consumption reduction, and cost savings.

#### **Summary of Financial Information for Recommended Non-Renewable Energy Conservation Measures**

Item	Estimate
Net Initial ECM Investment ( <i>Current Dollars Only</i> )	\$ 89,521 ( <i>In Current Dollars</i> )
Estimated Annual Cost Savings ( <i>Current Dollars Only</i> )	\$7,138 ( <i>In Current Dollars</i> )

Item	Estimate
ECM Effective Payback	12.54 years
Estimated Annual Energy Savings	9%
Estimated Annual Energy Utility Cost Savings ( <i>Excluding Water</i> )	10%
Estimated Annual Water Cost Saving	2%

### **Solar Photovoltaic (PV) Screening for CAPITOL COLLEGIATE ACADEMY**

Solar Rooftop Photovoltaic Analysis		
Estimated Number of Panels	69	
Estimated KW Rating	124	KW
Potential Annual kWh Produced	191,313	kWh
% of Current Electricity Uses	96.2%	
Financial Summary		
Investment Cost	\$434,700	
Estimated Energy Cost Savings	\$32,523	
Payback without Incentives	13.4	Years
Incentive Payback but without SRECs	8.1	Years
Payback with All Incentives	8.1	Years

### **Key Metrics to Benchmark the Subject Property's Energy Usage Profile**

- **Building Site Energy Use Intensity** - The sum of the total site energy use in thousands of Btu per unit of gross building area. Site energy accounts for all energy consumed at the building location only not the energy consumed during generation and transmission of the energy to the site.
- **Building Source Energy Use Intensity** – The sum of the total source energy use in thousands of Btu per unit of gross building area. Source energy is the energy consumed during generation and transmission in supplying the energy to your site.
- **Building Cost Intensity** - This metric is the sum of all energy use costs in dollars per unit of gross building area.
- **Greenhouse Gas Emissions** - Although there are numerous gases that are classified as contributors to the total for Greenhouse Emissions, the scope of this energy audit focuses on carbon dioxide (CO<sub>2</sub>). Carbon dioxide enters the atmosphere through the burning of fossil fuels (oil, natural gas, and coal), solid waste, trees and wood products, and also as a result of other chemical reactions (e.g., manufacture of cement).

Site Energy Use Intensity (EUI)	Rating
Current Site Energy Use Intensity (EUI)	40 kBtu/ft <sup>2</sup>
Post ECM Site Energy Use Intensity (EUI)	36 kBtu/ft <sup>2</sup>
Source Energy Use Intensity (EUI)	Rating
Current Source Energy Use Intensity (EUI)	90 kBtu/ft <sup>2</sup>
Post ECM Source Energy Use Intensity (EUI)	82 kBtu/ft <sup>2</sup>
Building Cost Intensity (BCI)	Rating
Current Building Cost Intensity	\$1.32/ft <sup>2</sup>
Post ECM Building Cost Intensity	\$1.19/ft <sup>2</sup>

#### **Summary of the Greenhouse Gas Reductions from Recommended Non-Renewable Energy Conservation Measures**

The following table provides a summary of the projected Greenhouse Gas Emissions reductions as a result of the recommended Energy Conservation Measures:

Greenhouse Gas Emissions Reduction	
Estimated Annual Thermal Energy Reduction	111 MMbtu
Total CO <sub>2</sub> Emissions Reduced	9.05 MtCO <sub>2</sub> /Yr
Total Cars Off the Road (Equivalent)*	2
Total Acres of Pine Trees Planted (Equivalent)*	2

*\*Equivalent reductions per DOE emissions calculation algorithms*

#### **Zero Net Energy Analysis for Renewable and Non-Renewable Recommended Measures**

Zero Net Energy Analysis	
Building Annual Net Energy Consumption	1,265,282 kBtu
Total Annual Energy Savings for Non-Renewable Energy Measures	110,911 kBtu
Total Annual Energy Savings from Renewable Energy Measures	652,760 kBtu
Total Annual Energy Savings	763,671 kBtu
Net Energy Consumption from Grid Post Implementation	501,611 kBtu
% Energy Reduction (Annual Energy-Net Energy) / (Annual Energy)	60%

## Energy Conservation Measures Screening:

EMG screens ECMs using two financial methodologies. ECMs which are considered financially viable must meet both criteria.

1. Simple Payback Period – The number of years required for the cumulative value of energy or water cost savings less future non-fuel or non-water costs to equal the investment costs of the building energy or water system, without consideration of discount rates. ECMs with a payback period greater than the Expected Useful Life (EUL) of the project are not typically recommended, as the cost of the project will not be recovered during the lifespan of the equipment. These ECMs are recommended for implementation during future system replacement. At that time, replacement may be evaluated based on the premium cost of installing energy efficient equipment.

$$\text{Simple Payback} = \frac{\text{Initial Cost}}{\text{Annual Savings}}$$

2. Savings-to-Investment Ratio (SIR) – The savings-to-investment ratio is the ratio of the present value savings to the present value costs of an energy or water conservation measure. The numerator of the ratio is the present value over the estimated useful life (EUL) of net savings in energy or water and non-fuel or non-water operation and maintenance costs attributable to the proposed energy or water conservation measure. The denominator of the ratio is the present value of the net increase in investment and replacement costs less salvage value attributable to the proposed energy or water conservation measure. It is recommended that energy efficiency recommendations should be based on a calculated SIR, with larger SIRs receiving a higher priority. A project is typically only recommended if SIR is greater than or equal to 1.0, unless other factors outweigh the financial benefit.

$$SIR = \frac{\text{Present Value (Annual Savings, } i\%, EUL)}{\text{Initial Cost}}$$

List of Recommended Energy Conservation Measures For Capitol Collegiate Academy												
ECM #	Description of ECM	Projected Initial Investment	Estimated Annual Energy Savings		Estimated Annual Water Savings	Estimated Cost Savings	Estimated Annual O&M Savings	Total Estimated Annual Cost Savings	Simple Payback	S.I.R.	Life Cycle Savings	Expected Useful Life (EUL)
			Natural Gas	Electricity								
		\$	Therms	kWh	kgal	\$	\$	\$	Years		\$	Years
No/Low Cost Recommendations												
1	Install Low Flow Faucet Aerators	\$625	418	0	59	\$890	\$0	\$890	0.70	12.16	\$6,968	10.00
	Location: Restrooms											
Totals for No/Low Cost Items		\$625	418	0	59	\$890	\$0	\$890	0.70			
Capital Cost Recommendations												
1	Replace Existing Water Heater With New Energy Efficient Units	\$1,270	0	1,063	0	\$184	\$0	\$184	6.91	1.99	\$1,258	18.00
	Location: Mechanical Closet											
2	Upgrade Building Lighting to LED and Install Automatic Lighting Controls	\$75,950	0	22,792	0	\$3,942	\$2,915	\$6,857	11.08	1.08	\$5,909	15.00
	Location: Building Interior And Exterior											
Total For Capital Cost		\$77,220	0	23,855	0	\$4,126	\$2,915	\$7,041	10.97			
	Interactive Savings Discount @ 10%		-42	-2,385	-6	-\$502	-\$291	-\$793				
	Total Contingency Expenses @ 15%	\$11,677										
Total for Improvements		\$89,521	377	21,469	53	\$4,515	\$2,623	\$7,138	12.54			

In addition to the above measures, EMG has identified the following measure(s) but has not recommended as they fail to meet the above-mentioned financial criteria of SIR>1.0. Thus, EMG has classified the measure(s) as recommended for consideration.



List of Recommended For Consideration Energy Conservation Measures For Capitol Collegiate Academy												
ECM #	Description of ECM	Initial Investment	Annual Energy Savings		Annual Water Savings	Cost Savings	Estimated Annual O&M Savings	Total Estimated Annual Cost Savings	Payback	S.I.R.	Life Cycle Savings	Expected Useful Life (EUL)
		\$	Natural Gas	Electricity	kgal	\$	\$	\$	Years		\$	Years
1	Replace Rooftop Package Unit	\$73,750	133	16,306	0	\$2,994	\$150	\$3,144	23.46	0.63	-\$26,978	20.00
	Location: Roof											
2	Install Low Flow Tankless Restroom Fixtures	\$17,582	0	0	129	\$748	\$0	\$748	23.50	0.51	-\$8,650	15.00
	Location: Restrooms											
3	Retrofit Apartment Tank Toilets to Dual Flush	\$315	0	0	2	\$9	\$0	\$9	35.67	0.42	-\$183	20.00
	Location:											
4	Replace External Windows	\$22,986	40	977	0	\$222	\$2	\$224	102.58	0.17	-\$19,084	25.00
	Location: Throughout Building											
Total for Improvements		\$114,633	173	17,283	130	\$3,973	\$152	\$4,125	27.79			

## 2. Introduction

The purpose of this Energy Audit is to provide Capitol Collegiate Academy and Sacramento City Unified School District with a baseline of energy usage, the relative energy efficiency of the facility, and specific recommendations for Energy Conservation Measures. Information obtained from these analyses may be used to support a future application to an Energy Conservation Program, Federal and Utility grants towards energy conservation, as well as support performance contracting, justify a municipal bond-funded improvement program, or as a basis for replacement of equipment or systems.

The energy audit consisted of an onsite visual assessment to determine current conditions, itemize the energy consuming equipment (i.e. Boilers, Make-Up Air Units, DWH equipment); review lighting systems both exterior and interior; and review efficiency of all such equipment. The study also included interviews and consultation with operational and maintenance personnel. The following is a summary of the tasks and reporting that make up the Energy Audit portion of the report.

The following is a summary of the tasks and reporting that make up the Energy Audit portion of the report.

### ENERGY AND WATER USING EQUIPMENT

- EMG has surveyed the common areas, office areas, rooms, maintenance facilities and mechanical rooms to document utility-related equipment, including heating systems, cooling systems, air handling systems and lighting systems.

### BUILDING ENVELOPE

- EMG has reviewed the characteristics and conditions of the building envelope, checking insulation values and conditions. This review also includes an inspection of the condition of walls, windows, doors, roof areas, insulation and special use areas

### RECOMMENDATIONS FOR ENERGY SAVINGS OPPORTUNITIES

- Based on the information gathered during the on site assessment, the utility rates, as well as recent consumption data and engineering analysis, EMG has identified opportunities to save energy and provide probable construction costs, projected energy/utility savings and provide a simple payback analysis.

### ANALYSIS OF ENERGY CONSUMPTION

- Based on the information gathered during the on-site assessment, EMG has conducted an analysis of the energy usage of all equipment, and identified which equipment is using the most energy and what equipment upgrades may be necessary. As a result, equipment upgrades, or replacements are identified that may provide a reasonable return on the investment and improve maintenance reliability.

### ENERGY AUDIT PROCESS

- Interviewing staff and review plans and past upgrades
- Performing an energy audit for each use type
- Performing a preliminary evaluation of the utility system
- Analyzing findings, utilizing ECM cost-benefit worksheets
- Making preliminary recommendations for system energy improvements and measures
- Estimating initial cost and changes in operating and maintenance costs based on implementation of energy efficiency measures
- Ranking recommended cost measures, based on the criticality of the project and the largest payback

### REPORTING

The EMG Energy Audit Report includes:

- A comprehensive study identifying all applicable Energy Conservation Measures (ECMs) and priorities, based on initial cost and payback
- A narrative discussion of building systems/components considered and a discussion of energy improvement options;
- A summary of ECMs including initial costs and simple paybacks, based on current utility rates and expected annual savings.

### 3. Facility Overview and Existing Conditions

#### 3.1. Building Occupancy and Point of Contact

Facility Schedule	
Hours of Operations / Week	35
Operational Weeks / Year	37
Estimated Facility Occupancy	391
% of Male Occupants	45%

Point of Contact	
Point of Contact Name	Annie Narayan
Point of Contact Title	Assistant Principal of Operations
Point of Contact – Contact Number	661.301.4642

#### 3.2. Building Heating, Ventilating and Air-Conditioning (HVAC)

**Description:**

Heating and cooling are mainly provided by rooftop packaged units and heat pumps. Heating is supplemented by forced air furnaces.

The Mechanical Equipment Schedule in Appendix E contains a summary of the HVAC Equipment at the property.

Building Central Heating System	
Primary Heating System	Rooftop Package Units
Secondary Heating System	Forced Air Furnace
Hydronic Distribution System	Not Applicable
Primary Heating Fuel	Natural Gas
Heating Mode Set-point	69 °F
Heating Mode- Set-back Temperature	53 °F

Building Cooling System	
Primary Cooling System	Package Units
Secondary Cooling System	Split Systems

Building Cooling System	
Hydronic Distribution System	Not Applicable
Cooling Mode Set-point	68 °F
Cooling Mode- Set-back Temperature	93 °F

Air Distribution System	
Building Ventilation	Roof Top Exhaust Fans
On-Demand Ventilation System in Use?	No
Energy Recovery Wheel / Enthalpy Wheel Exhaust Fans	No

Domestic Hot Water System	
Primary Domestic Water Fuel	Natural Gas

### 3.3. Lighting

**Description:**

The lighting in the school building primarily consists of T8 linear fluorescent lamp fixtures in classrooms and hallways. The fixtures were observed to be operating on bi-level mode in the classrooms. The exterior lights were primarily High Intensity Discharge (HID) fixtures.

The detailed lighting schedule and the proposed LED alternative is provided in Appendix D

## 4. Utility Analysis

Establishing the energy baseline begins with an analysis of the utility cost and consumption of the building. Utilizing the historical energy data and local weather information, we evaluate the existing utility consumption and assign it to the various end-uses throughout the buildings. The Historical Data Analysis breaks down utilities by consumption, cost and annual profile.

This data is analyzed, using standard engineering assumptions and practices. The analysis serves the following functions:

- Allows our engineers to benchmark the energy and water consumption of the facilities against consumption of efficient buildings of similar construction, use and occupancy.
- Generates the historical and current unit costs for energy and water
- Provides an indication of how well changes in energy consumption correlate to changes in weather.
- Reveals potential opportunities for energy consumption and/or cost reduction. For example, the analysis may indicate that there is excessive, simultaneous heating and cooling, which may mean that there is an opportunity to improve the control of the heating and cooling systems.

By performing this analysis and leveraging our experience, our engineers prioritize buildings and pinpoint systems for additional investigation during the site visit, thereby maximizing the benefit of their time spent on-site and minimizing time and effort by the customer's personnel.

Based upon the utility information provided about the Sacramento City Unified School District, the following energy rates are utilized in determining existing and proposed energy costs.

### Utility Rates used for Cost Analysis

Electricity (Blended Rate)	Natural Gas	Water / Sewer
\$0.17/kWh	\$1.31/therm	\$ 5.82/kGal

The data analyzed provides the following information: 1) breakdown of utilities by consumption, 2) cost and annual profile, 3) baseline consumption in terms of energy/utility at the facility, 4) the Energy Use Index, or Btu/sq ft, and cost/sq ft. For multiple water meters, the utility data is combined to illustrate annual consumption for each utility type.



#### 4.1. Electricity

PGE satisfies the electricity requirements for the facility. The primary end uses for electric utility comprises of lighting, cooling, office/school equipment, and appliances in the break room.

The table below provides the electric use for the period of twelve continuous months.

**Electric Consumption and Cost Data**

Billing Month	Consumption (KWH)	Unit Cost/KWH	Total Cost
July, 18	14,305	\$0.20	\$2,828
August, 18	18,992	\$0.18	\$3,383
September, 18	18,772	\$0.17	\$3,198
October, 18	18,191	\$0.17	\$3,084
November, 18	14,757	\$0.17	\$2,533
December, 18	14,237	\$0.17	\$2,475
January, 19	15,835	\$0.17	\$2,664
February, 19	15,868	\$0.16	\$2,569
March, 19	16,543	\$0.17	\$2,846
April, 19	14,796	\$0.18	\$2,605
May, 19	19,032	\$0.17	\$3,141
June, 19	17,641	\$0.18	\$3,091
<b>Total/average</b>	<b>198,969</b>	<b>\$0.17</b>	<b>\$34,417</b>



## 4.2. Natural Gas



Spurr Gas satisfies the natural gas requirements of the facility. The primary end use of natural gas is for building heating, domestic water heating, and cooking in the cafeteria.

The analysis of the 12 months of consumption is provided below.

**Natural Gas Consumption and Cost Data**

Billing Month	Consumption (Therms)	Unit Cost/Therm	Total Cost
July, 18	42	\$1.75	\$73
August, 18	53	\$1.60	\$85
September, 18	90	\$1.31	\$118
October, 18	162	\$1.19	\$193
November, 18	670	\$1.21	\$809
December, 18	1,074	\$1.34	\$1,443
January, 19	1,233	\$1.29	\$1,584
February, 19	1,189	\$1.32	\$1,564
March, 19	845	\$1.33	\$1,125
April, 19	253	\$1.31	\$331
May, 19	226	\$1.30	\$293
June, 19	29	\$1.32	\$39
<b>Total/average</b>	<b>5,864</b>	<b>\$1.31</b>	<b>\$7,658</b>







### 4.3. Water and Sewer

The City of Sacramento satisfies the water requirements for the facility. The primary end use of water is the plumbing fixtures such as staff showers, water closets, and lavatories. The table below provides the twelve continuous months' worth of consumption and cost for water in kGal for the facility.

**Water and Sewer Consumption and Cost Data**

Billing Month	Consumption (Kgal)	Unit Cost/Kgal	Total Cost
July, 18	569	\$4.35	\$2,475
August, 18	254	\$5.46	\$1,384
September, 18	281	\$5.30	\$1,489
October, 18	787	\$4.07	\$3,202
November, 18	516	\$4.41	\$2,276
December, 18	108	\$10.09	\$1,087
January, 19	89	\$10.71	\$954
February, 19	83	\$10.25	\$854
March, 19	92	\$10.92	\$1,006
April, 19	84	\$11.75	\$993
May, 19	91	\$10.67	\$974
June, 19	72	\$12.83	\$927
<b>Total/average</b>	<b>3,027</b>	<b>\$5.82</b>	<b>\$17,621</b>



## 5. Renewable Energy Discussions

### 5.1. Rooftop Solar Photovoltaic Feasibility

#### **Solar Energy Feasibility**

A photovoltaic array is a linked collection of photovoltaic modules, which are in turn made of multiple interconnected solar cells. The cells convert solar energy into direct current electricity via the photovoltaic effect. The power that one module can produce is seldom enough to meet requirements of a home or a business, so the modules are linked together to form an array. Most PV arrays use an inverter to convert the DC power produced by the modules into alternating current that can plug into the existing infrastructure to power lights, motors, and other loads. The modules in a PV array are usually first connected in series to obtain the desired voltage; the individual strings are then connected in parallel to allow the system to produce more current. Solar arrays are typically measured by the peak electrical power they produce, in watts, kilowatts, or even megawatts.

When determining if a site is suitable for a solar application, two basic considerations must be evaluated:

- At minimum, the sun should shine upon the solar collectors from 9 AM to 3 PM. If less, the application may still be worthwhile, but the benefit will be less.
- The array should face south and be free of any shading from buildings, trees, rooftop equipment, etc. If the array is not facing directly south, there will be a penalty in transfer efficiency, reducing the overall efficiency of the system.

Solar PV Questionnaire	Response
Does the property have a south, east, or west facing roof or available land of more than 250 square feet per required Solar Array Panel?	<b>Yes</b>
Is the area free from any shading such as trees, buildings, equipment etc throughout the whole day?	<b>Yes</b>
Can the panels be mounted at an incline of roughly 25-45 degrees? (equal to latitude of property)	<b>Yes</b>
Is the property in an area with acceptable average monthly sunlight levels?	<b>Yes</b>
Has the roofing been replaced within the past 3-5 years?	<b>No</b>
Is the roof structure sufficient to hold solar panels?	<b>Yes</b>
Is the property located in a state eligible for net metering?	<b>Yes</b>

A solar feasibility analysis of the Capitol Collegiate Academy site has resulted in the building containing more than sufficient amount of roof area for solar electricity generation. The analysis through the use of National Renewable Energy Laboratory's solar photovoltaic software assisted in calculating the potential electricity generated from the allocated land and roof area set for solar photovoltaic installment. The allocated roof area was through looking at the roof and surrounding areas at a bird's eye view. Also detailed in the report are incentives and rebates that can potentially bring down the installation cost of the ECMs and result in a higher return on investment and quicker payback period.

The approach taken in the solar photovoltaic (PV) roof analysis begins with surveying the roof and determine areas on the roof where solar PV panels can potentially be installed.

- 1) Conducting a preliminary sizing of solar PV panels on the roofs and on the ground and its potential electricity production for its first year of installment using the National Renewable Energy Laboratory (NREL) PV WATTS Version 2 Software.
- 2) Calculate energy and cost savings for the site as a sole proprietor of the system capable of collecting state, local, and federal tax credits and incentives and interconnecting and selling the renewable energy electrical production to the building.

Solar Rooftop Photovoltaic Analysis		KW  kWh
Estimated Number of Panels	69	
Estimated KW Rating	124	
Potential Annual kWh Produced	191,313	
% of Current Electricity Uses	96.2%	
Financial Summary		Years
Investment Cost	\$434,700	
Estimated Energy Cost Savings	\$32,523	
Payback without Incentives	13.4	
Incentive Payback but without SRECs	8.1	
Payback with All Incentives	8.1	Years

A photovoltaic array is a linked collection of photovoltaic modules, which are in turn made of multiple interconnected solar cells. The cells convert solar energy into direct current. Modules of cells are linked together to form an array. Most PV arrays use an inverter to convert the DC power produced by the modules into alternating current that can connect to existing AC infrastructure to power lights, motors, and other loads.

Cost of production has fallen years with increasing demand and through production and technological advances. The cost dropped from \$8–10/watt in 1996 to \$4–7/watt in 2006. The market is diversifying with new types of panels suited to unique installation methods including stick on sheets and PV spray coating. The solar PV cost used in the analysis was set at \$7.0/Watt which includes design, construction, administration, and installation and maintenance cost throughout the life of the solar panels.

One breakthrough for PV is “Net Metering”. When more PV electric power is generated than is consumed on site, the electric service meter reverses to “sell” the excess power directly back onto the power grid. The economics of PV for commercial industrial installations become attractive when coupled with incentives from Federal and state agencies, as well utility companies.

A kilowatt-hour costing \$0.15 might be valued at \$0.30 when produced by PV and sent to the grid. The economics of PV for commercial industrial installations become attractive when coupled with incentives from Federal and state agencies, as well utility companies.

The low payback period is highly dependent on the marketing potential of selling Solar Renewable Certificates to electricity generated providers who are under state regulations to contain a certain percentage of their electricity generation derived from renewable energy such as wind and solar.

Solar facilities are encouraged to sell their SRECs on the market (either spot market or through long-term contracts). Utilities may use SRECs for compliance under the state RPS for the year in which they are generated. Utilities may purchase up to 10% more SRECs than they require for compliance and “bank” those surplus SRECs for compliance during the following two years. Any SRECs pricing can range from \$300 - \$450/MWh and can be sold across state borders to other utility providers looking to purchase SRECs. EMG has selected to use the market value of \$300/MWh minus 5% administrative fee in the analysis.

A number of states and corresponding electrical utility supplier are required under regulation to have a certain percentage of its electricity be produced by solar energy. To offset that they allow other utility companies to buy Renewable Energy Credits (REC) credit off their customers and facilities that produce their own solar energy. Typically the national market, the utility market is \$400 per MWh to Utility Suppliers for not meeting this standard percentage so these REC credits are sold for \$350 per MWh. (1 REC credit = 1 MWh).

State charges these utility companies to meet their state compliance of 0.2% of the entire electricity consumption from solar energy by 2022 (from 0.005% in 2008 aggregated up to 0.2% by 2022). The REC credits correspond to these percentages as they aggregate each year.

## 6. Operations and Maintenance Plan

The quality of the maintenance and the operation of the facility's energy systems have a direct effect on its overall energy efficiency. Energy-efficiency needs to be a consideration when implementing facility modifications, equipment replacements, and general corrective actions. The following is a list of activities that should be performed as part of the routine maintenance program for the property.

### ***Building Envelope***

- ✓ Ensure that the building envelope has proper caulking and weather stripping.
- ✓ Patch holes in the building envelope with foam insulation and fire rated caulk around combustion vents
- ✓ Inspect building vents semiannually for bird infestation
- ✓ Inspect windows monthly for damaged panes and failed thermal seals
- ✗ Repair and adjust automatic door closing mechanisms as needed.

### ***Heating and Cooling***

- ✗ Pilots lights on furnaces and boilers be turned off in summer
- ✓ All preventive maintenance should be performed on all furnaces and boilers, which would include cleaning of burners and heat exchanger tubes.
- ✓ Ensure that the combustion vents exhaust outside the conditioned space and the vent dampers are functional
- ✓ Ensure that the control valves are functioning properly before start of every season
- ✗ Ensure steam traps are functional before start of each heating season
- ✗ Ensure use of chemical treatment for boiler make up water
- ✗ Ensure boiler outside temperature re-set is set to 55F
- ✗ Ensure use of chemical treatment for Colling tower water to prevent corrosion
- ✗ Ensure the duct work in unconditioned space is un-compromised and well insulated
- ✗ Duct cleaning is recommended every 10 years. This should include sealing of ducts using products similar to 'aero-seal'
- ✓ Ensure use of economizer mode is functional and used
- ✓ Ensure that the outside air dampers actuators are operating correctly
- ✓ Ensure air coils in the AHU and FCA's are pressure washed annually
- ✓ Return vents should remain un-obstructed and be located centrally
- ✓ Temperature settings reduced in unoccupied areas and set points seasonally adjusted.
- ✓ Evaporator coils and condenser coils should be regularly cleaned to improve heat transfer
- ✓ Refrigerant pipes should be insulated with a minimum of ¾" thick Elastomeric Rubber Pipe Insulation
- ✓ Ensure refrigerant pressure is maintained in the condensers
- ✓ Change air filters on return vents seasonally. Use only filters with 'Minimum Efficiency Rating Value'(MERV) of 8

### ***Central Domestic Hot Water Heater***

- ✓ Never place gas fired water heaters adjacent to return vents so as to prevent flame roll outs
- ✗ Ensure the circulation system is on timer to reduce the losses through re-circulation
- ✓ Ensure all hot water pipes are insulated with fiberglass insulation at all times
- ✓ Replacement water heater should have Energy Factor (EF)>0.9
- ✗ Tank-type water heaters flushed monthly

***Lighting Improvements***

- ✗ Utilize bi-level lighting controls in stairwells and hallways.
- ✓ Use LED replacement lamps
- ✓ Clean lighting fixture reflective surfaces and translucent covers.
- ✓ Ensure that timers and/or photocells are operating correctly on exterior lighting
- ✓ Use occupancy sensors for offices and other rooms with infrequent occupancy

***Existing Equipment and Replacements***

- ✓ Ensure that refrigerator and freezer doors close and seal correctly
- ✓ Ensure kitchen and bathroom exhaust outside the building and the internal damper operates properly
- ✓ Ensure that bathroom vents exhaust out
- ✓ Office/ computer equipment either in the “sleep” or “off” mode when not used

## 7. Appendices

---

APPENDIX A: Glossary of Terms

APPENDIX B: Mechanical Equipment Inventory

APPENDIX C: Lighting System Schedule

APPENDIX D: ECM Checklist

APPENDIX E: ECM Calculations

APPENDIX F: Solar PV



---

## **APPENDIX A:**

## **Glossary of Terms**

---

### **Glossary of Terms and Acronyms**

**ECM** – Energy Conservation Measures are projects recommended to reduce energy consumption. These can be No/Low cost items implemented as part of routine maintenance or Capital Cost items to be implemented as a capital improvement project.

**Initial Investment** – The estimated cost of implementing an ECM project. Estimates typically are based on R.S. Means Construction cost data and Industry Standards.

**Annual Energy Savings** – The reduction in energy consumption attributable to the implementation of a particular ECM. These savings values do not include the interactive effects of other ECMs.

**Cost Savings** – The expected reduction in utility or energy costs achieved through the corresponding reduction in energy consumption by implementation of an ECM.

**Simple Payback Period** – The number of years required for the cumulative value of energy or water cost savings less future non-fuel or non-water costs to equal the investment costs of the building energy or water system, without consideration of discount rates.

**EUL** – Expected Useful Life is the estimated lifespan of a typical piece of equipment based on industry accepted standards.

**RUL** – Remaining Useful Life is the EUL minus the effective age of the equipment and reflects the estimated number of operating years remaining for the item.

**SIR** – The savings-to-investment ratio is the ratio of the present value savings to the present value costs of an energy or water conservation measure. The numerator of the ratio is the present value of net savings in energy or water and non-fuel or non-water operation and maintenance costs attributable to the proposed energy or water conservation measure. The denominator of the ratio is the present value of the net increase in investment and replacement costs less salvage value attributable to the proposed energy or water conservation measure. It is recommended that energy-efficiency recommendations be based on a calculated SIR, with larger SIRs receiving a higher priority. A project typically is recommended only if the SIR is greater than or equal to 1.0, unless other factors outweigh the financial benefit.

**Life Cycle Cost** – The sum of the present values of (a) Investment costs, less salvage values at the end of the study period; (b) Non-fuel operation and maintenance costs; (c) Replacement costs less salvage costs of replaced building systems; and (d) Energy and/or water costs.

**Life Cycle Savings** – The sum of the estimated annual cost savings over the EUL of the recommended ECM, expressed in present value dollars.

**Building Site Energy Use Intensity** – The sum of the total site energy use in thousands of Btu per unit of gross building area. Site energy accounts for all energy consumed at the building location only not the energy consumed during generation and transmission of the energy to the site.

**Building Source Energy Use Intensity** – The sum of the total source energy use in thousands of Btu per unit of gross building area. Source energy is the energy consumed during generation and transmission in supplying the energy to your site.

**Building Cost Intensity** – This metric is the sum of all energy use costs in dollars per unit of gross building area.

**Greenhouse Gas Emissions** – Although there are numerous gases that are classified as contributors to the total for Greenhouse Emissions, the scope of this energy audit focuses on carbon dioxide (CO<sub>2</sub>). Carbon dioxide enters the atmosphere through the burning of fossil fuels (oil, natural gas, and coal), solid waste, trees and wood products, and also as a result of other chemical reactions (e.g., manufacture of cement).

---

## **APPENDIX B:**

# **Mechanical Equipment Inventory**

---

Mechanical Inventory						
System	Make	Model	Serial Number	Input Capacity	Location	Location- Floor
Condensing Unit/Heat Pump	Lennox	ML14XC1-036-230806	1917H13014	3 TON	Capitol Collegiate Academy / Portable Classrooms 34 and 35 (P02)	Classroom - O035
Condensing Unit/Heat Pump	Lennox	ML14XC1-036-230806	1917H13024	3 TON	Capitol Collegiate Academy / Portable Classrooms 34 and 35 (P02)	Classroom - O034
Condensing Unit/Heat Pump	Day & Nite	597CN060-D	3796E04621	5 TON	Capitol Collegiate Academy / Administration (004)	Office
Domestic Circulation/Booster Pump	Berkeley Pumps\ US Electric Motors	B080A	No tag/plate found	10 HP	Capitol Collegiate Academy / Site	Site
Exhaust Fan				500 CFM	Capitol Collegiate Academy / Multipurpose (006)	Kitchen
Exhaust Fan	Penn Ventilator Company	FX8B	No tag/plate found	1500 CFM	Capitol Collegiate Academy / Restrooms (002)	Roof
Exhaust Fan	Penn Ventilator Company	FX8B	No tag/plate found	1500 CFM	Capitol Collegiate Academy / Restrooms (002)	Roof
Furnace	Lennox	Inaccessible	Inaccessible	100 MBH	Capitol Collegiate Academy / Portable Classrooms 34 and 35 (P02)	Classroom - O035
Furnace	Lennox	Inaccessible	Inaccessible	100 MBH	Capitol Collegiate Academy / Portable Classrooms 34 and 35 (P02)	Classroom - O034

Furnace	Bryant	383KAV060111	4496A07899	110 MBH	Capitol Collegiate Academy / Administration (004)	Building exterior
Heat Pump	Bard	48WH6-A10C	Inaccessible	4 TON	Capitol Collegiate Academy / Portable Classrooms (P09)	Former 4th R
Heat Pump	Bard	48WH6-A10C	107N890629883	4 TON	Capitol Collegiate Academy / Portable Classrooms (P09)	Former 4th R
Heat Pump	Marvair	36WH7A05C	058F900648726	3 TON	Capitol Collegiate Academy / Portable Classrooms 11 to 15 (P01)	Classroom-0013
Heat Pump	Marvair	AVP36HPA05N-1000 BI	FL49789	3 TON	Capitol Collegiate Academy / Portable Classrooms 11 to 15 (P01)	Classroom-0014
Heat Pump	Marvair	36WH7-A05C	058F9006487	3 TON	Capitol Collegiate Academy / Portable Classrooms 11 to 15 (P01)	Classroom-0012
Heat Pump	Berd	WH421-A05VP4XXX	126L031847440-02	3.5 TON	Capitol Collegiate Academy / Portable Classrooms 11 to 15 (P01)	Classroom-0015
Heat Pump	Bard	WH491-A02AP4XXB	218H011647542-02	4 TON	Capitol Collegiate Academy / Head Start (P11)	Building exterior
Heat Pump	Bard	?421-A00VP4XXX	126F041915778-02	4 TON	Capitol Collegiate Academy / Portable Classrooms 11 to 15 (P01)	Classroom - 0011
Packaged Unit (RTU)				5 TON	Capitol Collegiate Academy / Portable Clinic (P08)	Roof

Packaged Unit (RTU)	BDP	581BPV048072ADAA	1899G20319	4 TON	Capitol Collegiate Academy / Classrooms 6 to 10 (003)	Classroom-O006
Packaged Unit (RTU)	BDP	561BPV04807ADAA	2199G20371	4 TON	Capitol Collegiate Academy / Classrooms 1 to 4 (001)	Classroom - O005
Packaged Unit (RTU)	BDP	561BPV04807ADAA	1899G20322	4 TON	Capitol Collegiate Academy / Classrooms 1 to 4 (001)	Classroom - Y030
Packaged Unit (RTU)	BDP	581BPV150224AEAA	2299G30679	12.5 TON	Capitol Collegiate Academy / Multipurpose (006)	Kitchen - K001
Packaged Unit (RTU)	BDP	581BPV048072ADAA	1899G20321	4 TON	Capitol Collegiate Academy / Classrooms 6 to 10 (003)	Classroom-O007
Packaged Unit (RTU)	BDP	561BPV04807ADAA	2199G20367	4 TON	Capitol Collegiate Academy / Classrooms 1 to 4 (001)	Classroom - O004
Packaged Unit (RTU)	BDP	561BPV04807ADAA	1899G20324	4 TON	Capitol Collegiate Academy / Classrooms 1 to 4 (001)	Classroom - Y040
Packaged Unit (RTU)	BDP	581BPV036072ADAA	2099G20246	3 TON	Capitol Collegiate Academy / Multipurpose (006)	Stage - U002
Packaged Unit (RTU)	BDP	581BPV048072ADAA	1899G20323	4 TON	Capitol Collegiate Academy / Classrooms 6 to 10 (003)	Classroom-O008
Packaged Unit (RTU)	BDP	561BPV04807ADAA	2199G20346	4 TON	Capitol Collegiate Academy / Classrooms 1 to 4 (001)	Classroom - O003

Packaged Unit (RTU)	Bryant	583ANW024040AAHD	2199G11138	2 TON	Capitol Collegiate Academy / Multipurpose (006)	Kitchen-K001
Packaged Unit (RTU)	BDP	581BPV048072ADAA	1899G20366	4 TON	Capitol Collegiate Academy / Classrooms 6 to 10 (003)	Classroom-O009
Packaged Unit (RTU)	BDP	561BPV04807ADAA	1899G20320	4 TON	Capitol Collegiate Academy / Classrooms 1 to 4 (001)	Classroom - O002
Packaged Unit (RTU)	BDP	561BPV06007ADAA	2199G20434	5 TON	Capitol Collegiate Academy / Classrooms 1 to 4 (001)	Classroom - O001
Packaged Unit (RTU)	BDP	581BPV060072ADAA	1899G20433	5 TON	Capitol Collegiate Academy / Classrooms 6 to 10 (003)	Classroom-O010
Packaged Unit (RTU)	Bryant	583ANW024040AAHD	2199G11135	2 TON	Capitol Collegiate Academy / Classrooms 6 to 10 (003)	Classroom-O008
Water Heater	A. O. Smith	EES 30 917	GL01-0294421-917	30 GAL	Capitol Collegiate Academy / Administration (004)	Janitor - J001
Water Heater	Rheem	22VR75-70N	RHLN0607U00250	75 GAL	Capitol Collegiate Academy / Multipurpose (006)	Janitor - J001

---

---

## **APPENDIX C:**

## **Lighting System Schedule**

---

---





										Lamp Details				Fixture Details				Existing Consumption	
Line No.	Building Name	Interior/ Exterior	Floor	Space Type	Room No.	Additional Area Description	LUX	Control Quantit y	Existing Control	Technology	Sub-Technology	Lamp Type	Total Lamps	Fixture Type	Fixture Quantity	24x7 Fixture Count	Fixture Height	Annual Hours	Existing Annual kWh
1	P011	Interior		CLASSROOM	P011		-	1	Light Switch	Linear Fluorescent	T8	4' 32W T8	24	2x4 Prism Troffer	12	0	8	1,295	995
2	P011	Interior		RESTROOM	Restroom		-	2	Light Switch	Linear Fluorescent	T8	4' 32W T8	8	2x4 Prism Troffer	4	0	8	1,295	332
3	P011	Interior		CAFETERIA	Cafeteria		-	1	Light Switch	Linear Fluorescent	T8	4' 32W T8	4	2x4 Prism Troffer	2	0	8	1,295	166
4	P011	Interior		OFFICE	Office		-	1	Light Switch	Linear Fluorescent	T8	4' 32W T8	8	2x4 Prism Troffer	4	0	8	1,295	332
5	P011	Exterior		HALLWAY	Exterior		-	0	Timer	CFL	CFL - 2 Pin	CFL13	2	Wallpack-Vertical	2	0	8	1,295	34
6	P011	Exterior		HALLWAY	Exterior		-	0	Timer	HID	MH	MH400	2	Wallpack-Vertical	2	0	8	1,295	1,036
7	P09 and P10	Interior		CLASSROOM	P10		-	4	Light Switch	Linear Fluorescent	T8	4' 32W T8	48	2x4 Prism Troffer	24	0	8	1,295	1,989
8	P09 and P10	Interior		HALLWAY	Exterior		-	0	Timer	CFL	CFL - 4 Pin	CFL42	2	Surface Mount Can	2	0	8	1,295	109
9	P08	Interior		OFFICE	Office		-	3	Light Switch	Linear Fluorescent	T8	4' 32W T8	12	2x4 Prism Troffer	6	0	8	1,295	497
10	P08	Interior		OFFICE	Office		-	4	Light Switch	Linear Fluorescent	T8	4' 32W T8	8	2x4 Prism Troffer	4	0	8	1,295	332
11	P09 and P10	Interior		HALLWAY	Exterior		-	0	Timer	HID	HPS	HPS50	2	Surface Mount	2	0	8	1,295	130
12	P02	Interior		CLASSROOM	35		-	4	Light Switch	Linear Fluorescent	T8	4' 32W T8	96	2x4 Prism Troffer	48	0	8	1,295	3,978
13	P02	Exterior		HALLWAY	Exterior		-	1	Timer	HID	HPS	HPS400	1	Wallpack-Horizontal	1	0	8	1,295	518
14	P02	Exterior		HALLWAY	Exterior		-	1	Timer	CFL	CFL - 4 Pin	CFL42	1	Surface Mount Hor	1	0	8	1,295	54
15	P01	Interior		HALLWAY	Exterior		-	0	Timer	CFL	CFL - 2 Pin	CFL13	5	Wallpack-Vertical	5	0	8	1,295	84
16	006	Exterior		HALLWAY	Exterior		-	1	Timer	CFL	CFL - 2 Pin	CFL13	1	Wallpack-Vertical	1	0	8	1,295	17
17	006	Exterior		HALLWAY	Exterior		-	1	Timer	CFL	CFL - 4 Pin	CFL42	5	Surface Mount Can	5	0	8	1,295	272
18	006	Exterior		HALLWAY	Exterior		-	1	Timer	HID	HPS	HPS400	1	Wallpack-Horizontal	1	0	8	1,295	518
19	006	Interior		CAFETERIA	Multipurpose		-	1	Light Switch	Linear Fluorescent	T8	4' 32W T8	32	2x4 Prism Troffer	16	0	8	1,295	1,326
20	006	Interior		AUDITORIUM	Stage		-	2	Light Switch	Linear Fluorescent	T8	4' 32W T8	12	2x4 Prism Troffer	6	0	8	1,295	497
21	006	Interior		KITCHEN	Kitchen		-	5	Light Switch	Linear Fluorescent	T8	4' 32W T8	20	2x4 Prism Troffer	10	0	8	1,295	829
22	006	Interior		KITCHEN	T001		-	2	Wall-Mounted Sensor	Linear Fluorescent	T8	4' 32W T8	4	2x4 Prism Troffer	2	0	8	1,295	166
23	P01	Interior		CLASSROOM	11		-	10	Light Switch	Linear Fluorescent	T8	4' 32W T8	270	2x4 Prism Troffer	90	0	8	1,295	11,189
24	003	Interior		HALLWAY	Exterior		-	1	Timer	CFL	CFL - 4 Pin	CFL42	7	Surface Mount Can	7	0	8	1,295	381
25	003	Interior		CLASSROOM	10		-	15	Light Switch	Linear Fluorescent	T8	4' 32W T8	180	2x4 Prism Troffer	90	0	8	1,295	7,459
26	001	Interior		OFFICE	1		-	15	Light Switch	Linear Fluorescent	T8	8' 59W T8	120	Industrial	60	0	8	1,295	9,169
27	001	Interior		RESTROOM	T01A		-	4	Light Switch	Linear Fluorescent	T8	4' 32W T8	8	Industrial	4	0	8	1,295	332
28	001	Interior		RESTROOM	Hallway		-	1	Wall-Mounted Sensor	Linear Fluorescent	T8	4' 32W T8	4	2x4 Prism Troffer	2	0	8	1,295	166
29	001	Interior		HALLWAY	Exterior		-	1	Timer	CFL	CFL - 4 Pin	CFL42	12	Surface Mount Can	12	0	8	1,295	653
30	002	Interior		STORAGE	Storage		-	1	Light Switch	Linear Fluorescent	T8	4' 32W T8	4	2x4 Prism Troffer	2	0	8	1,295	166
31	002	Interior		RESTROOM	Restroom		-	2	Light Switch	Linear Fluorescent	T8	4' 32W T8	8	2x4 Prism Troffer	4	0	8	1,295	332
32	004	Exterior		HALLWAY	Exterior		-	1	Timer	CFL	CFL - 4 Pin	CFL42	12	Surface Mount Can	12	0	8	1,295	653
33	005	Interior		HALLWAY	Exterior		-	0	Timer	CFL	CFL - 4 Pin	CFL42	10	Surface Mount Can	10	0	8	1,295	544
34	004	Interior		OFFICE	H001		-	1	Light Switch	Linear Fluorescent	T8	4' 32W T8	8	2x4 Prism Troffer	4	0	8	1,295	332
35	004	Interior		OFFICE	Office		-	2	Wall-Mounted Sensor	Linear Fluorescent	T8	4' 32W T8	36	2x4 Prism Troffer	18	0	8	1,295	1,492
36	004	Interior		OFFICE	C005		-	4	Wall-Mounted Sensor	Linear Fluorescent	T8	4' 32W T8	48	2x4 Prism Troffer	24	0	8	1,295	1,989
37	005	Interior		CLASSROOM	30		-	8	Light Switch	Linear Fluorescent	T8	4' 32W T8	80	2x4 Prism Troffer	40	0	8	1,295	3,315
38	005	Interior		RESTROOM	Women's		-	4	Light Switch	Linear Fluorescent	T8	4' 32W T8	8	2x4 Prism Troffer	4	0	8	1,295	332
Totals													1,113		543			49,210	52,709



									Fixture Details						Existing Consumption						Proposed- Post Retrofit							
Line No.	Building Name	Interior/ Exterior	Floor	Space Type	Room No.	Additional Area Description	Existing Control	Control Quantity	Technology	Sub-Technology	Lamp- Fixture	Fixture Quantity	Total Lamps	Fixture Height	Annual Hours	Existing Annual kWh	ECM	ECM Type	Recommended Sensor	LED Lamp Retrofit	Annual Hours of Operation	Proposed Annual kWh	Annual Savings From LED Retrofit					
1	P011	Interior		CLASSROOM	P011		Light Switch	1	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	12	24	8	1,295	995	ECM		Wall Mounted	4' 17W LED T8	1,295	528	466					
2	P011	Interior		RESTROOM	Restroom		Light Switch	2	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	4	8	8	1,295	332	ECM		Wall Mounted	4' 17W LED T8	1,295	176	155					
3	P011	Interior		CAFETERIA	Cafeteria		Light Switch	1	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	2	4	8	1,295	166	ECM		Wall Mounted	4' 17W LED T8	1,295	88	78					
4	P011	Interior		OFFICE	Office		Light Switch	1	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	4	8	8	1,295	332	ECM		Wall Mounted	4' 17W LED T8	1,295	176	155					
5	P011	Exterior		HALLWAY	Exterior		Timer	0	CFL	CFL - 2 Pin	CFL13; Wallpack-Vertical	2	2	8	1,295	34			Photo Sensor									
6	P011	Exterior		HALLWAY	Exterior		Timer	0	HID	MH	MH400; Wallpack-Vertical	2	2	8	1,295	1,036	ECM		Photo Sensor	70W LED Wallpack	1,295	181	855					
7	P09 and P10	Interior		CLASSROOM	P10		Light Switch	4	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	24	48	8	1,295	1,989	ECM		Wall Mounted	4' 17W LED T8	1,295	1,057	932					
8	P09 and P10	Interior		HALLWAY	Exterior		Timer	0	CFL	CFL - 4 Pin	CFL42; Surface Mount Can	2	2	8	1,295	109			Photo Sensor									
9	P08	Interior		OFFICE	Office		Light Switch	3	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	6	12	8	1,295	497	ECM		Wall Mounted	4' 17W LED T8	1,295	264	233					
10	P08	Interior		OFFICE	Office		Light Switch	4	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	4	8	8	1,295	332	ECM		Wall Mounted	4' 17W LED T8	1,295	176	155					
11	P09 and P10	Interior		HALLWAY	Exterior		Timer	0	HID	HPS	HPS50; Surface Mount	2	2	8	1,295	130	ECM		Photo Sensor	25W LED Flood	1,295	65	65					
13	P02	Exterior		HALLWAY	Exterior		Timer	1	HID	HPS	HPS400; Wallpack-Horizontal	1	1	8	1,295	518	ECM		Wall Mounted	70W LED Wallpack	1,295	91	427					
15	P01	Interior		HALLWAY	Exterior		Timer	0	CFL	CFL - 2 Pin	CFL13; Wallpack-Vertical	5	5	8	1,295	84			Photo Sensor									
17	006	Exterior		HALLWAY	Exterior		Timer	1	CFL	CFL - 4 Pin	CFL42; Surface Mount Can	5	5	8	1,295	272			Photo Sensor									
19	006	Interior		CAFETERIA	Multipurpose		Light Switch	1	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	16	32	8	1,295	1,326	ECM		Ceiling Mounted	4' 17W LED T8	1,295	704	622					
21	006	Interior		KITCHEN	Kitchen		Light Switch	5	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	10	20	8	1,295	829	ECM		Ceiling Mounted	4' 17W LED T8	1,295	440	389					
22	006	Interior		KITCHEN	T001		Wall-Mounted Sensor	2	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	2	4	8	1,295	166	ECM		Retain Existing Controls	4' 17W LED T8	1,295	88	78					
24	003	Interior		HALLWAY	Exterior		Timer	1	CFL	CFL - 4 Pin	CFL42; Surface Mount Can	7	7	8	1,295	381			Photo Sensor									
25	003	Interior		CLASSROOM	10		Light Switch	15	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	90	180	8	1,295	7,459	ECM		Ceiling Mounted	4' 17W LED T8	1,295	3,963	3,497					
26	001	Interior		OFFICE	1		Light Switch	15	Linear Fluorescent	T8	8' 59W T8; Industrial	60	120	8	1,295	9,169	ECM		Wall Mounted	8' 40W LED T8	1,295	6,216	2,953					
27	001	Interior		RESTROOM	T01A		Light Switch	4	Linear Fluorescent	T8	4' 32W T8; Industrial	4	8	8	1,295	332	ECM		Wall Mounted	4' 17W LED T8	1,295	176	155					
28	001	Interior		RESTROOM	Hallway		Wall-Mounted Sensor	1	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	2	4	8	1,295	166	ECM		Retain Existing Controls	4' 17W LED T8	1,295	88	78					
32	004	Exterior		HALLWAY	Exterior		Timer	1	CFL	CFL - 4 Pin	CFL42; Surface Mount Can	12	12	8	1,295	653			Photo Sensor									
33	005	Interior		HALLWAY	Exterior		Timer	0	CFL	CFL - 4 Pin	CFL42; Surface Mount Can	10	10	8	1,295	544			Photo Sensor									
34	004	Interior		OFFICE	H001		Light Switch	1	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	4	8	8	1,295	332	ECM		Ceiling Mounted	4' 17W LED T8	1,295	176	155					
35	004	Interior		OFFICE	Office		Wall-Mounted Sensor	2	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	18	36	8	1,295	1,492	ECM		Retain Existing Controls	4' 17W LED T8	1,295	793	699					
36	004	Interior		OFFICE	C005		Wall-Mounted Sensor	4	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	24	48	8	1,295	1,989	ECM		Retain Existing Controls	4' 17W LED T8	1,295	1,057	932					
37	005	Interior		CLASSROOM	30		Light Switch	8	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	40	80	8	1,295	3,315	ECM		Ceiling Mounted	4' 17W LED T8	1,295	1,761	1,554					
38	005	Interior		RESTROOM	Women's		Light Switch	4	Linear Fluorescent	T8	4' 32W T8; 2x4 Prism Troffer	4	8	8	1,295	332	ECM		Ceiling Mounted	4' 17W LED T8	1,295	176	155					
Totals																	1,113									27,117		22,792

---

---

## **APPENDIX D: ECM Checklist**

---

---

NA	In Place	Evaluate	ECM Description
✓			Add Reflective Coating To Exterior Windows
		✓	Replace External Windows
	✓		Upgrade Insulation
✓			Control External Air Leakage In Commercial Buildings
✓			Install Reflective Insulation Between Radiators And External Wall
✓			Replace Existing Motors With High Efficiency Motors
✓			Install On-Demand Ventilation on Air Handlers
	✓		Reduce HVAC Hours of Operation
✓			Install Variable Frequency Drives (VFD)
✓			Install Outside Air Temperature Reset Controls For Hot Water Boilers
✓			Install Chilled Water Reset Control
✓			Install Timers On Exhaust Fans
✓			Install Energy Savers on Vending, Snack Machines
✓			Install Building Energy Management System and Replace Terminal Units
✓			Re-Commission The Building & Its Control Systems
✓			Replace Inefficient Heating Plant
✓			Replace Inefficient Cooling Plant
✓			Replace Existing Air Conditioners with Energy Star Air Conditioners
✓			Replace Unit Electric Heaters with Natural Gas Fired Unit Heaters
✓			Convert From Gas Pilot to Electronic Ignition for Boilers
	✓		Insulate Hot Water Pipes
	✓		Insulate Refrigerant Lines
✓			Insulate Hot Surfaces And Tanks
	✓		Insulate Air Ducts
✓			Replace Defective Steam Traps
✓			Upgrade Electric Heating System To Heat Pumps
✓			Replace Inefficient Furnace System
		✓	Replace Rooftop Package Unit
✓			Install Energy Recovery Wheel on Air Handling Unit
		✓	Replace Existing Water Heater With New Energy Efficient Units
		✓	Replace Incandescent/Halogen Lamps With Energy Efficient Lamps
		✓	Upgrade Inefficient Linear Fluorescent Lamps And Fixtures
	✓		Upgrade EXIT SIGNS With LED EXIT Signs
✓			Bilevel and Tandem Linear Fluorescent Lighting ECM
		✓	Replace High Intensity Discharge (HID) Lamps With Energy Efficient Lamps
✓			Replace Existing Refrigerator(s) With Energy Star Certified Refrigerator(s)
✓			Replace Existing Freezers With High Efficiency Freezers
✓			Install Low Flow Shower Heads
		✓	Install Low Flow Faucet Aerators
		✓	Install Low Flow Restroom Flush Tank Toilets
		✓	Install Low Flow Tankless Restroom Fixtures

---

---

## **APPENDIX E: ECM Calculations**

---

---

UIC	Install Low Flow Faucet Aerators			
EAP2-b	Location: Restrooms			
Property Type:		Commercial	Estimated No. of Operational Weeks	37
			Number of Occupied Days/Week (Max 7)	5
KITCHEN FAUCETS		BATHROOM FAUCETS		
Number of Occupants Affected By Retrofit	0	Number of Occupants Affected by Retrofit	391	
Do You Want To Replace Kitchen Faucets Aerators	No (Select)	Do You Want To Replace Bathroom Faucets Aerators	Yes (Select)	
Total Number of Faucet Aerators To Be Replaced	0	Total Number of Faucet Aerators To Be Replaced	41	
Total Number of Faucets To Be Replaced:	0	Total Number of Faucets To Be Replaced:	0	
GPM of Existing Faucet Aerators	- GPM	GPM of Existing Faucet Aerators	2.2 GPM	
GPM of Proposed Faucet Aerator	- GPM	GPM of Proposed Faucet Aerator	0.5 GPM	
Estimated Number of Uses Per Day	4	Estimated Number of Uses Per Day	5	
Annual Water Savings From Installing Low Flow Aerators:		59.03	kGal	
WATER & ENERGY SAVING CALCULATION		COST SAVING CALCULATION		
Select Type of Water Heater Fuel:	Natural Gas (Select)	Property Location in United States	North Central Localities	
Energy Factor of Domestic Hot Water Heater:	0.60 EF	Heating Fuel Tariff	\$1.31 \$/Therm	
Hot Water Discharge Temperature at Faucet	110.00 °F	Water Tariff (\$/1000 Gal)	\$5.82 \$/kGal	
Equivalent Heating Fuel Savings:	418 Therms	Annual Cost Savings In Form of Water	\$344 \$	
<small>Savings Discounted by 15% to Account For Cold Water Use</small>		Annual Energy Savings From Water Heater	\$546 \$	
Annual Water Savings	59.03 kGal			
COST BENEFIT ANALYSIS				
Estimated Total Annual Cost Savings	\$890 \$\$	Estimated Total Installation Cost	\$625 \$\$	
Simple Payback Period	0.70 Years	Type of Recommendation	No/Low Cost ECM Recommendation	

Disclaimer: PREPARED BY EMG. May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

#### ECM EXPLANATION:

By reducing the flow of water coming from the restroom faucets, aerators can generate energy savings at low cost and with easy installation. The savings generated would be in the form of reduced water and sewer costs and at the same time aerators would save energy by reducing the demand for hot water. The average faucet has a flow rate of about 2 to 4 GPM. Adding a screw-in faucet aerator reduces the flow to 0.5 to 1.5 GPM in the bathroom and 2.2 GPM in the kitchen. In addition to saving energy and water, the "foamier" water that comes from faucet aerators wets objects better than water from a faucet with no aerator, which tends to bounce off the object rather than thoroughly wetting it.

EMG recommends replacing the proposed faucet aerators with new low flow aerators as mentioned above. The proposed ECM shall also result in an annual energy saving in form of reduction in water heating bills.

#### Summary:

Initial Investment: \$625      Estimated Annual Cost Savings: \$890      Simple Payback Period (Yrs): 0.70

UIC	Replace Existing Water Heater With New Energy Efficient Units			
EAD3	Location: Mechanical Closet			
Step 1	<b>Existing Water Heater Details</b>			
Number of Water Heaters Being Replaced:	1			
Select Existing Hot Water Heater Fuel	Electric	Natural Gas	Natural Gas	Electric
Insert Energy Factor of Existing Water Heater	0.78 EF			
Input Existing Water Heater Input Rating	4.50 kW			
Select One Method For Calculation	Annual Heating Hours	Annual Heating Hours	Annual DWH Load	Annual DWH Load
Insert Average Annual Hours of Operation	1,464 hrs			
Annual Water Heater Energy Consumption/Heater	6,588 kWh	0 Therms	#DIV/0! hrs	#DIV/0! hrs
Total Estimated Annual Energy Consumption For all Heaters	6,588 kWh	0 Therms	0 Therms	0 kWh
Total Estimated Annual Operating Energy Costs For all Heaters	\$1,140 \$	\$0 \$	\$0 \$	\$0 \$
Step 2	<b>Proposed New Water Heater</b>			
Proposed Hot Water Heater Fuel	Electric	Heat Pump	Electric	Natural Gas
Capacity of the Proposed New Water Heater	30-Gal,3.5-kW			
Energy Factor of Proposed Water Heater	0.93 EF	0.00 EF	0.00 EF	0.00 EF
Proposed Water Heater Input Rating	3.50 kW	0.00 kW	0.00 kW	0.00 kBtu/h
Annual kBtu/h Consumption For All The Proposed Water Heaters	18,853 kBtu/h	#DIV/0! kBtu/h	#DIV/0! kBtu/h	#DIV/0! kBtu/h
Estimated Annual Water Heater Fuel Consumption (All Heaters)	5,525 kWh	0 kWh	0 kWh	0 Therms
Estimated Total Annual Energy Costs	\$956 \$	\$0 \$	\$0 \$	\$0 \$
Step 3	<b>Energy &amp; Cost Saving Calculation</b>			
Estimated Cost of New Water Heater/Unit	\$851 \$	\$0 \$	\$0 \$	\$0 \$
Total Estimated Installation Cost	\$1,270 \$	\$0 \$	\$0 \$	\$0 \$
Total Estimated Annual Cost Savings	\$184 \$	\$0 \$	\$0 \$	\$0 \$
Total Annual Cost Savings:	\$184	Total Initial Investment::	\$1,270	
Simple Pay Back Period	6.91			
Type of Recommendation	Capital Cost ECM Recommendation			

Disclaimer: PREPARED BY EMG. DECEMBER 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

**ECM SUMMARY:**


Electric resistance is the most expensive method for heating domestic hot water. A natural gas or propane fired water system provide more units of heat with direct burning of fuel while high wattage draw is required for electric water heaters to create resistance heat. This electric usage can be seen with the increase power demand for the site and the additional kWh consumption. The installation process of the gas/propane fired water heater requires additional measures with tying a gas line or fuel tank to the system along with installing an exhaust gas vent. This process is not a costly retrofit if a current gas line or tank is at the site. The hot water exhaust duct can be tied to the existing gas fired furnaces or boilers for an easy retrofit.

**SUMMARY:**

Initial Investment: \$1,270      Simple Payback: 6.91 yrs  
 Annual Cost Savings: \$184







UIC	Replace Rooftop Package Unit			
EAH12-B	Location: Roof			
Estimated Annual Cooling Hours:		976	Hrs	Estimated Annual Heating Hours:
				1,464
Units to Replace	Air Conditioning	Heating System	Existing Type of Heating Fuel:	
	Yes	Yes	Natural Gas	
Existing Package System				
Number of Package Units to be Replaced:		Cooling	Heating	Total Combined Units
		10	10	10
Capacity of the air conditioner:		4	Tons	EER of the Existing Air Conditioner:
				7.44
Capacity of Existing Heating System:		72	MBH	Input Existing AFUE for the Furnace:
				74%
Estimated Annual Cooling Consumption:		62,968	kWh	Estimated Annual Heating Consumption :
(For All Units)				14,210
				Therms
Proposed Package System				
Capacity of the Proposed Air Conditioner:		4	Tons	EER of the Proposed Air Conditioner:
				10.04
Capacity of Proposed Heating System:		Gas Fired -75MBH	MBH	AFUE of Proposed Heating System:
				78%
Estimated Annual Energy Consumption With New Package Units				
Annual Electric Fuel Consumption:		46,661	kWh	Annual Heating Fuel Consumption:
				14,077
				Therms
Energy and Cost Analysis				
Average Electric Rate:		\$0.17	\$/kWh	Average Heating Rate:
				\$1.31
Estimated Annual Electric Savings :		16,306	kWh	Estimated Annual Heating Savings :
From All New Package Systems				13,284
Annual Electric Cost Savings:		\$2,821		Annual Electric Cost Savings:
From All New Package Systems				\$173
Proposed Type of System to be installed:		Package Heating and Cooling System		
Estimated Material and Labor Cost Including Overheads and Profits For All Units:				\$73,750.00
Estimated Total Energy Cost Savings From New HVAC System:				\$2,994
Estimated O&M Savings:				\$150
Estimated Simple Pay Back Period:		23.4589886	Yrs	Capital Cost ECM Recommendation

Disclaimer: PREPARED BY EMG. May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

UIC	Install Low Flow Tankless Restroom Fixtures	
EAP4	Location: Restrooms	
<b>ECM FOR DETERMINING WATER SAVINGS IN COMMERCIAL PROPERTIES</b>		
Number of Males	176	
Number of Females	215	
Number of Occupied Days Per Week (Max 7)	5	
Number of Occupied Weeks/Year (Max 52)	37	
Number of Urinals To Be Retrofitted	4	
Number of Water Closets To Be Retrofitted	20	
No. of Water Closets With Separate Flush Tank (Typical Residential Type)	0	
Estimated Restroom Usage/Individual/Day <small>Default is 4 Uses/Day For Residential/Office</small>	2	(Select)
<b>Urinal Water Savings</b>		
Do you Want To Make Any Changes To The Urinals?	Yes	
Estimated Existing Use of Urinal/Day/Man	80%	
Existing Gallons Per Flush Ratings For Urinal Flushes	1.00	GPF
Proposed Urinal	0.125 GPF-Wall Mount	
GPF of Proposed Urinal Flush Valve**	0.125	GPF
<small>**1992 EpACT Energy Act Mandates 1.0GPF Max on Urinals</small>		
Estimated Annual Water Savings From Urinal	45.58	kGal
<b>Water Closet Water Savings</b>		
<b>Tankless Water Closets</b>		
Do The Water Closet Need To Be Retrofitted?	(Select) Yes	
Existing Gallons Per Flush Ratings For Water Closet Flushes	1.60	GPF
Are The Existing Water Closet Being Replaced?	(Select) No	
<small>(If No; Then Only The Flush Valve Would Be Replaced With Dual Flush Retrofit Kit)</small>		
No. of Tankless Water Closets	20	
GPF of Proposed Dual Flush- Water Closet Valve*	1.60	GPF
<small>*Federal Law Requires All Flushes Not To Exceed 1.6 GPF</small>		
	Solid Waste(20%)	0.48
	Liquid Waste(80%)	GPF
Estimated Annual Water Savings From Male Users	11.67	kGal
Estimated Annual Water Savings From Female Users	71.28	kGal
Total Water Savings From Water Closets	82.95	kGal
<b>Water &amp; Cost Saving Calculations</b>		
<b>Water Savings Calculation</b>		
Water Savings By The Use of Low Flow Water Closet Flush Valves/Yr	82.95	kGal
Water Savings By The Use of Low Flow Urinal Flush Valves/ Yr	45.58	kGal
Total Annual Water Savings in kGal	128.53	kGal
<b>Cost Savings Calculations</b>		
Enter Water Tariff Rate (\$/1000Gal)	\$5.82	\$\$
Estimated Cost Savings From Water	\$748	\$\$
<b>Estimated Cost of Retrofit</b>		
Cost For Replacing Existing Urinal Fixture With A Low Flow Fixture	\$5,201	\$\$
<small>(Includes Labor)</small>		
Cost For Replacing Existing Flush Valves With Low Flow - Dual Flush Valves (\$80 Per Unit)	\$12,381	\$\$
<small>(Includes Labor)</small>		
<small>(Up For Liquid Waste And Down For Solid Waste)</small>		
Estimated Total Cost For Retrofit	\$17,582	\$\$
Simple Pay Back Period	23.50	Yrs
Type of Recommendation	Capital Cost ECM Recommendation	

Disclaimer: PREPARED BY EMG. May2016. INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

#### ECM EXPLANATION:

The highest water utilization at any home/office occurs in the restrooms. It is estimated that on an average a normal human being uses the restroom at least four times a day. Keeping with the global water conservation objectives, federal law prohibits use of any new water closet flushes over 1.6 GPF. At the same time the '1992 EpACT' mandates all new Urinals to have a maximum 1.0 GPF flush valves on urinals.

EMG recommends replacing all urinals above 1.0 GPF with a new 0.5 GPF or lesser urinals. At the same time EMG also recommends replacing all the water closets having a GPF rating of 1.6 and over with low flow water closet fixtures equipped with dual flush valves.

In case the property doesn't wish to replace the entire water closet fixtures, EMG recommends retrofitting all the tankless water closet flush fixtures with new dual flush fixtures that would result in a 30% water savings per flush for liquid wastes, while retaining the same flush rate for solid wastes.

#### SUMMARY:

Initial Investment:	\$17,582	Simple Payback Period:	23.50 Yrs
Annual Cost Savings:	\$748		

UIC	Retrofit Apartment Tank Toilets to Dual Flush	
EAP3	Location:	
<b>EXISTING CONDITION</b>		
Total Occupants:	<input type="text" value="10"/>	
Number of Water Closets To Be Replaced	<input type="text" value="2"/>	
Number of Occupied Days Per Week (Max 7)	<input type="text" value="5"/>	
Number of Occupied Weeks/Year (Max 52)	<input type="text" value="37"/>	
<b>Estimated Restroom Usage/Individual/Day</b>	<input type="text" value="4"/>	(Select)
<small>5.05 flushes/person/day@American Water Works Association (AWWA)</small>		
<b>PROPOSED RETROFIT/REPLACEMENT</b>		
Existing Gallons Per Flush Ratings For Water Closet Flushes	<input type="text" value="1.28"/>	GPF
Replace or Retrofit Toilets With Dual Flush Toilets	<input type="text" value="Retrofit"/>	
<b>Replace</b>		
Proposed Toilet	<input rough-in"="" type="text" value="0.8GPF -Floor Mount, 10"/>	
GPF of Proposed New Low Flow Water Closet Fixture*	<input type="text" value="0.80"/>	GPF
<b>Retrofit</b>		
Dual Flush - Retrofit Setup Valve for Flush Tank Toilet	<i>Solid Waste (20%)</i> <input type="text" value="1.28"/>	GPF
<i>*(Federal Law Requires All Flushes Not To Exceed 1.6 GPF)</i>	<i>Liquid Waste (80%)</i> <input type="text" value="1.02"/>	GPF
<b>Water &amp; Cost Saving Calculations</b>		
Water Savings By The Use of Low Flow Water Closet Flush Valves/Day	<input type="text" value="8.19"/>	gal
Total Annual Water Savings in gallons	<input type="text" value="1.52"/>	kgal
<b>Cost Savings Calculations</b>		
Enter Water Tariff Rate (\$/1000Gal)	<input type="text" value="\$5.82"/>	\$\$
Estimated Cost Savings From Water	<input type="text" value="\$9"/>	\$\$
<b>Estimated Cost of Retrofit</b>		
Estimated Total Cost For Retrofit	<input type="text" value="\$315"/>	\$\$
Simple Pay Back Period	<input type="text" value="35.67"/>	Yrs
<b>Type of Recommendation</b>	<input type="text" value="No/Low Cost ECM Recommendation"/>	

Disclaimer: PREPARED BY EMG. May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

#### **ECM EXPLANATION:**

The highest water utilization at any home/office occurs in the restrooms. It is estimated that on an average a normal human being uses the restroom at least four times a day. Keeping with the global water conservation objectives, federal law prohibits use of any new water closet flushes over 1.6 GPF.

Existing toilets can be retrofitted with pressure-assisted flush technology to reduce the flush rate to 1.0 GPF or less. Though water efficient these toilets make considerable amount of noise as this involves release of pressurized air during the course of flushing. Thus making them unpopular among residential properties.

Thus EMG recommends replacing the existing high flow toilets with new low flow 1.28GPF rated flush tank toilets, which are comparatively more water efficient at the same time considerably quieter as compared to the pressure assisted technology retrofitted toilets.

#### **Summary:**

Initial Investment:	\$315	Simple Payback:	35.67	Years
Annual Cost Savings:	\$9			

<table border="1"> <tr> <td>UIC</td> <td>Replace External Windows</td> </tr> <tr> <td>EAE2</td> <td>Location: Throughout building</td> </tr> </table>		UIC	Replace External Windows	EAE2	Location: Throughout building
UIC	Replace External Windows				
EAE2	Location: Throughout building				
ENTER EXISTING CONDITIONS					
<div>Existing and Proposed Window Properties</div> <div>Existing &amp; Proposed Air Leakage Through Windows</div>					
Total Sq.Ft window area:	336 sq.ft				
Approximate number of windows:	28				
Total existing window area:	336 Sq.Ft				
Select The Existing Window Type	Metal Frame & Double Glazing (Select)				
Existing U-value of window: (1/R)	0.87 Btu/ft <sup>2</sup> ·°F·h				
ASHRAE Climatic Zone	Zone-3				
New U-value with Double pane Low E window: (1/R)	0.35 Btu/ft <sup>2</sup> ·°F·h				
ASHRAE 90.1 Recommended Value					
Insert Existing Estimated Air Change Rate/Hr (ACH 1):	0.75				
(Existing Air Changes Per Hour, 1.5 is very leaky and 0.35 ideal)					
Insert Proposed Estimated Air Change Rate/Hr (ACH 2):	0.53				
Estimated Space Volume Under Consideration	10,000.00 Cu. Ft				
Is the Property Cooled ?	Yes (Select)				
<div>WINTER</div> <div>SUMMER</div>					
Select Type of Heating Fuel	Natural Gas (Select)				
Net heating plant & distribution system efficiency:	74.18 %				
Annual Heating Hours:	2,963 HDD				
Estimated Total Annual Input Heating Energy Savings By Replacing Windows	1.67 Therms				
Estimated Total Annual Input Heating Energy Savings Achieved By Controlling Air Leakage Through Windows	39 Therms				
Estimated Total Input Heating Fuel Savings From Replacing Windows	40 Therms				
Select Type of Cooling Fuel:	Electric (Default)				
Cooling Plant Efficiency (EER):	7.44 EER				
Annual Cooling Hours:	1,407 CDD				
Annual Total Input Cooling Fuel Savings During Summer Season By Replacing Windows	793 kWh				
Estimated Total Annual Input Cooling Energy Savings Achieved By Controlling Air Leakage Through Windows	184 kWh				
Estimated Total Input Cooling Fuel Savings From Replacing Windows	977 kWh				
ENERGY & COST ANALYSIS					
Insert Cost of Heating Fuel:	\$1.31 \$/Therm				
Insert Cost of Cooling Fuel:	\$0.17 \$/kWh				
Annual Heating Cost Savings:	\$52.89 \$\$				
Annual Cooling Cost Savings:	\$168.97 \$\$				
Total Annual Cost Savings	\$224				
Total Annual Cost Savings From Heating & Cooling:	\$222				
Cost of window upgrade:	\$22,986				
Estimated Annual O&M Savings	\$2				
Simple payback:	102.58 Yrs				
Type of Recommendation	Capital Cost ECM Recommendation				

Disclaimer: PREPARED BY EMG. May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

#### ECM DESCRIPTION:

Windows play a major role in the energy use and comfort of an interior space. In the winter, heat in a room is lost when cold outside air infiltrates around the edges of windows. Heat also can be lost by conduction directly through the pane, even if the window fits tightly. Windows with insulated panes, such as those filled with Argon address this issue, while proper caulking and sealant address the infiltration issue. The cold drafts and the chilly windowpane make the room uncomfortable. Windows also can help to heat a room by letting the sun's rays enter. While this solar radiation is beneficial in the winter, it can be a major source of discomfort in hot, summer climates. Energy Star rated windows with Low-E glazing are designed to keep the solar heat gain minimized during the summer months. Choosing a replacement window that fits properly has the desired U-value, and proper glazing characteristics is critical to energy conservation through window upgrades.

#### Summary:

Initial Investment:	\$22,986	Simple Payback	102.58 Yrs
Annual Energy Cost Savings:	\$224		

---

## **APPENDIX F:**

### **Solar PV**

---

UIC		Install Fixed Tilt Solar Photovoltaic System													
EAR-2		Details:													
Select State:		Northern California		Electric Rate:		\$0.17		\$/KWH		Annual Electric Consumption:		198,969		KWh	
Roof No.	Description	Number of Roofs	DC System Size Per Roof	PV System Sizing For All Roofs	Estimated Number of 315 Watt PV Panels:	Total Estimated Annual Electricity Generated/ Roof	Total Estimated Electricity Generated (All Roofs)	Total Cost Savings	Installation Cost: (\$3.5/Watt)	Simple Pay Back Period without Incentives	One Time Potential Utility or State Incentives	One Time Potential Federal Incentives	Annual Potential Incentives and Rebates		Simple Pay Back Period with All Incentives
			kW	kW		kWh	kWh			Yrs		Dept. of Treasury Renewable Grant (30%)	Federal REPI Incentive	Solar Renewable Certificates (SRECS)- (~\$0/MWH)	Years
												30%	\$0.02	\$0	
1	Building 1	1	20.20	20	64	31,115	31,115	\$5,290	\$70,700	13.4	\$0	\$21,210	\$685	\$0	8.1
2	Building 2	1	13	13	1	20,179	20,179	\$3,430	\$45,850	13.4	\$0	\$13,755	\$444	\$0	8.1
3	Building 3	1	21	21	1	32,348	32,348	\$5,499	\$73,500	13.4	\$0	\$22,050	\$712	\$0	8.1
4	Building 4	1	22	22	1	33,118	33,118	\$5,630	\$75,250	13.4	\$0	\$22,575	\$729	\$0	8.1
5	Building 5	1	34	34	1	52,526	52,526	\$8,929	\$119,350	13.4	\$0	\$35,805	\$1,156	\$0	8.1
6	Building 7	1	14	14	1	22,027	22,027	\$3,745	\$50,050	13.4	\$0	\$15,015	\$485	\$0	8.1
7															
8				0	0		0	\$0	\$0		\$0	\$0	\$0	\$0	
9				0	0		0	\$0	\$0		\$0	\$0	\$0	\$0	
10				0	0		0	\$0	\$0		\$0	\$0	\$0	\$0	
		6		124	69	191,313.0	191,313	\$32,523	\$434,700	13.37	\$0	\$130,410	\$4,209	\$0	8.06

Solar Rooftop Photovoltaic Analysis	
Total Number of Roofs	6
Estimated Number of Panels	69
Estimated KW Rating	124 KW
Potential Annual KWh Produced	191,313 KWh
% of Current Electricity Load	96.2%

Financial Analysis	
Investment Cost	\$434,700
Estimated Energy Cost Savings	\$32,523
Potential Rebates	\$130,410
Potential Annual Incentives	\$4,209
Payback without Incentives	13.4 years
Incentive Payback but without SRECS	8.1 years
Payback with All Incentives	8.1 years

Disclaimer: PREPARED BY EMG. JANUARY 2017, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.