



A Bureau Veritas Group Company

LEVEL II ENERGY AUDIT

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT
5735 47th Avenue
Sacramento, California 95824

DLR GROUP
1050 20th Street, Suite 250
Sacramento, California 95939



ZERO NET ENERGY ASHRAE LEVEL II AUDIT
NICHOLAS ELEMENTARY SCHOOL
6601 Steiner Drive
Sacramento, California 95823

PREPARED BY:

EMG / A Bureau Veritas Company
10461 Mill Run Circle, Suite 1100
Owings Mills, Maryland 21117
800.733.0660
www.emgcorp.com

EMG CONTACT:

Kaustubh Anil Chabukswar
Program Manager
800.733.0660 x7512
kachabukswar@emgcorp.com

EMG PROJECT #:

136988.19R000-038.268

DATE OF REPORT:

October 25, 2019

ONSITE DATE:

September 19 & 20, 2019



engineering | environmental | capital planning | project management

A Bureau Veritas Group Company



www.EMGcorp.com | 800.733.0660

TABLE OF CONTENTS

Certification	1
1. .. Executive Summary	2
1.1. Energy Conservation Measures	3
2. .. Introduction	8
3. .. Facility Overview and Existing Conditions	9
3.1. Building Occupancy and Point of Contact	9
3.2. Building Heating, Ventilating and Air-Conditioning (HVAC)	9
3.3. Lighting	10
4. .. Utility Analysis	11
4.1. Electricity	12
4.2. Natural Gas	14
4.3. Water and Sewer	16
5. .. Renewable Energy Discussions	18
5.1. Rooftop Solar Photovoltaic Feasibility	18
6. .. Operations and Maintenance Plan	20
7. .. Appendices	22
APPENDIX A:	Glossary of Terms
APPENDIX B:	Mechanical Equipment Inventory
APPENDIX C:	Lighting System Schedule
APPENDIX D:	ECM Checklist
APPENDIX E:	ECM Calculations
APPENDIX F:	Solar PV

Certification

EMG has completed an Energy Audit of Nicholas Elementary School located at 6601 Steiner Drive in Sacramento, California 95823. EMG visited the site on September 19 & 20, 2019.

The assessment was performed at the Client's request using methods and procedures consistent with ASHRAE Level II Energy Audit and using methods and procedures as outlined in EMG's Proposal.

This report has been prepared for and is exclusively for the use and benefit of the Client identified on the cover page of this report. The purpose for which this report shall be used shall be limited to the use as stated in the contract between the client and EMG.

This report, or any of the information contained therein, is not for the use or benefit of, nor may it be relied upon by any other person or entity, for any purpose without the advance written consent of EMG. Any reuse or distribution without such consent shall be at the client's or recipient's sole risk, without liability to EMG.

Estimated installation costs are based on EMG's experience on similar projects and industry standard cost estimating tools including *RS Means and Whitestone CostLab*. In developing the installed costs, EMG also considered the area correction factors for labor rates for Sacramento, California 95823. Since actual installed costs may vary widely for particular installation based on labor & material rates at time of installation, EMG does not guarantee installed cost estimates and shall in no event be liable should actual installed costs vary from the estimated costs herein. We strongly encourage the owner to confirm these cost estimates independently. EMG does not guarantee the costs savings estimated in this report. EMG shall in no event be liable should the actual energy savings vary from the savings estimated herein.

EMG certifies that EMG has no undisclosed interest in the subject property and that EMG's employment and compensation are not contingent upon the findings or estimated costs to remedy any deficiencies due to deferred maintenance and any noted component or system replacements.

Any questions regarding this report should be directed to Kaustubh Anil Chabukswar at 800.733.0660, ext. 7512.

Prepared by: Noah Strafford
Energy Auditor
Project Manager

Reviewed by: 
Kathleen Wright
Technical Report Reviewer for
Kaustubh Anil Chabukswar, CEM CRM
Program Manager

1. Executive Summary

The purpose of this Energy Audit is to provide Sacramento City Unified School District and Nicholas Elementary School with a baseline of energy usage and the relative energy efficiency of the facility and specific recommendations for Energy Conservation Measures. Information obtained from these analyses may be used to support a future application to an Energy Conservation Program, Federal & Utility grants towards energy conservation, support performance contracting, justify a municipal bond funded improvement program, or as a basis for replacement of equipment or systems.

Bldg #	Structures Assessed	Building Type	EMG Calculated Area (SF)	Estimated Occupancy
1	001 Main Building	School Building	11,749	160
2	002 Classrooms 3-7	School Building	5,729	100
3	003 classrooms 9-12	School Building	7,276	110
4	P01 Classrooms K-3	Portable School Building	960	20
5	P02 Classrooms P-18	Portable School Building	960	20
6	P03 Classrooms P-1 to P-7	Portable School Building	6,720	90
7	P04-P07 Classrooms P-08 to P-11	Portable School Building	3,840	60
8	P08-P11 Classrooms P-12 to P-17	Portable School Building	5,760	80
9	P12 Restrooms	Portable School Building	480	12

The study included a review of the building's construction features, historical energy and water consumption and costs, review of the building envelope, HVAC equipment, heat distribution systems, lighting, and the building's operational and maintenance practices.

1.1. Energy Conservation Measures

EMG has identified eight Energy Conservation Measures (ECMs) for this property. The savings for each measure is calculated using standard engineering methods followed in the industry, and detailed calculations for ECM are provided in Appendix E for reference. A 10% discount in energy savings was applied to account for the interactive effects amongst the ECMs. In addition to the consideration of the interactive effects, EMG has applied a 15% contingency to the implementation costs to account for potential cost overruns during the implementation of the ECMs.

The following table summarizes the recommended ECMs in terms of description, investment cost, energy consumption reduction, and cost savings.

Summary of Financial Information for Recommended Non-Renewable Energy Conservation Measures

Item	Estimate
Net Initial ECM Investment <i>(Current Dollars Only)</i>	\$152,242 <i>(In Current Dollars)</i>
Estimated Annual Cost Savings <i>(Current Dollars Only)</i>	\$20,782 <i>(In Current Dollars)</i>
ECM Effective Payback	7.33 years
Estimated Annual Energy Savings	40.4%
Estimated Annual Energy Utility Cost Savings <i>(Excluding Water)</i>	35.0%

Solar Photovoltaic (PV) Screening for NICHOLAS ELEMENTARY SCHOOL

Solar Rooftop Photovoltaic Analysis		
Estimated Number of Panels	273	
Estimated KW Rating	86	KW
Potential Annual kWh Produced	331,884	kWh
% of Current Electricity Uses	61.8%	
Financial Summary		
Investment Cost	\$301,000	
Estimated Energy Cost Savings	\$24,422	
Payback without Incentives	12.3	Years
Incentive Payback but without SRECs	7.4	Years
Payback with All Incentives	7.4	Years

Key Metrics to Benchmark the Subject Property's Energy Usage Profile

- **Building Site Energy Use Intensity** - The sum of the total site energy use in thousands of Btu per unit of gross building area. Site energy accounts for all energy consumed at the building location only not the energy consumed during generation and transmission of the energy to the site.
- **Building Source Energy Use Intensity** – The sum of the total source energy use in thousands of Btu per unit of gross building area. Source energy is the energy consumed during generation and transmission in supplying the energy to your site.
- **Building Cost Intensity** - This metric is the sum of all energy use costs in dollars per unit of gross building area.

- Greenhouse Gas Emissions - Although there are numerous gases that are classified as contributors to the total for Greenhouse Emissions, the scope of this energy audit focuses on carbon dioxide (CO₂). Carbon dioxide enters the atmosphere through the burning of fossil fuels (oil, natural gas, and coal), solid waste, trees and wood products, and also as a result of other chemical reactions (e.g., manufacture of cement).

Site Energy Use Intensity (Eui)	Rating
Current Site Energy Use Intensity (EUI)	25 kBtu/ft ²
Post ECM Site Energy Use Intensity (EUI)	15 kBtu/ft ²
Source Energy Use Intensity (Eui)	Rating
Current Source Energy Use Intensity (EUI)	65 kBtu/ft ²
Post ECM Source Energy Use Intensity (EUI)	42 kBtu/ft ²
Building Cost Intensity (Bci)	Rating
Current Building Cost Intensity	\$1.02/ft ²
Post ECM Building Cost Intensity	\$0.67/ft ²

Summary of the Greenhouse Gas Reductions from Recommended Non-Renewable Energy Conservation Measures

The following table provides a summary of the projected Greenhouse Gas Emissions reductions as a result of the recommended Energy Conservation Measures:

Greenhouse Gas Emissions Reduction	
Estimated Annual Thermal Energy Reduction	445 MMbtu
Total CO ₂ Emissions Reduced	33.66 MtCO ₂ /Yr.
Total Cars Off the Road (Equivalent)*	6
Total Acres of Pine Trees Planted (Equivalent)*	8

**Equivalent reductions per DOE emissions calculation algorithms*

Zero Net Energy Analysis for Renewable and Non-Renewable Recommended Measures

Zero Net Energy Analysis	
Building Annual Net Energy Consumption	1,107,361 kBtu
Total Annual Energy Savings for Non-Renewable Energy Measures	444,775 kBtu
Total Annual Energy Savings from Renewable Energy Measures	449,988 kBtu
Total Annual Energy Savings	894,763 kBtu
Net Energy Consumption from Grid Post Implementation	212,598 kBtu



Zero Net Energy Analysis	
% Energy Reduction (Annual Energy-Net Energy) / (Annual Energy)	19%

Energy Conservation Measures Screening:

EMG screens ECMs using two financial methodologies. ECMs which are considered financially viable must meet both criteria.

1. Simple Payback Period –The number of years required for the cumulative value of energy or water cost savings less future non-fuel or non-water costs to equal the investment costs of the building energy or water system, without consideration of discount rates. ECMs with a payback period greater than the Expected Useful Life (EUL) of the project are not typically recommended, as the cost of the project will not be recovered during the lifespan of the equipment. These ECMs are recommended for implementation during future system replacement. At that time, replacement may be evaluated based on the premium cost of installing energy efficient equipment.

$$\text{Simple Payback} = \frac{\text{Initial Cost}}{\text{Annual Savings}}$$

2. Savings-to-Investment Ratio (SIR) – The savings-to-investment ratio is the ratio of the present value savings to the present value costs of an energy or water conservation measure. The numerator of the ratio is the present value over the estimated useful life (EUL) of net savings in energy or water and non-fuel or non-water operation and maintenance costs attributable to the proposed energy or water conservation measure. The denominator of the ratio is the present value of the net increase in investment and replacement costs less salvage value attributable to the proposed energy or water conservation measure. It is recommended that energy efficiency recommendations should be based on a calculated SIR, with larger SIRs receiving a higher priority. A project is typically only recommended if SIR is greater than or equal to 1.0, unless other factors outweigh the financial benefit.

$$SIR = \frac{\text{Present Value (Annual Savings, } i\%, \text{ EUL)}}{\text{Initial Cost}}$$

List of Recommended Energy Conservation Measures For Nicholas Elementary School												
ECM #	Description of ECM	Projected Initial Investment	Estimated Annual Energy Savings		Estimated Annual Water Savings	Estimated Cost Savings	Estimated Annual O&M Savings	Total Estimated Annual Cost Savings	Simple Payback	S.I.R.	Life Cycle Savings	Expected Useful Life (EUL)
			Steam	Electricity								
		\$	Mlbs	kWh	kgal	\$	\$	\$	Years		\$	Years
No/Low Cost Recommendations												
1	Install Low Flow Faucet Aerators Location: Restrooms And Classrooms	\$548	0	0	141	\$6,047	\$0	\$6,047	0.09	94.07	\$51,037	10.00
Totals for No/Low Cost Items		\$548	0	0	141	\$6,047	\$0	\$6,047	0.09			
Capital Cost Recommendations												
1	Reduce HVAC Hours of Operation Location: Throughout	\$12,776	0	16,992	0	\$3,805	\$0	\$3,805	3.36	3.56	\$32,647	15.00
2	Install Timers On Exhaust Fans Location: Throughout	\$1,062	0	4,642	0	\$1,564	\$0	\$1,564	0.68	17.59	\$17,611	15.00
3	Replace Existing Water Heater With New Energy Efficient Units Location: P01	\$1,002	0	863	0	\$160	\$0	\$160	6.27	2.19	\$1,197	18.00
4	Upgrade Building Lighting to LED and Install Automatic Lighting Controls Location: Building Interior And Exterior	\$95,632	0	46,940	0	\$8,692	\$5,767	\$14,459	6.61	1.80	\$76,979	15.00
5	Re-Commission The Building & Its Control Systems Location: Throughout	\$19,466	0	6,372	0	\$1,797	\$0	\$1,797	10.83	1.10	\$1,988	15.00
6	Install Low Flow Restroom Flush Tank Toilets Location: Restrooms And Locker Rooms	\$1,897	0	0	461	\$16,063	\$0	\$16,063	0.12	125.95	\$237,081	20.00
Total For Capital Cost		\$131,836	0	75,810	461	\$32,082	\$5,767	\$37,848	3.48			
	<i>Interactive Savings Discount @ 10%</i>		0	-7,581	-60	-\$3,813	-\$577	-\$4,390				
	<i>Total Contingency Expenses @ 15%</i>	\$19,858										
#NAME?		\$152,242	0	68,229	542	\$34,316	\$5,190	\$39,506	3.85			

In addition to the above measures, EMG has identified the following measure(s) but has not recommended as they fail to meet the above-mentioned financial criteria of SIR>1.0. Thus, EMG has classified the measure(s) as recommended for consideration.



List of Recommended For Consideration Energy Conservation Measures For Nicholas Elementary School												
ECM #	Description of ECM	Initial Investment	Annual Energy Savings		Annual Water Savings	Cost Savings	Estimated Annual O&M Savings	Total Estimated Annual Cost Savings	Payback	S.I.R.	Life Cycle Savings	Expected Useful Life (EUL)
			\$	Steam								
1	Replace External Windows	\$224,930	0	30,643	0	\$8,221	\$82	\$8,303	27.09	0.64	-\$80,351	25.00
	Location: Throughout											
2	Install Low Flow Tankless Restroom Fixtures	\$12,381	0	0	0	\$17,491	\$0	\$17,491	0.71	#DIV/0!	\$196,425	15.00
	Location: Restrooms											
Total for Improvements		\$224,930	0	30,643	0	\$8,221	\$82	\$8,303	27.09			



2. Introduction

The purpose of this Energy Audit is to provide Nicholas Elementary School and Sacramento City Unified School District with a baseline of energy usage, the relative energy efficiency of the facility, and specific recommendations for Energy Conservation Measures. Information obtained from these analyses may be used to support a future application to an Energy Conservation Program, Federal and Utility grants towards energy conservation, as well as support performance contracting, justify a municipal bond-funded improvement program, or as a basis for replacement of equipment or systems.

The energy audit consisted of an onsite visual assessment to determine current conditions, itemize the energy consuming equipment (i.e. Boilers, Make-Up Air Units, DWH equipment); review lighting systems both exterior and interior; and review efficiency of all such equipment. The study also included interviews and consultation with operational and maintenance personnel. The following is a summary of the tasks and reporting that make up the Energy Audit portion of the report.

The following is a summary of the tasks and reporting that make up the Energy Audit portion of the report.

ENERGY AND WATER USING EQUIPMENT

- EMG has surveyed the common areas, office areas, rooms, maintenance facilities and mechanical rooms to document utility-related equipment, including heating systems, cooling systems, air handling systems and lighting systems.

BUILDING ENVELOPE

- EMG has reviewed the characteristics and conditions of the building envelope, checking insulation values and conditions. This review also includes an inspection of the condition of walls, windows, doors, roof areas, insulation and special use areas

RECOMMENDATIONS FOR ENERGY SAVINGS OPPORTUNITIES

- Based on the information gathered during the on site assessment, the utility rates, as well as recent consumption data and engineering analysis, EMG has identified opportunities to save energy and provide probable construction costs, projected energy/utility savings and provide a simple payback analysis.

ANALYSIS OF ENERGY CONSUMPTION

- Based on the information gathered during the on-site assessment, EMG has conducted an analysis of the energy usage of all equipment, and identified which equipment is using the most energy and what equipment upgrades may be necessary. As a result, equipment upgrades, or replacements are identified that may provide a reasonable return on the investment and improve maintenance reliability.

ENERGY AUDIT PROCESS

- Interviewing staff and review plans and past upgrades
- Performing an energy audit for each use type
- Performing a preliminary evaluation of the utility system
- Analyzing findings, utilizing ECM cost-benefit worksheets
- Making preliminary recommendations for system energy improvements and measures
- Estimating initial cost and changes in operating and maintenance costs based on implementation of energy efficiency measures
- Ranking recommended cost measures, based on the criticality of the project and the largest payback

REPORTING

The EMG Energy Audit Report includes:

- A comprehensive study identifying all applicable Energy Conservation Measures (ECMs) and priorities, based on initial cost and payback
- A narrative discussion of building systems/components considered and a discussion of energy improvement options;
- A summary of ECMs including initial costs and simple paybacks, based on current utility rates and expected annual savings.

3. Facility Overview and Existing Conditions

3.1. Building Occupancy and Point of Contact

Facility Schedule	
Hours of Operations / Week	35
Operational Weeks / Year	36
Estimated Facility Occupancy	651
% of Male Occupants	50%

Point Of Contact	
Point of Contact Name	Ken Ramirez
Point of Contact Title	SPOM1
Point of Contact – Contact Number	(916) 395-4500

3.2. Building Heating, Ventilating and Air-Conditioning (HVAC)

Description:

Heating and cooling of permanent buildings 001-003 is provided primarily by central split AC systems with natural gas forced-air furnaces. Packaged rooftop units provide additional heating and cooling to building 001. The portable units are served by a mixture of wall mounted heat pumps and wall mounted gas/ electric package units.

The Mechanical Equipment Schedule in Appendix E contains a summary of the HVAC Equipment at the property.

Building Central Heating System	
Primary Heating System	Forced Air Furnace and Rooftop Packaged Units
Secondary Heating System	Wall Mounted Package Units
Hydronic Distribution System	Not Applicable
Primary Heating Fuel	Natural Gas
Heating Mode Set-point	69 °F
Heating Mode- Set-back Temperature	53 °F

Building Cooling System	
Primary Cooling System	Split Systems
Secondary Cooling System	Wall Mounted Package Units
Hydronic Distribution System	Not Applicable
Cooling Mode Set-point	73 °F
Cooling Mode- Set-back Temperature	93 °F

Air Distribution System	
Building Ventilation	Roof-top Exhaust Fans
On-Demand Ventilation System in Use?	No
Energy Recovery Wheel / Enthalpy Wheel Exhaust Fans	No

Domestic Hot Water System	
Primary Domestic Water Fuel	Natural Gas

3.3. Lighting

Description:

The lighting in the school building primarily consists of T8 linear fluorescent lamp fixtures in classrooms and hallways. The fixtures were observed to be operating on bi-level mode in the classrooms. The exterior lights were primarily High Intensity Discharge (HID) fixtures.

The detailed lighting schedule and the proposed LED alternative is provided in Appendix C

4. Utility Analysis

Establishing the energy baseline begins with an analysis of the utility cost and consumption of the building. Utilizing the historical energy data and local weather information, we evaluate the existing utility consumption and assign it to the various end-uses throughout the buildings. The Historical Data Analysis breaks down utilities by consumption, cost and annual profile.

This data is analyzed, using standard engineering assumptions and practices. The analysis serves the following functions:

- Allows our engineers to benchmark the energy and water consumption of the facilities against consumption of efficient buildings of similar construction, use and occupancy.
- Generates the historical and current unit costs for energy and water
- Provides an indication of how well changes in energy consumption correlate to changes in weather.
- Reveals potential opportunities for energy consumption and/or cost reduction. For example, the analysis may indicate that there is excessive, simultaneous heating and cooling, which may mean that there is an opportunity to improve the control of the heating and cooling systems.

By performing this analysis and leveraging our experience, our engineers prioritize buildings and pinpoint systems for additional investigation during the site visit, thereby maximizing the benefit of their time spent on-site and minimizing time and effort by the customer's personnel.

Based upon the utility information provided about the Sacramento City Unified School District, the following energy rates are utilized in determining existing and proposed energy costs.

Utility Rates used for Cost Analysis

Electricity (Blended Rate)	Natural Gas	Water / Sewer
\$0.19 /kWh	\$1.32 /therm	\$34.86 /kGal

The data analyzed provides the following information: 1) breakdown of utilities by consumption, 2) cost and annual profile, 3) baseline consumption in terms of energy/utility at the facility, 4) the Energy Use Index, or Btu/sq. ft, and cost/sq. ft. For multiple water meters, the utility data is combined to illustrate annual consumption for each utility type.



4.1. Electricity

PG&E satisfies the electricity requirements for the facility. The primary end uses for electric utility comprises of lighting, cooling, office/school equipment, and appliances in the break room.

The table below provides the electric use for the period of twelve continuous months.

Electric Consumption and Cost Data

Billing Month	Consumption (Kwh)	Unit Cost/Kwh	Total Cost
July, 18	17,917.18	0.19	3,477.77
August, 18	15,451.44	0.21	3,304.45
September, 18	22,903.85	0.17	3,895.91
October, 18	21,138.13	0.17	3,628.70
November, 18	14,630.54	0.19	2,740.42
December, 18	16,849.52	0.18	3,110.05
January, 19	14,921.75	0.19	2,825.98
February, 19	17,109.62	0.18	3,026.25
March, 19	17,699.93	0.19	3,297.92
April, 19	16,011.68	0.19	3,059.49
May, 19	18,229.53	0.18	3,249.92
June, 19	20,609.31	0.19	3,913.78
Total/average	213,472.48	0.19	39,530.64





4.2. Natural Gas

SMUD Gas satisfies the natural gas requirements of the facility. The primary end use of natural gas is for building heating, domestic water heating, and cooking in the cafeteria.

The analysis of the 12 months of consumption is provided below.

Natural Gas Consumption and Cost Data

Billing Month	Consumption (Therms)	Unit Cost/Therm	Total Cost
July, 18	26	\$2.19	\$57
August, 18	28	\$2.08	\$59
September, 18	53	\$1.53	\$82
October, 18	109	\$1.30	\$142
November, 18	427	\$1.22	\$521
December, 18	681	\$1.37	\$930
January, 19	781	\$1.29	\$1,007
February, 19	750	\$1.31	\$985
March, 19	559	\$1.32	\$741
April, 19	200	\$1.28	\$256
May, 19	123	\$1.31	\$161
June, 19	51	\$1.32	\$67
Total/average	3,790	\$1.32	\$5,008





4.3. Water and Sewer

The City of Sacramento satisfies the water requirements for the facility. The primary end use of water is the plumbing fixtures such as staff showers, water closets, and lavatories. The table below provides the twelve continuous months' worth of consumption and cost for water in kGal for the facility.

Water and Sewer Consumption and Cost Data

Billing Month	Consumption (Kgal)	Unit Cost/Kgal	Total Cost
July,18	46	\$0.15	\$7,134
August,18	31	\$0.17	\$5,170
September,18	93	\$11.27	\$1,052
October,18	86	\$12.45	\$1,073
November,18	58	\$17.96	\$1,038
December,18	48	\$20.77	\$994
January,19	34	\$26.60	\$906
February,19	31	\$26.85	\$826
March,19	35	\$29.11	\$1,025
April,19	41	\$24.10	\$994
May,19	81	\$13.05	\$1,059
June,19	63	\$20.66	\$1,298
Total/average	78,115	\$34.86	\$22,569



5. Renewable Energy Discussions

5.1. Rooftop Solar Photovoltaic Feasibility

Solar Energy Feasibility

A photovoltaic array is a linked collection of photovoltaic modules, which are in turn made of multiple interconnected solar cells. The cells convert solar energy into direct current electricity via the photovoltaic effect. The power that one module can produce is seldom enough to meet requirements of a home or a business, so the modules are linked together to form an array. Most PV arrays use an inverter to convert the DC power produced by the modules into alternating current that can plug into the existing infrastructure to power lights, motors, and other loads. The modules in a PV array are usually first connected in series to obtain the desired voltage; the individual strings are then connected in parallel to allow the system to produce more current. Solar arrays are typically measured by the peak electrical power they produce, in watts, kilowatts, or even megawatts.

When determining if a site is suitable for a solar application, two basic considerations must be evaluated:

- At minimum, the sun should shine upon the solar collectors from 9 AM to 3 PM. If less, the application may still be worthwhile, but the benefit will be less.
- The array should face south and be free of any shading from buildings, trees, rooftop equipment, etc. If the array is not facing directly south, there will be a penalty in transfer efficiency, reducing the overall efficiency of the system.

Solar Pv Questionnaire	Response
Does the property have a south, east, or west facing roof or available land of more than 250 square feet per required Solar Array Panel?	Yes
Is the area free from any shading such as trees, buildings, equipment etc. throughout the whole day?	Yes
Can the panels be mounted at an incline of roughly 25-45 degrees? (equal to latitude of property)	Yes
Is the property in an area with acceptable average monthly sunlight levels?	Yes
Has the roofing been replaced within the past 3-5 years?	No
Is the roof structure sufficient to hold solar panels?	Additional Study is Required
Is the property located in a state eligible for net metering?	Yes

A solar feasibility analysis of the XXX site has resulted in the building containing more than sufficient amount of roof area for solar electricity generation. The analysis through the use of National Renewable Energy Laboratory’s solar photovoltaic software assisted in calculating the potential electricity generated from the allocated land and roof area set for solar photovoltaic installment. The allocated roof area was through looking at the roof and surrounding areas at a bird’s eye view. Also detailed in the report are incentives and rebates that can potentially bring down the installation cost of the ECMs and result in a higher return on investment and quicker payback period.

The approach taken in the solar photovoltaic (PV) roof analysis begins with surveying the roof and determine areas on the roof where solar PV panels can potentially be installed.

- 1) Conducting a preliminary sizing of solar PV panels on the roofs and on the ground and its potential electricity production for its first year of installment using the National Renewable Energy Laboratory (NREL) PV WATTS Version 2 Software.
- 2) Calculate energy and cost savings for the site as a sole proprietor of the system capable of collecting state, local, and federal tax credits and incentives and interconnecting and selling the renewable energy electrical production to the building.

Solar Rooftop Photovoltaic Analysis		
Estimated Number of Panels	273	
Estimated KW Rating	86	KW
Potential Annual kWh Produced	331,884	kWh
% of Current Electricity Uses	61.8%	
Financial Summary		
Investment Cost	\$301,000	
Estimated Energy Cost Savings	\$24,422	
Payback without Incentives	12.3	Years
Incentive Payback but without SRECs	7.4	Years
Payback with All Incentives	7.4	Years

A photovoltaic array is a linked collection of photovoltaic modules, which are in turn made of multiple interconnected solar cells. The cells convert solar energy into direct current. Modules of cells are linked together to form an array. Most PV arrays use an inverter to convert the DC power produced by the modules into alternating current that can connect to existing AC infrastructure to power lights, motors, and other loads.

Cost of production has fallen years with increasing demand and through production and technological advances. The cost dropped from \$8–10/watt in 1996 to \$4–7/watt in 2006. The market is diversifying with new types of panels suited to unique installation methods including stick on sheets and PV spray coating. The solar PV cost used in the analysis was set at \$7.0/Watt which includes design, construction, administration, and installation and maintenance cost throughout the life of the solar panels.

One breakthrough for PV is “Net Metering”. When more PV electric power is generated than is consumed on site, the electric service meter reverses to “sell” the excess power directly back onto the power grid. The economics of PV for commercial industrial installations become attractive when coupled with incentives from Federal and state agencies, as well utility companies.

A kilowatt-hour costing \$0.15 might be valued at \$0.30 when produced by PV and sent to the grid. The economics of PV for commercial industrial installations become attractive when coupled with incentives from Federal and state agencies, as well utility companies.

The low payback period is highly dependent on the marketing potential of selling Solar Renewable Certificates to electricity generated providers who are under state regulations to contain a certain percentage of their electricity generation derived from renewable energy such as wind and solar.

Solar facilities are encouraged to sell their SRECs on the market (either spot market or through long-term contracts). Utilities may use SRECs for compliance under the state RPS for the year in which they are generated. Utilities may purchase up to 10% more SRECs than they require for compliance and “bank” those surplus SRECs for compliance during the following two years. Any SRECs pricing can range from \$300 - \$450/MWh and can be sold across state borders to other utility providers looking to purchase SRECs. EMG has selected to use the market value of \$300/MWh minus 5% administrative fee in the analysis.

A number of states and corresponding electrical utility supplier are required under regulation to have a certain percentage of its electricity be produced by solar energy. To offset that they allow other utility companies to buy Renewable Energy Credits (REC) credit off their customers and facilities that produce their own solar energy. Typically, the national market, the utility market is \$400 per MWh to Utility Suppliers for not meeting this standard percentage so these REC credits are sold for \$350 per MWh. (1 REC credit = 1 MWh).

State charges these utility companies to meet their state compliance of 0.2% of the entire electricity consumption from solar energy by 2022 (from.005% in 2008 aggregated up to 0.2% by 2022). The REC credits correspond to these percentages as they aggregate each year.

6. Operations and Maintenance Plan

The quality of the maintenance and the operation of the facility's energy systems have a direct effect on its overall energy efficiency. Energy-efficiency needs to be a consideration when implementing facility modifications, equipment replacements, and general corrective actions. The following is a list of activities that should be performed as part of the routine maintenance program for the property.

Building Envelope

- ✓ Ensure that the building envelope has proper caulking and weather stripping.
- ✓ Patch holes in the building envelope with foam insulation and fire rated caulk around combustion vents
- ✓ Inspect building vents semiannually for bird infestation
- ✓ Inspect windows monthly for damaged panes and failed thermal seals
- ✓ Repair and adjust automatic door closing mechanisms as needed.

Heating and Cooling

- ✓ Pilots lights on furnaces and boilers be turned off in summer
- ✗ All preventive maintenance should be performed on all furnaces and boilers, which would include cleaning of burners and heat exchanger tubes.
- ✗ Ensure that the combustion vents exhaust outside the conditioned space and the vent dampers are functional
- ✗ Ensure that the control valves are functioning properly before start of every season
- ✗ Ensure steam traps are functional before start of each heating season
- ✗ Ensure use of chemical treatment for boiler make up water
- ✗ Ensure boiler outside temperature re-set is set to 55F
- ✗ Ensure use of chemical treatment for Colling tower water to prevent corrosion
- ✓ Ensure the duct work in unconditioned space is un-compromised and well insulated
- ✓ Duct cleaning is recommended every 10 years. This should include sealing of ducts using products similar to 'aero-seal'
- ✗ Ensure use of economizer mode is functional and used
- ✓ Ensure that the outside air dampers actuators are operating correctly
- ✗ Ensure air coils in the AHU and FCA's are pressure washed annually
- ✓ Return vents should remain un-obstructed and be located centrally
- ✓ Temperature settings reduced in unoccupied areas and set points seasonally adjusted.
- ✓ Evaporator coils and condenser coils should be regularly cleaned to improve heat transfer
- ✓ Refrigerant pipes should be insulated with a minimum of ¾" thick Elastomeric Rubber Pipe Insulation
- ✓ Ensure refrigerant pressure is maintained in the condensers
- ✓ Change air filters on return vents seasonally. Use only filters with 'Minimum Efficiency Rating Value'(MERV) of 8

Central Domestic Hot Water Heater

- ✓ Never place gas fired water heaters adjacent to return vents so as to prevent flame roll outs
- ✗ Ensure the circulation system is on timer to reduce the losses through re-circulation
- ✓ Ensure all hot water pipes are insulated with fiberglass insulation at all times
- ✓ Replacement water heater should have Energy Factor (EF)>0.9
- ✓ Tank-type water heaters flushed monthly

**Lighting
Improvements**

- ✓ Utilize bi-level lighting controls in stairwells and hallways.
- ✓ Use LED replacement lamps
- ✓ Clean lighting fixture reflective surfaces and translucent covers.
- ✓ Ensure that timers and/or photocells are operating correctly on exterior lighting
- ✓ Use occupancy sensors for offices and other rooms with infrequent occupancy

Existing Equipment and Replacements

- ✓ Ensure that refrigerator and freezer doors close and seal correctly
- ✓ Ensure kitchen and bathroom exhaust outside the building and the internal damper operates properly
- ✓ Ensure that bathroom vents exhaust out
- ✓ Office/ computer equipment either in the “sleep” or “off” mode when not used

7. Appendices

APPENDIX A: Glossary of Terms

APPENDIX B: Mechanical Equipment Inventory

APPENDIX C: Lighting System Schedule

APPENDIX D: ECM Checklist

APPENDIX E: ECM Calculations

APPENDIX F: Solar PV

APPENDIX A: Glossary of Terms

Glossary of Terms and Acronyms

ECM – Energy Conservation Measures are projects recommended to reduce energy consumption. These can be No/Low cost items implemented as part of routine maintenance or Capital Cost items to be implemented as a capital improvement project.

Initial Investment – The estimated cost of implementing an ECM project. Estimates typically are based on R.S. Means Construction cost data and Industry Standards.

Annual Energy Savings – The reduction in energy consumption attributable to the implementation of a particular ECM. These savings values do not include the interactive effects of other ECMs.

Cost Savings – The expected reduction in utility or energy costs achieved through the corresponding reduction in energy consumption by implementation of an ECM.

Simple Payback Period – The number of years required for the cumulative value of energy or water cost savings less future non-fuel or non-water costs to equal the investment costs of the building energy or water system, without consideration of discount rates.

EUL – Expected Useful Life is the estimated lifespan of a typical piece of equipment based on industry accepted standards.

RUL – Remaining Useful Life is the EUL minus the effective age of the equipment and reflects the estimated number of operating years remaining for the item.

SIR - The savings-to-investment ratio is the ratio of the present value savings to the present value costs of an energy or water conservation measure. The numerator of the ratio is the present value of net savings in energy or water and non-fuel or non-water operation and maintenance costs attributable to the proposed energy or water conservation measure. The denominator of the ratio is the present value of the net increase in investment and replacement costs less salvage value attributable to the proposed energy or water conservation measure. It is recommended that energy-efficiency recommendations be based on a calculated SIR, with larger SIRs receiving a higher priority. A project typically is recommended only if the SIR is greater than or equal to 1.0, unless other factors outweigh the financial benefit.

Life Cycle Cost - The sum of the present values of (a) Investment costs, less salvage values at the end of the study period; (b) Non-fuel operation and maintenance costs; (c) Replacement costs less salvage costs of replaced building systems; and (d) Energy and/or water costs.

Life Cycle Savings – The sum of the estimated annual cost savings over the EUL of the recommended ECM, expressed in present value dollars.

Building Site Energy Use Intensity - The sum of the total site energy use in thousands of Btu per unit of gross building area. Site energy accounts for all energy consumed at the building location only not the energy consumed during generation and transmission of the energy to the site.

Building Source Energy Use Intensity – The sum of the total source energy use in thousands of Btu per unit of gross building area. Source energy is the energy consumed during generation and transmission in supplying the energy to your site.

Building Cost Intensity - This metric is the sum of all energy use costs in dollars per unit of gross building area.

Greenhouse Gas Emissions - Although there are numerous gases that are classified as contributors to the total for Greenhouse Emissions, the scope of this energy audit focuses on carbon dioxide (CO₂). Carbon dioxide enters the atmosphere through the burning of fossil fuels (oil, natural gas, and coal), solid waste, trees and wood products, and also as a result of other chemical reactions (e.g., manufacture of cement).

APPENDIX B: Mechanical Equipment Inventory

Mechanical Inventory								
System	Make	Model	Serial Number	Input Capacity	Output Capacity	Room Number	Space Served	Quantity
Central Split System Condensing Unit	Carrier	38CKC060570	1003E40928	5 TON	-	Roof	002 Classrooms 3-7	1
Central Split System Condensing Unit	Carrier	38CKC060570	4302E13804	5 TON	-	Roof	003 Classrooms 9-12	1
Central Split System Condensing Unit	Carrier	38CKC060570	4302E13801	5 TON	-	Roof	003 Classrooms 9-12	1
Central Split System Condensing Unit	Carrier	38CKC060570	0503E25332	5 TON	-	Roof	003 Classrooms 9-12	1
Central Split System Condensing Unit	Carrier	38CKCO24340	1603E10644	2 TON	-	Roof	003 Classrooms 9-12	1
Central Split System Condensing Unit	Carrier	38CKC060570	1003E40929	5 TON	-	Roof	003 Classrooms 9-12	1
Central Split System Condensing Unit	Carrier	38CKCO60570	4302E13813	5 TON	-	Roof	001 Main Building	1
Central Split System Condensing Unit	Carrier	38CKC060570	1603E18312	5 TON	-	Roof	002 Classrooms 3-7	1
Central Split System Condensing Unit	Carrier	38CKCO60570	1903E09393	5 TON	-	Roof	002 Classrooms 3-7	1
Central Split System Condensing Unit	Carrier	38CKC060570	1903E49711	5 TON	-	Roof	002 Classrooms 3-7	1
Central Split System Condensing Unit	Carrier	38CKC060570	1903E09417	5 TON	-	Roof	003 Classrooms 9-12	1
Central Split System Condensing Unit	Carrier	38CKC060570	1603E18306	5 TON	-	Roof	002 Classrooms 3-7	1
Central Split System Condensing Unit	Carrier	38CKC060570	1903E49714	5 TON	-	Roof	001 Main Building	1
Central Split System Condensing Unit	Carrier	38CKC060570	903E09419	5 TON	-	Roof	003 Classrooms 9-12	1
Central Split System Furnace	Carrier	ZI58DLX110---10122	S1903A42896	110 MBH	89 MBH	Utility closet - 1	001 Main Building	1
Central Split System Furnace	Carrier	ZI58DLX045---10108	S2803A27819	110 MBH	89 MBH	Utility closet - O020	003 Classrooms 9-12	1
Central Split System Furnace	Carrier	ZI58DLX110---10122	S2403A42819	110 MBH	89 MBH	Utility closet - 6	002 Classrooms 3-7	1
Central Split System Furnace	Carrier	ZI58DLX110---10122	S2403A42830	110 MBH	89 MBH	Utility closet - X008	003 Classrooms 9-12	1
Central Split System Furnace	Carrier	ZI58DLX110---10122	S1903A42903	110 MBH	89 MBH	Utility closet - O010	003 Classrooms 9-12	1
Central Split System Furnace	Carrier	ZI58DLX110---10122	S2403A42810	110 MBH	89 MBH	Utility closet - O009	003 Classrooms 9-12	1
Central Split System Furnace	Carrier	ZI58DLX110---10122	S2403A42823	110 MBH	89 MBH	Utility closet - O012	003 Classrooms 9-12	1
Central Split System Furnace	Carrier	ZI58DLX110---10122	S1903A42904	110 MBH	89 MBH	Utility closet - 4	002 Classrooms 3-7	1
Central Split System Furnace	Carrier	ZI58DLX110---10122	S2403A42833	110 MBH	89 MBH	Utility closet - 7	002 Classrooms 3-7	1
Central Split System Furnace	Carrier	ZI58DLX110---10122	S2403A42824	110 MBH	89 MBH	Utility closet - 2	001 Main Building	1
Central Split System Furnace	Carrier	ZI58DLX110---10122	5002A41452	110 MBH	89 MBH	Utility closet - 5	002 Classrooms 3-7	1
Central Split System Furnace	Carrier	ZI58DLX110---10122	0403A40217	110 MBH	89 MBH	Utility closet - X008	003 Classrooms 9-12	1
Central Split System Furnace	Carrier	ZI58DLX110---10122	S2403A42828	110 MBH	89 MBH	Utility closet - 3	002 Classrooms 3-7	1
Exhaust Fan	Greenheck	GB-071-4X- QD- R2	-	1000 CFM	-	Roof	001 Main Building	1
Exhaust Fan	PennBarry	DX13R	-	500 CFM	-	Roof	003 Classrooms 9-12	1
Exhaust Fan	Jenn-Aire	242CKA	-	1500 CFM	-	Roof - Kitchen	001 Main Building	1
Exhaust Fan	PennBarry	DX13R	-	500 CFM	-	Roof	002 Classrooms 3-7	1
Packaged Unit (RTU)	Trane	YCC060F3MOBE	M235PJ02H	125 MBH	100 MBH	Roof	001 Main Building	1
Packaged Unit (RTU)	AAON, Inc.	RK-16-2-E0-212: FOCED0E0H00S0X	200308-AKGM50937	270 MBH	219 MBH	Building exterior	001 Main Building	1
Packaged Unit (RTU)	Trane	YCC036F3LOBD	M215TJB1H	50 MBH	40 MBH	Roof - Kitchen	001 Main Building	1
Packaged Unit (RTU)	AAON, Inc.	Illegible	Illegible	270 MBH	219 MBH	Building exterior	001 Main Building	1
Wall Mounted Gas/ Electric Package Unit	Bard Manufacturing Company	WG422-ANBVX4XXX	253H031818614-1	75 MBH	59 MBH	Building Exterior - P-17	P08-P11 Classrooms P-12 to P-17	1
Wall Mounted Gas/ Electric Package Unit	Bard Manufacturing Company	WG422-ANBVX4XXX	253H031818613-1	75 MBH	59 MBH	Building Exterior - P-12	P08-P11 Classrooms P-12 to P-17	1

Wall Mounted Gas/ Electric Package Unit	Bard Manufacturing Company	WG422-ANBVX4XXX	253H031818659-1	75 MBH	59 MBH	Building Exterior - P-6	P03 Classrooms P-1 to P-7	1
Wall Mounted Gas/ Electric Package Unit	Bard Manufacturing Company	WG422-ANBVX4XXX	253H031818631-1	75 MBH	59 MBH	Building Exterior - P-4	P03 Classrooms P-1 to P-7	1
Wall Mounted Gas/ Electric Package Unit	Bard Manufacturing Company	WG422-ANBVX4XXX	253H031818638-1	75 MBH	59 MBH	Building Exterior - P-2	P03 Classrooms P-1 to P-7	1
Wall Mounted Gas/ Electric Package Unit	Bard Manufacturing Company	WG422-ANBVX4XXX	253H031818612-1	75 MBH	59 MBH	Building Exterior - P-3	P03 Classrooms P-1 to P-7	1
Wall Mounted Gas/ Electric Package Unit	Bard Manufacturing Company	WG422-ANBVX4XXX	253H031818654-1	75 MBH	59 MBH	Building Exterior - P-1	P03 Classrooms P-1 to P-7	1
Wall Mounted Gas/ Electric Package Unit	Bard Manufacturing Company	WG422-ANBVX4XXX	253H031818630-1	75 MBH	59 MBH	Building Exterior - P-5	P03 Classrooms P-1 to P-7	1
Wall Mounted Gas/ Electric Package Unit	Bard Manufacturing Company	WG422-ANBVX4XXX	253H031818618-1	75 MBH	59 MBH	Building exterior	P01 Classroom K-3	1
Wall Mounted Gas/ Electric Package Unit	Bard Manufacturing Company	WG422-ANBX4XXX	253H031818620-1	75 MBH	59 MBH	Building exterior	P02 Classroom P-18	1
Wall Mounted Heat Pump	Bard Manufacturing Company	WH431-A0ZCX4XXB WMCB-08A	176L981277076-02	3.5 TON	-	Building Exterior - P-16	P08-P11 Classrooms P-12 to P-17	1
Wall Mounted Heat Pump	Bard Manufacturing Company	WH431-A0ZCX4XXB WMCB-08A	176L981277073-02	3.5 TON	-	Building Exterior - P-15	P08-P11 Classrooms P-12 to P-17	1
Wall Mounted Heat Pump	Bard Manufacturing Company	WH431-A0ZCX4XXX WMCB-08A	176D991339423-02	3.5 TON	-	Building Exterior - P-14	P08-P11 Classrooms P-12 to P-17	1
Wall Mounted Heat Pump	Bard Manufacturing Company	WH431-A0ZCX4XXX WMCB-08A	176D991339427-02	3.5 TON	-	Building Exterior - P-13	P08-P11 Classrooms P-12 to P-17	1
Wall Mounted Heat Pump	Bard Manufacturing Company	36WH7-A05C	058M890621370	3 TON	-	Building Exterior - P-10	P04-P07 Classrooms P-08 to P-11	1
Wall Mounted Heat Pump	Bard Manufacturing Company	36WH7-A05C	058M890621372	3 TON	-	Building Exterior - P-11	P04-P07 Classrooms P-08 to P-11	1
Wall Mounted Heat Pump	Bard Manufacturing Company	36WH7-A05C	058N890626335	3 TON	-	Building Exterior - P-7	P03 Classrooms P-1 to P-7	1
Wall Mounted Heat Pump	Bard Manufacturing Company	Illegible	Illegible	3 TON	-	Building Exterior - P-8	P04-P07 Classrooms P-08 to P-11	1

Wall Mounted Heat Pump	Bard Manufacturing Company	Illegible	Illegible	3 TON	-	Building Exterior - P-9	P04-P07 Classrooms P-08 to P-11	1
Water Heater	Rheem	81VP6S	RH 0304213491	6 GAL, 2kW	-	Under Sink	P01 Classroom K-3	1
Water Heater	Rheem	22V30-30F	RHLN 0204V05801	30 GAL, 30 MBH	-	Electrical room	003 Classrooms 9-12	1

APPENDIX C: Lighting System Schedule



Line No.	Building Name	Interior/ Exterior	Floor	Space Type	Room No.	Additional Area Description	LUX	Control Quantity	Existing Control	Lamp Details				Fixture Details			Existing Consumption		
										Technology	Sub-Technology	Lamp Type	Total Lamps	Fixture Type	Fixture Quantity	24x7 Fixture Count	Fixture Height	Annual Hours	Existing Annual kWh
1	Nicholas Elementary School	Interior	1	CLASSROOM	2000 Portables	18 dual only swit	730	28	Light Switch	Linear Fluorescent	T8	4' 32W T8	756	2x4 Prism Troffer	252	0	8	2,160	52,255
2	Nicholas Elementary School	Interior		CLASSROOM	1991 Portables	and 6 lamp 2 bu	150	10	Light Switch	Linear Fluorescent	T8	4' 32W T8	60	2x4 Prism Troffer	30	0	8	2,160	4,147
3	Nicholas Elementary School	Interior		CLASSROOM	1991 Portables	and 6 lamp 2 bu	150	10	Light Switch	Linear Fluorescent	T8	4' 32W T8	70	2x4 Prism Troffer	35	0	8	2,160	4,838
4	Nicholas Elementary School	Interior		ESTROOM - PRIVAT	P12		600	1	Light Switch	Linear Fluorescent	T8	4' 32W T8	4	2x4 Prism Troffer	2	0	8	900	115
5	Nicholas Elementary School	Interior		ESTROOM - PRIVAT	P12		600	1	Light Switch	Linear Fluorescent	T8	4' 32W T8	6	2x4 Prism Troffer	3	0	8	900	173
6	Nicholas Elementary School	Interior		ESTROOM - PRIVAT	P12		600	1	Light Switch	Linear Fluorescent	T8	4' 32W T8	6	2x4 Prism Troffer	3	0	8	900	173
7	Nicholas Elementary School	Interior		CLASSROOM	003		320	16	Light Switch	Linear Fluorescent	T8	4' 32W T8	144	2x4 Prism Troffer	48	0	12	2,160	9,953
8	Nicholas Elementary School	Interior		STORAGE	003	003 storage 1f	150	5	Light Switch	Linear Fluorescent	T8	4' 32W T8	10	2x4 Prism Troffer	5	0	12	684	219
9	Nicholas Elementary School	Interior		CLASSROOM	003 library	Library	460	4	Light Switch	Linear Fluorescent	T8	4' 32W T8	36	2x4 Prism Troffer	12	0	12	2,160	2,488
10	Nicholas Elementary School	Interior		CLASSROOM	003 library	Library	460	4	Light Switch	Linear Fluorescent	T8	4' 32W T8	27	2x4 Prism Troffer	9	0	12	2,160	1,866
11	Nicholas Elementary School	Interior		KITCHEN	001 KITCHEN		280	5	Light Switch	Linear Fluorescent	T8	4' 32W T8	4	2x4 Prism Troffer	2	0	8	1,800	230
12	Nicholas Elementary School	Interior		KITCHEN	001 KITCHEN		280	5	Light Switch	Linear Fluorescent	T8	4' 32W T8	22	2x4 Prism Troffer	11	0	8	1,800	1,267
13	Nicholas Elementary School	Interior		KITCHEN	001 KITCHEN		280	5	Light Switch	Linear Fluorescent	T8	4' 32W T8	2	2x4 Prism Troffer	1	0	8	1,800	115
14	Nicholas Elementary School	Interior		KITCHEN	001 KITCHEN		280	5	Light Switch	Linear Fluorescent	T8	4' 32W T8	12	2x4 Prism Troffer	4	0	8	1,800	691
15	Nicholas Elementary School	Interior		KITCHEN	001 KITCHEN		280	5	Light Switch	Linear Fluorescent	T8	4' 32W T8	6	2x4 Prism Troffer	2	0	8	1,800	346
16	Nicholas Elementary School	Interior		CLASSROOM	001 multipurpose	Multipurpose	480	2	Light Switch	Linear Fluorescent	T8	4' 32W T8	54	2x4 Prism Troffer	18	0	15	2,160	3,732
17	Nicholas Elementary School	Interior		CLASSROOM	001 multipurpose	Multipurpose	480	2	Light Switch	Linear Fluorescent	T8	4' 32W T8	54	2x4 Prism Troffer	18	0	15	2,160	3,732
18	Nicholas Elementary School	Interior		CLASSROOM	001-3	Kindergarten	380	15	Light Switch	CFL	CFL - Screw-in	CFL18	6	Surface Mount Can	6	0	8	2,160	233
19	Nicholas Elementary School	Interior		CLASSROOM	001-3	Kindergarten	380	15	Light Switch	Linear Fluorescent	T8	4' 32W T8	108	2x4 Prism Troffer	36	0	11	2,160	7,465
20	Nicholas Elementary School	Interior		CLASSROOM	001-3	Kindergarten	380	15	Light Switch	CFL	CFL - Screw-in	CFL18	3	Surface Mount Can	3	0	12	2,160	117
21	Nicholas Elementary School	Interior		CLASSROOM	001-3	Kindergarten	380	15	Light Switch	CFL	CFL - Screw-in	CFL18	3	Surface Mount Can	3	0	12	2,160	117
22	Nicholas Elementary School	Interior		OFFICE	001 lobby		500	7	Light Switch	Linear Fluorescent	T8	4' 32W T8	24	2x4 Prism Troffer	6	0	12	2,160	1,659
23	Nicholas Elementary School	Interior		OFFICE	001 lobby		500	7	Light Switch	Linear Fluorescent	T8	4' 32W T8	8	2x4 Prism Troffer	2	0	12	2,160	553
24	Nicholas Elementary School	Interior		OFFICE	001 lobby		500	7	Light Switch	Linear Fluorescent	T8	4' 32W T8	8	2x4 Prism Troffer	2	0	8	2,160	553
25	Nicholas Elementary School	Interior		OFFICE	001 lobby		500	7	Light Switch	Linear Fluorescent	T8	4' 32W T8	20	2x4 Prism Troffer	5	0	8	2,160	1,382
26	Nicholas Elementary School	Interior		OFFICE	001 lobby		500	7	Light Switch	Linear Fluorescent	T8	4' 32W T8	12	2x4 Prism Troffer	4	0	8	2,160	829
27	Nicholas Elementary School	Interior		OFFICE	001 lobby		500	7	Light Switch	Linear Fluorescent	T8	4' 32W T8	8	2x4 Prism Troffer	2	0	8	2,160	553
28	Nicholas Elementary School	Interior		OFFICE	001 lobby		500	7	Light Switch	Linear Fluorescent	T8	4' 32W T8	6	Industrial	3	0	8	2,160	415
Totals													1,479	527			53,424	100,218	

APPENDIX D: ECM Checklist

NA	In Place	Evaluate	ECM Description
✓			Add Reflective Coating To Exterior Windows
		✓	Replace External Windows
	✓		Upgrade Insulation
	✓		Control External Air Leakage In Commercial Buildings
✓			Install Reflective Insulation Between Radiators And External Wall
✓			Replace Existing Motors With High Efficiency Motors
✓			Install On-Demand Ventilation on Air Handlers
		✓	Reduce HVAC Hours of Operation
✓			Install Variable Frequency Drives (VFD)
✓			Install Outside Air Temperature Reset Controls For Hot Water Boilers
✓			Install Chilled Water Reset Control
		✓	Install Timers On Exhaust Fans
✓			Install Energy Savers on Vending, Snack Machines
		✓	Install Building Energy Management System and Replace Terminal Units
		✓	Re-Commission The Building & Its Control Systems
✓			Replace Inefficient Heating Plant
✓			Replace Inefficient Cooling Plant
	✓		Replace Existing Air Conditioners with Energy Star Air Conditioners
✓			Replace Unit Electric Heaters with Natural Gas Fired Unit Heaters
	✓		Convert From Gas Pilot to Electronic Ignition for Boilers
✓			Insulate Hot Water Pipes
	✓		Insulate Refrigerant Lines
	✓		Insulate Hot Surfaces And Tanks
	✓		Insulate Air Ducts
✓			Replace Defective Steam Traps
✓			Upgrade Electric Heating System To Heat Pumps
	✓		Replace Inefficient Furnace System
✓			Replace Rooftop Package Unit
	✓		Install Energy Recovery Wheel on Air Handling Unit
		✓	Replace Existing Water Heater With New Energy Efficient Units
✓			Replace Incandescent/Halogen Lamps With Energy Efficient Lamps
✓			Upgrade Inefficient Linear Fluorescent Lamps And Fixtures
✓			Upgrade EXIT SIGNS With LED EXIT Signs
✓			Bilevel and Tandem Linear Fluorescent Lighting ECM
		✓	Replace High Intensity Discharge (HID) Lamps With Energy Efficient Lamps
✓			Replace Existing Refrigerator(s) With Energy Star Certified Refrigerator(s)
	✓		Replace Existing Freezers With High Efficiency Freezers
✓			Install Low Flow Shower Heads
		✓	Install Low Flow Faucet Aerators
		✓	Install Low Flow Restroom Flush Tank Toilets
		✓	Install Low Flow Tankless Restroom Fixtures

APPENDIX F: ECM Calculations

UIC		Install Low Flow Faucet Aerators	
EAP2-b	Location: Restrooms and Classrooms		
Property Type:	Commercial	Estimated No. of Operational Weeks	36
		Number of Occupied Days/Week (Max 7)	5
KITCHEN FAUCETS		BATHROOM FAUCETS	
Number of Occupants Affected By Retrofit	800	Number of Occupants Affected by Retrofit	800
Do You Want To Replace Kitchen Faucets Aerators	Yes (Select)	Do You Want To Replace Bathroom Faucets Aerators	Yes (Select)
Total Number of Faucet Aerators To Be Replaced	32	Total Number of Faucet Aerators To Be Replaced	4
Total Number of Faucets To Be Replaced:	0	Total Number of Faucets To Be Replaced:	0
GPM of Existing Faucet Aerators	2.2 GPM	GPM of Existing Faucet Aerators	2.2 GPM
GPM of Proposed Faucet Aerator	0.5 GPM	GPM of Proposed Faucet Aerator	0.5 GPM
Estimated Number of Uses Per Day	2	Estimated Number of Uses Per Day	4
Annual Water Savings From Installing Low Flow Aerators:	141.00 kGal		
WATER & ENERGY SAVING CALCULATION		COST SAVING CALCULATION	
Select Type of Water Heater Fuel:	Natural Gas (Select)	Property Location in United States	North Central Localities
Energy Factor of Domestic Hot Water Heater:	0.70 EF	Heating Fuel Tariff	\$1.32 \$/Therm
Hot Water Discharge Temperature at Faucet	110.00 °F	Water Tariff (\$/1000 Gal)	\$34.86 \$/kGal
Equivalent Heating Fuel Savings: <small>Savings Discounted by 15% to Account For Cold Water Use</small>	857 Therms	Annual Cost Savings In Form of Water	\$4,915 \$
Annual Water Savings	141.00 kGal	Annual Energy Savings From Water Heater	\$1,132 \$
COST BENEFIT ANALYSIS			
Estimated Total Annual Cost Savings	\$6,047 \$\$	Estimated Total Installation Cost	\$548 \$\$
Simple Payback Period	0.09 Years	Type of Recommendation	No/Low Cost ECM Recommendation

Disclaimer: PREPARED BY EMG. May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM EXPLANATION:

By reducing the flow of water coming from the restroom faucets, aerators can generate energy savings at low cost and with easy installation. The savings generated would be in the form of reduced water and sewer costs and at the same time aerators would save energy by reducing the demand for hot water. The average faucet has a flow rate of about 2 to 4 GPM. Adding a screw-in faucet aerator reduces the flow to 0.5 to 1.5 GPM in the bathroom and 2.2 GPM in the kitchen. In addition to saving energy and water, the "foamier" water that comes from faucet aerators wets objects better than water from a faucet with no aerator, which tends to bounce off the object rather than thoroughly wetting it.

EMG recommends replacing the proposed faucet aerators with new low flow aerators as mentioned above. The proposed ECM shall also result in an annual energy saving in form of reduction in water heating bills.

Summary:

Initial Investment: \$548 Estimated Annual Cost Savings: \$6,047 Simple Payback Period (Yrs): 0.09

UIC	Install Timers On Exhaust Fans			
EAC7A	Location: Throughout			
Type of Exhaust Fan:		Rooftop Exhaust Fans		
EXISTING CONDITION				
No. of Timers to Be Installed:	3	Qty	HP of Individual Fan Motor:	0.25 HP
No. of Exhaust Fans:	8		Total kW:	1.49 kW
Existing Daily Hours of Operation/Exhaust Fan:	15.00	Hrs/Day	Annual kWh For All Fans:	8,169 kWh
PROPOSED CONDITION				
New Daily Hours With Timers/Exhaust Fan:	12.00	Hrs/Day	New Annual kWh For All Fans:	6,535 kWh
Type of Heating Fuel:	Natural Gas		Is The Property Cooled?	Yes
Only For Apt. Bathroom Exhaust Fans		Only For Roof Top Exhaust Fans- Commerical Spaces		
CFM for Individual Bathroom Exhaust Fans <i>(For bathrooms < 100 Sqft)</i>	90	CFM	No. of Water Closets In Building	44
Total Exhaust CFM From All Fans	720	CFM	No. of Urinals In Building	21
Annual Heating Energy Savings	0	kbtu	Total CFM for All Restroom Exhaust	3,250 CFM
Annual Cooling Energy Savings	0	kbtu	Annual Heating Energy Savings	42,120 kbtu
			Annual Cooling Energy Savings	21,060 kbtu
Energy & Cost Savings				
Estimated Annual Heating Plant Efficiency	79.00	%	Estimated Annual Cooling Plant Efficiency	7.00 EER
Annual Heating Energy Savings	533	Therms	Annual Cooling Energy Savings	3,009 kWh
Annual Electric Fan Motor Savings	1,634	kWh		
COST ANALYSIS				
Electric Rate:	\$0.19	\$/kWh	Total Annual Electric Savings	4,642 kWh
Material Cost For Timers:	\$508	\$	Total Annual Non Electric Savings	533 Therms
Total Cost for Installing Timers	\$1,062	\$	Annual Cost savings:	\$1,564 \$
Simple Payback:	0.68	Yrs		
Type of Recommendation	Capital Cost ECM Recommendation			

Disclaimer: PREPARED BY EMG. May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG Corp. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM DESCRIPTION:

Exhaust fans are generally used in areas with high concentrations of pollutants generated from occupants' activities. These exhaust requirements are rarely continuous, and the fans should operate only as needed. Continuous operations of bathroom exhaust fans results in exhausting conditioned air out. This causes low pressures in the conditioned space, which is filled up by infiltrated air from unconditioned spaces. Air infiltration leads to increase loads on heating and cooling system increasing the energy consumed to condition the space. In addition to this the fan motor is also consumes energy to operate, though insignificant as compared to the HVAC losses.

In case of the residential properties with individual exhaust fans in the bathrooms, EMG recommends installing timer switches on each bathroom fan to control the fan operations. Bathroom fans are essential to exhaust out the excess humidity and odor control. The timer switch will limit the operation time to 20 mins.

In case of central exhaust systems that have roof top or side wall mounted exhaust fans, EMG recommends a single electronic timer control to restrict the exhaust fan operations to typical building occupancy hours +/- 2 hrs. A single electronic timer would be able to control all the exhaust fans.

Summary:

Initial Investment:	\$508	Simple Payback:	0.68	Years
Energy Cost Savings:	\$1,564			

<i>UIC</i>	Reduce HVAC Hours of Operation
EAC3	Location: Throughout

No of Programmable Thermostats To Be Installed : Qty.

Select Type of Programmable Thermostat Recommended: (Select)
(Selection Based on Type of Property)

Heating Load Calculation			Cooling Load Calculation		
Select Type of Heating Fuel	<input type="text" value="Natural Gas"/> <small>(Select)</small>		Select Type of Cooling Fuel	<input type="text" value="Electric"/> <small>(Default)</small>	
Estimated Current Annual Energy Consumption For Winter Heating	<input type="text" value="3,114"/> Therms		Estimated Current Annual Energy Consumption For Summer Cooling	<input type="text" value="42,481"/> kWh	
	Weekdays	Weekends		Weekdays	Weekends
Day Time Set Back Hours	<input type="text" value="6.00"/>	<input type="text" value="6.00"/>	Day Time Set Back Hours	<input type="text" value="6.00"/>	<input type="text" value="6.00"/>
Night Time Set Back Hours	<input type="text" value="8.00"/>	<input type="text" value="8.00"/>	Night Time Set Back Hours	<input type="text" value="8.00"/>	<input type="text" value="8.00"/>
Hours Without Set Back	<input type="text" value="10.00"/>	<input type="text" value="10.00"/>	Hours Without Set Back	<input type="text" value="10.00"/>	<input type="text" value="10.00"/>
Typical Indoor Temp	<input type="text" value="69.00"/> °F		Typical Indoor Temp	<input type="text" value="73.00"/> °F	
Temp Set Point With Set Back During Day Time	<input type="text" value="53.00"/> °F		Temp Set Point With Set Back During Day Time	<input type="text" value="93.00"/> °F	
Temp Set Point With Set Back During Night Time	<input type="text" value="65.00"/> °F		Temp Set Point With Set Back During Night Time	<input type="text" value="78.00"/> °F	
Average Heating Set Point	<input type="text" value="63.67"/> °F		Average Cooling Set Point	<input type="text" value="79.67"/> °F	
Savings Per Degree Set Back For Heating Season <small>(Industry Standard, 2004)</small>	<input type="text" value="3%"/>		Savings Per Degree Set Back For Cooling Season <small>(Industry Standard, 2004)</small>	<input type="text" value="6%"/>	
Estimated Annual Heating Energy Consumption	<input type="text" value="311,400"/> kBtu		Estimated Annual Cooling Energy Consumption	<input type="text" value="144,945"/> kBtu	
Estimated New Annual Heating Energy Consumption	<input type="text" value="261,576"/> kBtu		Estimated New Annual Cooling Energy Consumption	<input type="text" value="86,967"/> kbtu	
Estimated Annual Heating Energy Savings	<input type="text" value="498"/> Therms		Estimated Annual Cooling Energy Savings	<input type="text" value="16,992"/> kWh	

Cost Analysis					
Average Annual Cost of Heating Fuel:	<input type="text" value="\$1.32"/>	\$/Therm	Estimated Installation Cost Per Thermostats:	<input type="text" value="\$1,070"/>	\$\$
			<small>(Includes Material, Labor & Installation Costs)</small>		
Average Annual Cost of Electricity:	<input type="text" value="\$0.19"/>	\$/kWh	Total Estimated Cost For All Programmable Thermostats	<input type="text" value="\$12,776"/>	\$\$
Estimated Annual Heating Cost Savings:	<input type="text" value="\$658"/>	\$\$	Total Estimated Cost Savings From All Programmable Thermostats	<input type="text" value="\$3,805"/>	
Estimated Annual Cooling Cost Savings:	<input type="text" value="\$3,147"/>	\$\$	Estimated Simple Pay Back Period	<input type="text" value="3.36"/>	Yrs
<i>Type of Recommendation</i>	<input type="text" value="Capital Cost ECM Recommendation"/>				

Disclaimer: PREPARED BY EMG, May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM DESCRIPTION:

Turning off energy-consuming systems when they are not needed is the most basic energy conservation technique. When a building is occupied intermittently, energy savings can be realized by minimizing the time the heating or cooling system is operated when the building is closed. Building control algorithms should be implemented to delay startup until the last moment and to shut down as early as possible. Because of the thermal inertia of both the building structure and its heating and cooling equipment, preheat or precool time is almost always required to raise or lower the space temperature to the desired level before the occupants return. This start-up time depends on the outdoor environment, the thermal response of the building, and the thermal performance of the space conditioning equipment. Similarly, the thermal inertia of the building maintains the indoor temperature at a comfortable level for a short period of time after the equipment is shut off. It allows the system to be turned off before the end of an occupied period. An optimum start/stop control accounts for these factors.

SUMMARY

Initial Investment: \$12,776 Simple Payback Period: 3.36 Yrs
 Annual Energy Cost Saving: \$3,805

UIC		Replace Existing Water Heater With New Energy Efficient Units			
EAD3		Location: P01			
Step 1	Existing Water Heater Details	P01 - Under Sink	003 Electrical Room (not ECM)	Specify Location Here	Specify Location Here
	Number of Water Heaters Being Replaced:	1	0		
	Select Existing Hot Water Heater Fuel	Electric	Natural Gas	Natural Gas	Electric
	Insert Energy Factor of Existing Water Heater	0.77 EF	0.70 EF		
	Input Existing Water Heater Input Rating	2.00 kW	30.00 kBtus		
	Select One Method For Calculation	Annual DWH Load	Annual DWH Load	Annual DWH Load	Annual DWH Load
	Insert Annual Water Heater Energy Consumption/Heater	6,404 kWh	523 Therms		
	Annual Hours of Operation	3,202 hrs	1,743 hrs	#DIV/0! hrs	#DIV/0! hrs
	Total Estimated Annual Energy Consumption For all Heaters	6,404 kWh	0 Therms	0 Therms	0 kWh
	Total Estimated Annual Operating Energy Costs For all Heaters	\$1,186 \$	\$0 \$	\$0 \$	\$0 \$
Step 2	Proposed New Water Heater				
	Proposed Hot Water Heater Fuel	Electric	Natural Gas	Electric	Natural Gas
	Capacity of the Proposed New Water Heater	10-Gal,1.6-kW	29-Gal,40-kBtu		
	Energy Factor of Proposed Water Heater	0.89 EF	0.61 EF	0.00 EF	0.00 EF
	Proposed Water Heater Input Rating	1.60 kW	40.00 kBtu/h	0.00 kW	0.00 kBtu/h
	Annual kBtu/h Consumption For All The Proposed Water Heaters	18,904 kBtu/h	0 kBtu/h	#DIV/0! kBtu/h	#DIV/0! kBtu/h
	Estimated Annual Water Heater Fuel Consumption (All Heaters)	5,541 kWh	0 Therms	0 kWh	0 Therms
	Estimated Total Annual Energy Costs	\$1,026 \$	\$0 \$	\$0 \$	\$0 \$
Step 3	Energy & Cost Saving Calculation				
	Estimated Cost of New Water Heater/Unit	\$672 \$	\$1,029 \$	\$0 \$	\$0 \$
	Total Estimated Installation Cost	\$1,002 \$	\$0 \$	\$0 \$	\$0 \$
	Total Estimated Annual Cost Savings	\$160 \$	\$0 \$	\$0 \$	\$0 \$
	Total Annual Cost Savings:	\$160	Total Initial Investment::	\$1,002	
	Simple Pay Back Period	6.27			
	Type of Recommendation	Capital Cost ECM Recommendation			

Disclaimer: PREPARED BY EMG. DECEMBER 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM SUMMARY:

Electric resistance is the most expensive method for heating domestic hot water. A natural gas or propane fired water system provide more units of heat with direct burning of fuel while high wattage draw is required for electric water heaters to create resistance heat. This electric usage can be seen with the increase power demand for the site and the additional kWh consumption. The installation process of the gas/propane fired water heater requires additional measures with tying a gas line or fuel tank to the system along with installing an exhaust gas vent. This process is not a costly retrofit if a current gas line or tank is at the site. The hot water exhaust duct can be tied to the existing gas fired furnaces or boilers for an easy retrofit.

SUMMARY:

Initial Investment: \$1,002 Simple Payback: 6.27 yrs
Annual Cost Savings: \$160

UIC	Upgrade Building Lighting to LED and Install Automatic Lighting Controls
EAL10	Location: Building Interior and Exterior

	No. of ECMs	No. of Fixtures	No. of Lamps	KWh Saved	Energy Cost Saving	O & M Savings
Upgrade Lighting to LED	28	527	1,479	46,940	\$8,692.31	\$5,766.76

Existing Technology	Sub-Technology	No. of ECMs	No. of Fixtures	No. of Lamps	KWh Saved	Energy Cost Saving	O & M Savings
CFL	CFL - 2 Pin	0	0	0	0	\$0	\$0
CFL	CFL - 4 Pin	0	0	0	0	\$0	\$0
CFL	CFL - Screw-in	3	12	12	181	\$34	\$2,017
Circline	T9	0	0	0	0	\$0	\$0
Incan/H/MR	H	0	0	0	0	\$0	\$0
Incan/H/MR	Incan	0	0	0	0	\$0	\$0
Incan/H/MR	MR	0	0	0	0	\$0	\$0
HID	HPS	0	0	0	0	\$0	\$0
HID	MH	0	0	0	0	\$0	\$0
HID	MV	0	0	0	0	\$0	\$0
HID	QL	0	0	0	0	\$0	\$0
Linear Fluorescent	T8	25	515	515	46,759	\$8,659	\$3,750
Linear Fluorescent	T12	0	0	0	0	\$0	\$0
Linear Fluorescent	T8 U	0	0	0	0	\$0	\$0
Linear Fluorescent	T12 U	0	0	0	0	\$0	\$0
Linear Fluorescent	T5	0	0	0	0	\$0	\$0
Linear Fluorescent	T6	0	0	0	0	\$0	\$0
Linear Fluorescent	T10	0	0	0	0	\$0	\$0

Proposed Controls	No. of Controls	No. of Controls
Photo Sensor	0	Ceiling Mounted
Wall Mounted	0	218

Initial Investment		Equipment Rentals	
Material Cost	\$35,322.00	Scissor Lift 26' - Interior Space	\$0.00
Labor Cost	\$60,310.11	Bucket Truck - Exterior Space:	\$0.00
Local Electric Rate:	\$0.17 /kWh	Estimated Annual Energy Savings:	46,940
Hourly Labor Rate For Electrician:	\$72.40	Estimated Annual Energy Cost Savings:	\$8,692
Budgeted Initial Investment:	\$95,632	Estimated Annual O&M Cost Savings:	\$5,767
Estimated Return on Investment:	6.61 Years	Estimated Annual Cost Savings:	\$14,459

(Including O&M Savings)

<i>UIC</i>	Re-Commission The Building & Its Control Systems	
EAC10	Location: Throughout	
Enter the Total Area of The Facility	43,474	SqFt
Select the Type of Heating Fuel:	Natural Gas	<i>(Select)</i>
Estimated Annual Heating Fuel Consumption:	3,114	Therms
Is the Property Cooled?	Yes	<i>(Select)</i>
Estimated Annual Electrical Energy Consumed For Cooling:	42,481	kWh
Estimated Energy Savings From Re-Commissioning on Building Systems:	15%	<i>(Select)</i>
Estimated Heating Energy Saving Post Re-Commissioning:	467	Therms
Estimated Cooling Energy Saving Post Re-Commissioning:	6,372	kWh
Average Heating Fuel Rate Paid By The Property:	\$1.32	\$/Therm
Average Electrical Rate Paid By The Property:	\$0.19	\$/kWh
Annual Energy Cost Savings:	\$1,797	\$
Estimated Cost For Re-Commissioning The Facility: <i>(LBNL 2009 Report on Building Commissioning)</i>	\$19,466	\$
Simple Payback Period:	10.83	Yrs
<i>Type of Recommendation</i>	Capital Cost ECM Recommendation	

Disclaimer: PREPARED BY EMG.May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM DESCRIPTION

The goal of commissioning of a facility is to ensure that the equipments in the facility are performing as per the desired standards or as per design standards. The role of commissioning in existing buildings is to identify the almost inevitable "drift" from where things should be and puts the things back on track. Based on the LBNL 2009 Report on Building Commissioning the average re-commissioning of existing buildings yielded atleast 16% of energy savings across the facility. This average has been developed based on over 643 buildings that were commissioned across United States in different climatic zones.

Thus EMG strongly recommends re-commissioning of all existing buildings in order to ensure that all the sensors, equipments and control systems are working as per the design conditions.

SUMMARY:

Initial Investment:	\$19,466	Simple Payback:	10.83	Years
Energy Cost Savings:	\$1,797			

UIC	Install Low Flow Restroom Flush Tank Toilets	
EAP3	Location: Restrooms and Locker Rooms	
EXISTING CONDITION		
Total Occupants:	<input type="text" value="800"/>	
Number of Water Closets To Be Replaced	<input type="text" value="2"/>	
Number of Occupied Days Per Week (Max 7)	<input type="text" value="5"/>	
Number of Occupied Weeks/Year (Max 52)	<input type="text" value="36"/>	
Estimated Restroom Usage/Individual/Day	<input type="text" value="4"/>	(Select)
<small>5.05 flushes/person/day@American Water Works Association (AWWA)</small>		
PROPOSED RETROFIT/REPLACEMENT		
Existing Gallons Per Flush Ratings For Water Closet Flushes	<input type="text" value="1.60"/>	GPF
Replace or Retrofit Toilets With Dual Flush Toilets	<input type="text" value="Replace"/>	
Replace		
Proposed Toilet	<input rough-in"="" type="text" value="0.8GPF -Floor Mount, 10"/>	
GPF of Proposed New Low Flow Water Closet Fixture*	<input type="text" value="0.80"/>	GPF
Retrofit		
Dual Flush - Retrofit Setup Valve for Flush Tank Toilet	<i>Solid Waste (20%)</i> <input type="text" value="0.80"/>	GPF
<small>*(Federal Law Requires All Flushes Not To Exceed 1.6 GPF)</small>	<i>Liquid Waste (80%)</i> <input type="text" value="0.80"/>	GPF
Water & Cost Saving Calculations		
Water Savings By The Use of Low Flow Water Closet Flush Valves/Day	<input type="text" value="2,560.00"/>	gal
Total Annual Water Savings in gallons	<input type="text" value="460.80"/>	kgal
Cost Savings Calculations		
Enter Water Tariff Rate (\$/1000Gal)	<input type="text" value="\$34.86"/>	\$\$
Estimated Cost Savings From Water	<input type="text" value="\$16,063"/>	\$\$
Estimated Cost of Retrofit		
Estimated Total Cost For Retrofit	<input type="text" value="\$1,897"/>	\$\$
Simple Pay Back Period	<input type="text" value="0.12"/>	Yrs
Type of Recommendation	<input type="text" value="Capital Cost ECM Recommendation"/>	

Disclaimer: PREPARED BY EMG. May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM EXPLANATION:

The highest water utilization at any home/office occurs in the restrooms. It is estimated that on an average a normal human being uses the restroom at least four times a day. Keeping with the global water conservation objectives, federal law prohibits use of any new water closet flushes over 1.6 GPF.

Existing toilets can be retrofitted with pressure-assisted flush technology to reduce the flush rate to 1.0 GPF or less. Though water efficient these toilets make considerable amount of noise as this involves release of pressurized air during the course of flushing. Thus making them unpopular among residential properties.

Thus EMG recommends replacing the existing high flow toilets with new low flow 1.28GPF rated flush tank toilets, which are comparatively more water efficient at the same time considerably quieter as compared to the pressure assisted technology retrofitted toilets.

Summary:

Initial Investment: \$1,897
Simple Payback: 0.12 Years
Annual Cost Savings \$16,063

	<i>UIC</i>	Replace External Windows
	<i>EAE2</i>	Location: Throughout

ENTER EXISTING CONDITIONS

Existing and Proposed Window Properties	Existing & Proposed Air Leakage Through Windows
Total Sq.Ft window area: <input style="width: 100px;" type="text" value="4,416"/> sq.ft	Insert Existing Estimated Air Change Rate/Hr (ACH 1): <input style="width: 100px;" type="text" value="1.00"/> <small>(Existing Air Changes Per Hour, 1.5 is very leaky and 0.35 ideal)</small>
Approximate number of windows: <input style="width: 100px;" type="text" value="274"/>	Insert Proposed Estimated Air Change Rate/Hr (ACH 2): <input style="width: 100px;" type="text" value="0.70"/>
Total existing window area: <input style="width: 100px;" type="text" value="4,416"/> Sq.Ft	Estimated Space Volume Under Consideration: <input style="width: 100px;" type="text" value="391,266.00"/> Cu. Ft
Select The Existing Window Type: <input style="width: 150px;" type="text" value="Metal Frame & Single Glazing"/> <small>(Select)</small>	
Existing U-value of window: (1/R) <input style="width: 100px;" type="text" value="1.31"/> Btu/ ft ² ·°F·h	
ASHRAE Climatic Zone: <input style="width: 100px;" type="text" value="Zone-3"/>	Is the Property Cooled?: <input style="width: 100px;" type="text" value="Yes"/> <small>(Select)</small>
New U-value with Double pane Low E window: (1/R) <input style="width: 100px;" type="text" value="0.35"/> Btu/ ft ² ·°F·h <small>AHRAE 90.1 Recommended Value</small>	

WINTER	SUMMER
Select Type of Heating Fuel: <input style="width: 150px;" type="text" value="Natural Gas"/> <small>(Select)</small>	Select Type of Cooling Fuel: <input style="width: 150px;" type="text" value="Electric"/> <small>(Default)</small>
Net heating plant & distribution system efficiency: <input style="width: 100px;" type="text" value="79.00"/> %	Cooling Plant Efficiency (EER): <input style="width: 100px;" type="text" value="7.00"/> EER
Annual Heating Hours: <input style="width: 100px;" type="text" value="2,943"/> HDD	Annual Cooling Hours: <input style="width: 100px;" type="text" value="1,407"/> CDD
Estimated Total Annual Input Heating Energy Savings By Replacing Windows: <input style="width: 100px;" type="text" value="37.90"/> Therms	Annual Total Input Cooling Fuel Savings During Summer Season By Replacing Windows: <input style="width: 100px;" type="text" value="20,451"/> kWh
Estimated Total Annual Input Heating Energy Savings Achieved By Controlling Air Leakage Through Windows: <input style="width: 100px;" type="text" value="1,889"/> Therms	Estimated Total Annual Input Cooling Energy Savings Achieved By Controlling Air Leakage Through Windows: <input style="width: 100px;" type="text" value="10,192"/> kWh
Estimated Total Input Heating Fuel Savings From Replacing Windows: <input style="width: 100px;" type="text" value="1,927"/> Therms	Estimated Total Input Cooling Fuel Savings From Replacing Windows: <input style="width: 100px;" type="text" value="30,643"/> kWh

ENERGY & COST ANALYSIS			
Insert Cost of Heating Fuel: <input style="width: 100px;" type="text" value="\$1.32"/> \$/Therm	Annual Heating Cost Savings: <input style="width: 100px;" type="text" value="\$2,546.17"/> \$\$		
Insert Cost of Cooling Fuel: <input style="width: 100px;" type="text" value="\$0.19"/> \$/kWh	Annual Cooling Cost Savings: <input style="width: 100px;" type="text" value="\$5,674.44"/> \$\$		
Total Annual Cost Savings : <input style="width: 100px;" type="text" value="\$8,303"/>	Total Annual Cost Savings From Heating & Cooling : <input style="width: 100px;" type="text" value="\$8,221"/> \$\$		
Cost of window upgrade : <input style="width: 100px;" type="text" value="\$224,930"/>	Estimated Annual O&M Savings: <input style="width: 100px;" type="text" value="\$82"/> \$		
Simple payback : <input style="width: 100px;" type="text" value="27.09"/> Yrs	<i>Type of Recommendation</i> <input style="width: 150px;" type="text" value="Capital Cost ECM Recommendation"/>		

Disclaimer: PREPARED BY EMG. May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM DESCRIPTION:			
<p>Windows play a major role in the energy use and comfort of an interior space. In the winter, heat in a room is lost when cold outside air infiltrates around the edges of windows. Heat also can be lost by conduction directly through the pane, even if the window fits tightly. Windows with insulated panes, such as those filled with Argon address this issue, while proper caulking and sealant address the infiltration issue. The cold drafts and the chilly windowpane make the room uncomfortable. Windows also can help to heat a room by letting the sun's rays enter. While this solar radiation is beneficial in the winter, it can be a major source of discomfort in hot, summer climates. Energy Star rated windows with Low-E glazing are designed to keep the solar heat gain minimized during the summer months. Choosing a replacement window that fits properly has the desired U-value, and proper glazing characteristics is critical to energy conservation through window upgrades.</p>			
Summary:			
Initial Investment:	\$224,930	Simple Payback	27.09 Yrs
Annual Energy Cost Savings:	\$8,303		

UIC	Install Low Flow Tankless Restroom Fixtures	
EAP4	Location: Restrooms	
ECM FOR DETERMINING WATER SAVINGS IN COMMERCIAL PROPERTIES		
Number of Males	400	
Number of Females	400	
Number of Occupied Days Per Week (Max 7)	5	
Number of Occupied Weeks/Year (Max 52)	35	
Number of Urinals To Be Retrofitted	8	
Number of Water Closets To Be Retrofitted	20	
No. of Water Closets With Separate Flush Tank <small>(Typical Residential Type)</small>	2	
Estimated Restroom Usage/Individual/Day <small>Default is 4 Uses/Day For Residential/Office</small>	4	(Select)
Urinal Water Savings		
Do you Want To Make Any Changes To The Urinals?	No	
Estimated Existing Use of Urinal/Day/Man	80%	
Existing Gallons Per Flush Ratings For Urinal Flushes	1.00	GPF
Proposed Urinal	0.125 GPF -Wall Mount	
GPF of Proposed Urinal Flush Valve**	0.125	GPF
<small>**1992 EpACT Energy Act Mandates 1.0GPF Max on Urinals)</small>		
Estimated Annual Water Savings From Urinal	0.00	kGal
Water Closet Water Savings		
Tankless Water Closets		
Do The Water Closet Need To Be Retrofitted?	(Select) Yes	
Existing Gallons Per Flush Ratings For Water Closet Flushes	1.60	GPF
Are The Existing Water Closet Being Replaced?	(Select) No	
<small>(If No, Then Only The Flush Valve Would Be Replaced With Dual Flush Retrofit Kit)</small>		
No. of Tankless Water Closets	18	
GPF of Proposed Dual Flush- Water Closet Valve*	Solid Waste (20%) 1.60	GPF
	Liquid Waste (80%) 0.48	GPF
<small>*Federal Law Requires All Flushes Not To Exceed 1.6 GPF)</small>		
Estimated Annual Water Savings From Male Users	250.88	kGal
Estimated Annual Water Savings From Female Users	250.88	kGal
Total Water Savings From Water Closets	501.76	kGal
Water & Cost Saving Calculations		
Water Savings Calculation		
Water Savings By The Use of Low Flow Water Closet Flush Valves/Yr	501.76	kGal
Water Savings By The Use of Low Flow Urinal Flush Valves/ Yr	0.00	kGal
Total Annual Water Savings in kGal	501.76	kGal
Cost Savings Calculations		
Enter Water Tariff Rate (\$/1000Gal)	\$0.29	\$\$
Estimated Cost Savings From Water	\$146	\$\$
Estimated Cost of Retrofit		
Cost For Replacing Existing Urinal Fixture With A Low Flow Fixture <small>(Includes Labor)</small>	\$0	\$\$
Cost For Replacing Existing Flush Valves With Low Flow - Dual Flush Valves (\$80 Per Unit) <small>(Up For Liquid Waste And Down For Solid Waste)</small>	\$12,381	\$\$
Estimated Total Cost For Retrofit	\$12,381	\$\$
Simple Pay Back Period	85.09	Yrs
Type of Recommendation	Capital Cost ECM Recommendation	

Disclaimer: PREPARED BY EMG, May 2016. INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM EXPLANATION:

The highest water utilization at any home/office occurs in the restrooms. It is estimated that on an average a normal human being uses the restroom at least four times a day. Keeping with the global water conservation objectives, federal law prohibits use of any new water closet flushes over 1.6 GPF. At the same time the '1992 EpACT' mandates all new Urinals to have a maximum 1.0 GPF flush valves on urinals.

EMG recommends replacing all urinals above 1.0 GPF with a new 0.5 GPF or lesser urinals. At the same time EMG also recommends replacing all the water closets having a GPF rating of 1.6 and over with low flow water closet fixtures equipped with dual flush valves.

In case the property doesn't wish to replace the entire water closet fixtures, EMG recommends retrofitting all the tankless water closet flush fixtures with new dual flush fixtures that would result in a 30% water savings per flush for liquid wastes, while retaining the same flush rate for solid wastes.

SUMMARY:

Initial Investment: \$12,381 Simple Payback Period: 85.09 Yrs
Annual Cost Savings: \$146

APPENDIX G: Solar PV

UIC	Install Fixed Tilt Solar Photovoltaic System
EAR-2	Details:

Select State: **Northern California** Electric Rate: **\$0.19** \$/KWh Annual Electric Consumption: **213,472** KWh

Roof No.	Description	Number of Roofs	DC System Size Per Roof	PV System Sizing For All Roofs	Estimated Number of 315 Watt PV Panels:	Total Estimated Annual Electricity Generated/ Roof	Total Estimated Electricity Generated (All Roofs)	Total Cost Savings	Installation Cost: (\$3.5/Watt)	Simple Pay Back Period without Incentives	One Time Potential Utility or State Incentives	One Time Potential Federal Incentives	Annual Potential Incentives and Rebates		Simple Pay Back Period with All Incentives
			kw	kw		kWh	kWh			Yrs		Dept. of Treasury Renewable Grant (30%)	Federal REPI Incentive	Solar Renewable Certificates (SRECS)- (\$0/MWh)	Years
												30%	\$0.02	\$0	
1	Building 4	1	11	11	34	16,409	16,409	\$3,039	\$37,450	12.3	\$0	\$11,235	\$361	\$0	7.4
2	Building 6	1	56	56	179	86,491	86,491	\$16,016	\$197,400	12.3	\$0	\$59,220	\$1,903	\$0	7.4
3	Building 8	1	19	19	60	28,984	28,984	\$5,367	\$66,150	12.3	\$0	\$19,845	\$638	\$0	7.4
4			0	0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
5			0	0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
6			0	0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
7			0	0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
8			0	0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
9			0	0	0	0	0	\$0	\$0		\$0	\$0	\$0	\$0	
		3		86	273	131,884.0	131,884	\$24,422	\$301,000	12.32	\$0	\$90,300	\$2,901	\$0	7.44

Solar Rooftop Photovoltaic Analysis	
Total Number of Roofs	3
Estimated Number of Panels	273
Estimated KW Rating	86
Potential Annual KWh Produced	131,884
% of Current Electricity Load	61.8%

KW

KWh

Financial Analysis	
Investment Cost	\$301,000
Estimated Energy Cost Savings	\$24,422
Potential Rebates	\$90,300
Potential Annual Incentives	\$2,901
Payback without Incentives	12.3
Incentive Payback but without SRECS	7.4
Payback with All Incentives	7.4

years

years

years