



LEVEL II ENERGY AUDIT

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT

5735 47th Avenue
Sacramento, California 95824

DLR GROUP

1050 20th Street, Suite 250
Sacramento, California 95923



ZERO NET ENERGY ASHRAE LEVEL II AUDIT
ETHEL PHILLIPS ELEMENTARY SCHOOL
2930 21st Avenue
Sacramento, California 95820

PREPARED BY:

EMG / A Bureau Veritas Company
10461 Mill Run Circle, Suite 1100
Owings Mills, Maryland 21117
800.733.0660
www.emgcorp.com

EMG CONTACT:

Kaustubh Anil Chabukswar
Program Manager
800.733.0660 x7512
kachabukswar@emgcorp.com

EMG PROJECT #:

136988.19R000-022.268

DATE OF REPORT:

October 25, 2019

ONSITE DATE:

August 27, 2019



engineering | environmental | capital planning | project management

A Bureau Veritas Group Company



www.EMGcorp.com | 800.733.0660

TABLE OF CONTENTS

Certification 1

1. Executive Summary 2

 1.1. Energy Conservation Measures 2

2. Introduction 8

3. Facility Overview and Existing Conditions 9

 3.1. Building Occupancy and Point of Contact 9

 3.2. Building Heating, Ventilating and Air-Conditioning (HVAC) 9

 3.3. Lighting 10

4. Utility Analysis 11

 4.1. Electricity 12

 4.2. Natural Gas..... 14

 4.3. Water and Sewer 16

5. Renewable Energy Discussions..... 18

 5.1. Rooftop Solar Photovoltaic Feasibility 18

6. Operations and Maintenance Plan 20

7. Appendices 22

Certification

EMG has completed an Energy Audit of Ethel Phillips Elementary School located at 2930 21st Avenue, in Sacramento, California 95820. EMG visited the site on August 27, 2019.

The assessment was performed at the Client's request using methods and procedures consistent with ASHRAE Level II Energy Audit and using methods and procedures as outlined in EMG's Proposal.

This report has been prepared for and is exclusively for the use and benefit of the Client identified on the cover page of this report. The purpose for which this report shall be used shall be limited to the use as stated in the contract between the client and EMG.

This report, or any of the information contained therein, is not for the use or benefit of, nor may it be relied upon by any other person or entity, for any purpose without the advance written consent of EMG. Any reuse or distribution without such consent shall be at the client's or recipient's sole risk, without liability to EMG.

Estimated installation costs are based on EMG's experience on similar projects and industry standard cost estimating tools including *RS Means and Whitestone CostLab*. In developing the installed costs, EMG also considered the area correction factors for labor rates for Sacramento, California 95820. Since actual installed costs may vary widely for particular installation based on labor & material rates at time of installation, EMG does not guarantee installed cost estimates and shall in no event be liable should actual installed costs vary from the estimated costs herein. We strongly encourage the owner to confirm these cost estimates independently. EMG does not guarantee the costs savings estimated in this report. EMG shall in no event be liable should the actual energy savings vary from the savings estimated herein.

EMG certifies that EMG has no undisclosed interest in the subject property and that EMG's employment and compensation are not contingent upon the findings or estimated costs to remedy any deficiencies due to deferred maintenance and any noted component or system replacements.

Any questions regarding this report should be directed to Kaustubh Anil Chabukswar at 800.733.0660, ext. 7512.

Prepared by: Noah Strafford
Energy Auditor
Project Manager



Reviewed by:

Kathleen Wright
Technical Report Reviewer for
Kaustubh Anil Chabukswar, CEM CRM
Program Manager

1. Executive Summary

The purpose of this Energy Audit is to provide Sacramento City Unified School District and Ethel Phillips Elementary School with a baseline of energy usage and the relative energy efficiency of the facility and specific recommendations for Energy Conservation Measures. Information obtained from these analyses may be used to support a future application to an Energy Conservation Program, Federal & Utility grants towards energy conservation, support performance contracting, justify a municipal bond funded improvement program, or as a basis for replacement of equipment or systems.

Building #	Structures Assessed	Building Type	EMG Calculated Area (SF)	Estimated Occupancy
1	001 Classrooms 18 to 25	School Building	8,009	100
2	002 Classrooms 9 to 17	School Building	10,298	125
3	003 Classrooms 3 to 8	School Building	6,487	80
4	004 Multipurpose	School Building	9,987	125
5	005 Classroom 1	School Building	1,582	20
6	006 Garage/Storage	School Building	1,500	20
7	007 Classroom 26	School Building	1,248	15
8	P01 Portable 27	Portable School Building	960	15
9	P02 Portable 28	Portable School Building	960	15
10	P03 Portable 29	Portable School Building	960	15
11	P04 Portable P1, P2, P3	Portable School Building	960	15
12	P05 Portable 30	Portable School Building	960	15
13	P06 Portable 31	Portable School Building	1,920	25
14	P07 Portable	Portable School Building	1,440	20

The study included a review of the building's construction features, historical energy and water consumption and costs, review of the building envelope, HVAC equipment, heat distribution systems, lighting, and the building's operational and maintenance practices.

1.1. Energy Conservation Measures

EMG has identified seven Energy Conservation Measures (ECMs) for this property. The savings for each measure is calculated using standard engineering methods followed in the industry, and detailed calculations for ECM are provided in Appendix E for reference. A 10% discount in energy savings was applied to account for the interactive effects amongst the ECMs. In addition to the consideration of the interactive effects, EMG has applied a 15% contingency to the implementation costs to account for potential cost overruns during the implementation of the ECMs.

The following table summarizes the recommended ECMs in terms of description, investment cost, energy consumption reduction, and cost savings.

Summary of Financial Information for Recommended Non-Renewable Energy Conservation Measures

ITEM	ESTIMATE
Net Initial ECM Investment <i>(Current Dollars Only)</i>	\$45,970 <i>(In Current Dollars)</i>
Estimated Annual Cost Savings <i>(Current Dollars Only)</i>	\$14,203 <i>(In Current Dollars)</i>
ECM Effective Payback	3.24 years
Estimated Annual Energy Savings	21%
Estimated Annual Energy Utility Cost Savings <i>(Excluding Water)</i>	16.0%
Estimated Annual Water Cost Saving	35%

Solar Photovoltaic (PV) Screening for ETHEL PHILLIPS ELEMENTARY SCHOOL

SOLAR ROOFTOP PHOTOVOLTAIC ANALYSIS		
Estimated Number of Panels	267	
Estimated KW Rating	84	KW
Potential Annual kWh Produced	130,829	kWh
% of Current Electricity Uses	45.4%	
FINANCIAL SUMMARY		
Investment Cost	\$294,700	
Estimated Energy Cost Savings	\$22,437	
Payback without Incentives	13.1	Years
Incentive Payback but without SRECs	7.9	Years
Payback with All Incentives	7.9	Years

Key Metrics to Benchmark the Subject Property's Energy Usage Profile

- **Building Site Energy Use Intensity** - The sum of the total site energy use in thousands of Btu per unit of gross building area. Site energy accounts for all energy consumed at the building location only not the energy consumed during generation and transmission of the energy to the site.
- **Building Source Energy Use Intensity** – The sum of the total source energy use in thousands of Btu per unit of gross building area. Source energy is the energy consumed during generation and transmission in supplying the energy to your site.
- **Building Cost Intensity** - This metric is the sum of all energy use costs in dollars per unit of gross building area.
- **Greenhouse Gas Emissions** - Although there are numerous gases that are classified as contributors to the total for Greenhouse Emissions, the scope of this energy audit focuses on carbon dioxide (CO₂). Carbon dioxide enters the atmosphere through the burning of fossil fuels (oil, natural gas, and coal), solid waste, trees and wood products, and also as a result of other chemical reactions (e.g., manufacture of cement).

SITE ENERGY USE INTENSITY (EUI)	RATING
Current Site Energy Use Intensity (EUI)	31 kBtu/ft ²
Post ECM Site Energy Use Intensity (EUI)	24 kBtu/ft ²
SOURCE ENERGY USE INTENSITY (EUI)	RATING
Current Source Energy Use Intensity (EUI)	80 kBtu/ft ²
Post ECM Source Energy Use Intensity (EUI)	67 kBtu/ft ²
BUILDING COST INTENSITY (BCI)	RATING
Current Building Cost Intensity	\$1.17/ft ²
Post ECM Building Cost Intensity	\$0.99/ft ²

Summary of the Greenhouse Gas Reductions from Recommended Non-Renewable Energy Conservation Measures

The following table provides a summary of the projected Greenhouse Gas Emissions reductions as a result of the recommended Energy Conservation Measures:

GREENHOUSE GAS EMISSIONS REDUCTION	
Estimated Annual Thermal Energy Reduction	307 MMbtu
Total CO ₂ Emissions Reduced	21.7 MtCO ₂ /Yr.
Total Cars Off the Road (Equivalent)*	4
Total Acres of Pine Trees Planted (Equivalent)*	5

**Equivalent reductions per DOE emissions calculation algorithms*

Zero Net Energy Analysis for Renewable and Non-Renewable Recommended Measures

ZERO NET ENERGY ANALYSIS	
Building Annual Net Energy Consumption	1,448,871 kBtu
Total Annual Energy Savings for Non-Renewable Energy Measures	307,422 kBtu
Total Annual Energy Savings from Renewable Energy Measures	446,388 kBtu
Total Annual Energy Savings	753,810 kBtu
Net Energy Consumption from Grid Post Implementation	695,061 kBtu
% Energy Reduction (Annual Energy-Net Energy) / (Annual Energy)	47.9 %

Energy Conservation Measures Screening:

EMG screens ECMs using two financial methodologies. ECMs which are considered financially viable must meet both criteria.

1. Simple Payback Period –The number of years required for the cumulative value of energy or water cost savings less future non-fuel or non-water costs to equal the investment costs of the building energy or water system, without consideration of discount rates. ECMs with a payback period greater than the Expected Useful Life (EUL) of the project are not typically recommended, as the cost of the project will not be recovered during the lifespan of the equipment. These ECMs are recommended for implementation during future system replacement. At that time, replacement may be evaluated based on the premium cost of installing energy efficient equipment.

$$\text{Simple Payback} = \frac{\text{Initial Cost}}{\text{Annual Savings}}$$

2. Savings-to-Investment Ratio (SIR) – The savings-to-investment ratio is the ratio of the present value savings to the present value costs of an energy or water conservation measure. The numerator of the ratio is the present value over the estimated useful life (EUL) of net savings in energy or water and non-fuel or non-water operation and maintenance costs attributable to the proposed energy or water conservation measure. The denominator of the ratio is the present value of the net increase in investment and replacement costs less salvage value attributable to the proposed energy or water conservation measure. It is recommended that energy efficiency recommendations should be based on a calculated SIR, with larger SIRs receiving a higher priority. A project is typically only recommended if SIR is greater than or equal to 1.0, unless other factors outweigh the financial benefit.

$$SIR = \frac{\text{Present Value (Annual Savings, } i\%, \text{ EUL)}}{\text{Initial Cost}}$$

List of Recommended Energy Conservation Measures For Ethel Phillips Elementary School																
ECM #	UIC	Description of ECM	Projected Initial Investment	Estimated Annual Energy Savings					Estimated Annual Water Savings	Estimated Cost Savings	Estimated Annual O&M Savings	Total Estimated Annual Cost Savings	Simple Payback	S.I.R.	Life Cycle Savings	Expected Useful Life (EUL)
				Natural Gas	Propane	No.2 Oil	Steam	Electricity								
			\$	Therms	Gallons	Gallons	Mlbs	kWh	kgal	\$	\$	\$	Years		\$	Years
No/Low Cost Recommendations																
1	EAP2-b	Install Low Flow Faucet Aerators	\$548	783	0	0	0	0	99	\$1,765	\$0	\$1,765	0.31	27.46	\$14,509	10.00
		Location: Restrooms And Classrooms														
Totals for No/Low Cost Items			\$548	783	0	0	0	0	99	\$1,765	\$0	\$1,765	0.31			
Capital Cost Recommendations																
1	EAC3	Reduce HVAC Hours of Operation	\$1,597	684	0	0	0	27,064	0	\$5,531	\$0	\$5,531	0.29	41.34	\$64,432	15.00
		Location: Throughout														
2	EAC7A	Install Timers On Exhaust Fans	\$1,062	459	0	0	0	3,953	0	\$1,276	\$0	\$1,276	0.83	14.34	\$14,167	15.00
		Location: Throughout														
3	EAP3	Install Low Flow Restroom Flush Tank Toilets	\$5,692	0	0	0	0	0	325	\$2,439	\$0	\$2,439	2.33	6.38	\$30,596	20.00
		Location: Restrooms And Locker Rooms														
4	EAL10	Upgrade Building Lighting to LED and Install Automatic Lighting Controls	\$10,168	0	0	0	0	9,705	0	\$1,664	\$244	\$1,909	5.33	2.24	\$12,617	15.00
		Location: Building Interior And Exterior														
5	EAP4	Install Low Flow Tankless Restroom Fixtures	\$19,190	0	0	0	0	0	364	\$2,732	\$0	\$2,732	7.02	1.70	\$13,422	15.00
		Location: Restrooms														
6	EAD3	Replace Existing Water Heater With New Energy Efficient Units	\$1,716	100	0	0	0	0	0	\$130	\$0	\$130	13.19	1.04	\$73	18.00
		Location: Building 004														
Total For Capital Cost			\$39,426	1,243	0	0	0	40,723	689	\$13,772	\$244	\$14,016	2.81			
		Interactive Savings Discount @ 10%		-203	0	0	0	-4,072	-79	-\$1,554	-\$24	-\$1,578				
		Total Contingency Expenses @ 15%	\$5,996													
Total for Improvements			\$45,970	1,824	0	0	0	36,651	709	\$13,983	\$220	\$14,203	3.24			

In addition to the above measures, EMG has identified the following measure(s) but has not recommended as they fail to meet the above-mentioned financial criteria of SIR>1.0. Thus, EMG has classified the measure(s) as recommended for consideration.

List of Recommended For Consideration Energy Conservation Measures For Ethel Phillips Elementary School																
ECM #	UIC	Description of ECM	Initial Investment	Annual Energy Savings					Annual Water Savings	Cost Savings	Estimated Annual O&M Savings	Total Estimated Annual Cost Savings	Payback	S.I.R.	Life Cycle Savings	Expected Useful Life (EUL)
			\$	Natural Gas	Propane	No.2 Oil	Steam	Electricity	kgal	\$	\$	\$	Years		\$	Years
1	EAH11-A	Upgrade Electric Heating System To Heat Pumps	\$24,367	0	0	0	0	7,137	0	\$1,224	\$0	\$1,224	19.91	0.75	-\$6,162	20.00
		Location: Portable Classrooms														
1	EAE2	Replace External Windows	\$367,768	2,515	0	0	0	61,784	0	\$13,867	\$69	\$13,937	26.39	0.34	-\$125,087	25.00
		Location: Buildings 001, 002, 003, 004, 005, 007 & P01-P06														
1	EAH12-A	Replace Inefficient Furnace and Air Conditioning System	\$222,038	66	0	0	0	28,074	28	\$4,899	\$245	\$5,144	43.16	0.34	-\$145,505	20.00
		Location: Throughout														
1	EAH12-B	Replace Rooftop Package Unit	\$26,260	204	0	0	0	0	0	\$266	266	\$13.29	1976.62	0.16	-\$22,109	20.00
		Location: Building 001														
Total for Improvements			\$24,367	0	0	0	0	7,137	0	\$1,224	\$0	\$1,224	19.91			

2. Introduction

The purpose of this Energy Audit is to provide Ethel Phillips Elementary School and Sacramento City Unified School District with a baseline of energy usage, the relative energy efficiency of the facility, and specific recommendations for Energy Conservation Measures. Information obtained from these analyses may be used to support a future application to an Energy Conservation Program, Federal and Utility grants towards energy conservation, as well as support performance contracting, justify a municipal bond-funded improvement program, or as a basis for replacement of equipment or systems.

The energy audit consisted of an onsite visual assessment to determine current conditions, itemize the energy consuming equipment (i.e. Boilers, Make-Up Air Units, DWH equipment); review lighting systems both exterior and interior; and review efficiency of all such equipment. The study also included interviews and consultation with operational and maintenance personnel. The following is a summary of the tasks and reporting that make up the Energy Audit portion of the report.

The following is a summary of the tasks and reporting that make up the Energy Audit portion of the report.

ENERGY AND WATER USING EQUIPMENT

- EMG has surveyed the common areas, office areas, rooms, maintenance facilities and mechanical rooms to document utility-related equipment, including heating systems, cooling systems, air handling systems and lighting systems.

BUILDING ENVELOPE

- EMG has reviewed the characteristics and conditions of the building envelope, checking insulation values and conditions. This review also includes an inspection of the condition of walls, windows, doors, roof areas, insulation and special use areas

RECOMMENDATIONS FOR ENERGY SAVINGS OPPORTUNITIES

- Based on the information gathered during the on site assessment, the utility rates, as well as recent consumption data and engineering analysis, EMG has identified opportunities to save energy and provide probable construction costs, projected energy/utility savings and provide a simple payback analysis.

ANALYSIS OF ENERGY CONSUMPTION

- Based on the information gathered during the on-site assessment, EMG has conducted an analysis of the energy usage of all equipment, and identified which equipment is using the most energy and what equipment upgrades may be necessary. As a result, equipment upgrades, or replacements are identified that may provide a reasonable return on the investment and improve maintenance reliability.

ENERGY AUDIT PROCESS

- Interviewing staff and review plans and past upgrades
- Performing an energy audit for each use type
- Performing a preliminary evaluation of the utility system
- Analyzing findings, utilizing ECM cost-benefit worksheets
- Making preliminary recommendations for system energy improvements and measures
- Estimating initial cost and changes in operating and maintenance costs based on implementation of energy efficiency measures
- Ranking recommended cost measures, based on the criticality of the project and the largest payback

REPORTING

The EMG Energy Audit Report includes:

- A comprehensive study identifying all applicable Energy Conservation Measures (ECMs) and priorities, based on initial cost and payback
- A narrative discussion of building systems/components considered and a discussion of energy improvement options;
- A summary of ECMs including initial costs and simple paybacks, based on current utility rates and expected annual savings.

3. Facility Overview and Existing Conditions

3.1. Building Occupancy and Point of Contact

FACILITY SCHEDULE	
Hours of Operations / Week	35
Operational Weeks / Year	36
Estimated Facility Occupancy	495
% of Male Occupants	50%

POINT OF CONTACT	
Point of Contact Name	Artmio Ortiz
Point of Contact Title	Plant manager
Point of Contact – Contact Number	916-585-2702

3.2. Building Heating, Ventilating and Air-Conditioning (HVAC)

Description:

Heating and cooling in permanent buildings 001, 002, 003, 004, 005 and 007 is provided primarily by central split AC systems with natural gas furnaces. Buildings 001, 002 and 004 are supplementary served by rooftop package units utilizing natural gas for heating. The portable units are served by wall mounted heat pumps for heating and cooling.

The Mechanical Equipment Schedule in Appendix B contains a summary of the HVAC Equipment at the property.

BUILDING CENTRAL HEATING SYSTEM	
Primary Heating System	Central Split System Forced Air Furnace
Secondary Heating System	Rooftop package units and Wall Mounted Heat Pumps
Hydronic Distribution System	Not Applicable
Primary Heating Fuel	Natural Gas
Heating Mode Set-point	69 °F
Heating Mode- Set-back Temperature	53 °F

BUILDING COOLING SYSTEM	
Primary Cooling System	Packaged Rooftop Units

BUILDING COOLING SYSTEM	
Secondary Cooling System	Central Split System
Hydronic Distribution System	Not Applicable
Cooling Mode Set-point	73 °F
Cooling Mode- Set-back Temperature	93 °F

AIR DISTRIBUTION SYSTEM	
Building Ventilation	Roof-top Exhaust Fans
On-Demand Ventilation System in Use?	No
Energy Recovery Wheel / Enthalpy Wheel Exhaust Fans	No

DOMESTIC HOT WATER SYSTEM	
Primary Domestic Water Fuel	Natural Gas

3.3. Lighting

Description:

The lighting in the school building was upgraded to LED in 2019 and primarily consists of T8 linear fluorescent lamp fixtures in classrooms and hallways. The fixtures were observed to be operating on bi-level mode in the classrooms. The exterior lights were primarily High Intensity Discharge (HID) fixtures.

The detailed lighting schedule and the proposed LED alternative is provided in Appendix C.

4. Utility Analysis

Establishing the energy baseline begins with an analysis of the utility cost and consumption of the building. Utilizing the historical energy data and local weather information, we evaluate the existing utility consumption and assign it to the various end-uses throughout the buildings. The Historical Data Analysis breaks down utilities by consumption, cost and annual profile.

This data is analyzed, using standard engineering assumptions and practices. The analysis serves the following functions:

- Allows our engineers to benchmark the energy and water consumption of the facilities against consumption of efficient buildings of similar construction, use and occupancy.
- Generates the historical and current unit costs for energy and water
- Provides an indication of how well changes in energy consumption correlate to changes in weather.
- Reveals potential opportunities for energy consumption and/or cost reduction. For example, the analysis may indicate that there is excessive, simultaneous heating and cooling, which may mean that there is an opportunity to improve the control of the heating and cooling systems.

By performing this analysis and leveraging our experience, our engineers prioritize buildings and pinpoint systems for additional investigation during the site visit, thereby maximizing the benefit of their time spent on-site and minimizing time and effort by the customer's personnel.

Based upon the utility information provided about the Sacramento City Unified School District, the following energy rates are utilized in determining existing and proposed energy costs.

Utility Rates used for Cost Analysis

ELECTRICITY (BLENDED RATE)	NATURAL GAS	WATER / SEWER
\$0.17 /kWh	\$1.30 /therm	\$7.51 /kGal

The data analyzed provides the following information: 1) breakdown of utilities by consumption, 2) cost and annual profile, 3) baseline consumption in terms of energy/utility at the facility, 4) the Energy Use Index, or Btu/sq. ft, and cost/sq. ft. For multiple water meters, the utility data is combined to illustrate annual consumption for each utility type.



4.1. Electricity

PGE satisfies the electricity requirements for the facility. The primary end uses for electric utility comprises of lighting, cooling, office/school equipment, and appliances in the break room.

The table below provides the electric use for the period of twelve continuous months.

Electric Consumption and Cost Data

BILLING MONTH	CONSUMPTION (KWH)	UNIT COST/KWH	TOTAL COST
July,18	17,183.90	0.21	3,636.44
August,18	23,117.10	0.18	4,252.77
September,18	30,505.77	0.16	4,903.87
October,18	29,938.99	0.16	4,806.29
November,18	22,396.70	0.17	3,758.28
December,18	20,965.44	0.17	3,587.51
January,19	21,147.31	0.17	3,666.85
February,19	23,808.12	0.17	3,953.93
March,19	24,098.44	0.17	4,138.62
April,19	20,996.13	0.18	3,688.43
May,19	26,846.48	0.17	4,498.24
June,19	27,482.58	0.17	4,574.79
Total/average	288,486.96	0.17	49,466.02





4.2. Natural Gas

SMUD Gas satisfies the natural gas requirements of the facility. The primary end use of natural gas is for building heating, domestic water heating, and cooking in the cafeteria.

The analysis of the 12 months of consumption is provided below.

Natural Gas Consumption and Cost Data

BILLING MONTH	CONSUMPTION (THERMS)	UNIT COST/THERM	TOTAL COST
July, 18	22	\$2.38	\$53
August, 18	34	\$1.91	\$65
September, 18	62	\$1.45	\$90
October, 18	172	\$1.20	\$206
November, 18	580	\$1.20	\$696
December, 18	715	\$1.37	\$977
January, 19	910	\$1.28	\$1,168
February, 19	954	\$1.31	\$1,246
March, 19	732	\$1.31	\$959
April, 19	260	\$1.25	\$324
May, 19	145	\$1.27	\$184
June, 19	60	\$1.28	\$77
Total/average	4,646	\$1.30	\$6,046





4.3. Water and Sewer

The City of Sacramento satisfies the water requirements for the facility. The primary end use of water is the plumbing fixtures such as staff showers, water closets, and lavatories. The table below provides the twelve continuous months' worth of consumption and cost for water in kGal for the facility.

Water and Sewer Consumption and Cost Data

BILLING MONTH	CONSUMPTION (KGAL)	UNIT COST/KGAL	TOTAL COST
July,18	274	\$5.53	\$1,517
August,18	358	\$5.09	\$1,823
September,18	353	\$5.11	\$1,806
October,18	371	\$4.93	\$1,829
November,18	328	\$5.17	\$1,693
December,18	68	\$15.40	\$1,053
January,19	5	\$158.75	\$841
February,19	6	\$127.35	\$823
March,19	6	\$149.92	\$861
April,19	25	\$35.67	\$902
May,19	144	\$7.37	\$1,063
June,19	95	\$11.25	\$1,072
Total/average	2,035	\$7.51	\$15,284



5. Renewable Energy Discussions

5.1. Rooftop Solar Photovoltaic Feasibility

Solar Energy Feasibility

A photovoltaic array is a linked collection of photovoltaic modules, which are in turn made of multiple interconnected solar cells. The cells convert solar energy into direct current electricity via the photovoltaic effect. The power that one module can produce is seldom enough to meet requirements of a home or a business, so the modules are linked together to form an array. Most PV arrays use an inverter to convert the DC power produced by the modules into alternating current that can plug into the existing infrastructure to power lights, motors, and other loads. The modules in a PV array are usually first connected in series to obtain the desired voltage; the individual strings are then connected in parallel to allow the system to produce more current. Solar arrays are typically measured by the peak electrical power they produce, in watts, kilowatts, or even megawatts.

When determining if a site is suitable for a solar application, two basic considerations must be evaluated:

- At minimum, the sun should shine upon the solar collectors from 9 AM to 3 PM. If less, the application may still be worthwhile, but the benefit will be less.
- The array should face south and be free of any shading from buildings, trees, rooftop equipment, etc. If the array is not facing directly south, there will be a penalty in transfer efficiency, reducing the overall efficiency of the system.

SOLAR PV QUESTIONNAIRE	RESPONSE
Does the property have a south, east, or west facing roof or available land of more than 250 square feet per required Solar Array Panel?	Yes
Is the area free from any shading such as trees, buildings, equipment etc. throughout the whole day?	Yes
Can the panels be mounted at an incline of roughly 25-45 degrees? (equal to latitude of property)	Yes
Is the property in an area with acceptable average monthly sunlight levels?	Yes
Has the roofing been replaced within the past 3-5 years?	No
Is the roof structure sufficient to hold solar panels?	Additional Study Required
Is the property located in a state eligible for net metering?	Yes

A solar feasibility analysis of the site has resulted in the building containing more than sufficient amount of roof area for solar electricity generation. The analysis through the use of National Renewable Energy Laboratory's solar photovoltaic software assisted in calculating the potential electricity generated from the allocated land and roof area set for solar photovoltaic installment. The allocated roof area was through looking at the roof and surrounding areas at a bird's eye view. Also detailed in the report are incentives and rebates that can potentially bring down the installation cost of the ECMs and result in a higher return on investment and quicker payback period.

The approach taken in the solar photovoltaic (PV) roof analysis begins with surveying the roof and determine areas on the roof where solar PV panels can potentially be installed.

- 1) Conducting a preliminary sizing of solar PV panels on the roofs and on the ground and its potential electricity production for its first year of installment using the National Renewable Energy Laboratory (NREL) PV WATTS Version 2 Software.
- 2) Calculate energy and cost savings for the site as a sole proprietor of the system capable of collecting state, local, and federal tax credits and incentives and interconnecting and selling the renewable energy electrical production to the building.

SOLAR ROOFTOP PHOTOVOLTAIC ANALYSIS		
Estimated Number of Panels	267	KW kWh
Estimated KW Rating	84	
Potential Annual kWh Produced	130,829	
% of Current Electricity Uses	45.4%	
FINANCIAL SUMMARY		
Investment Cost	\$294,700	Years
Estimated Energy Cost Savings	\$22,437	
Payback without Incentives	13.1	
Incentive Payback but without SRECs	7.9	
Payback with All Incentives	7.9	

A photovoltaic array is a linked collection of photovoltaic modules, which are in turn made of multiple interconnected solar cells. The cells convert solar energy into direct current. Modules of cells are linked together to form an array. Most PV arrays use an inverter to convert the DC power produced by the modules into alternating current that can connect to existing AC infrastructure to power lights, motors, and other loads.

Cost of production has fallen years with increasing demand and through production and technological advances. The cost dropped from \$8–10/watt in 1996 to \$4–7/watt in 2006. The market is diversifying with new types of panels suited to unique installation methods including stick on sheets and PV spray coating. The solar PV cost used in the analysis was set at \$7.0/Watt which includes design, construction, administration, and installation and maintenance cost throughout the life of the solar panels.

One breakthrough for PV is "Net Metering". When more PV electric power is generated than is consumed on site, the electric service meter reverses to "sell" the excess power directly back onto the power grid. The economics of PV for commercial industrial installations become attractive when coupled with incentives from Federal and state agencies, as well utility companies.

A kilowatt-hour costing \$0.15 might be valued at \$0.30 when produced by PV and sent to the grid. The economics of PV for commercial industrial installations become attractive when coupled with incentives from Federal and state agencies, as well utility companies.

The low payback period is highly dependent on the marketing potential of selling Solar Renewable Certificates to electricity generated providers who are under state regulations to contain a certain percentage of their electricity generation derived from renewable energy such as wind and solar.

Solar facilities are encouraged to sell their SRECs on the market (either spot market or through long-term contracts). Utilities may use SRECs for compliance under the state RPS for the year in which they are generated. Utilities may purchase up to 10% more SRECs than they require for compliance and "bank" those surplus SRECs for compliance during the following two years. Any SRECs pricing can range from \$300 - \$450/MWh and can be sold across state borders to other utility providers looking to purchase SRECs. EMG has selected to use the market value of \$300/MWh minus 5% administrative fee in the analysis.

A number of states and corresponding electrical utility supplier are required under regulation to have a certain percentage of its electricity be produced by solar energy. To offset that they allow other utility companies to buy Renewable Energy Credits (REC) credit off their customers and facilities that produce their own solar energy. Typically, the national market, the utility market is \$400 per MWh to Utility Suppliers for not meeting this standard percentage so these REC credits are sold for \$350 per MWh. (1 REC credit = 1 MWh).

State charges these utility companies to meet their state compliance of 0.2% of the entire electricity consumption from solar energy by 2022 (from 0.005% in 2008 aggregated up to 0.2% by 2022). The REC credits correspond to these percentages as they aggregate each year.

6. Operations and Maintenance Plan

The quality of the maintenance and the operation of the facility's energy systems have a direct effect on its overall energy efficiency. Energy-efficiency needs to be a consideration when implementing facility modifications, equipment replacements, and general corrective actions. The following is a list of activities that should be performed as part of the routine maintenance program for the property.

Building Envelope

- ✓ Ensure that the building envelope has proper caulking and weather stripping.
- ✗ Patch holes in the building envelope with foam insulation and fire rated caulk around combustion vents
- ✗ Inspect building vents semiannually for bird infestation
- ✓ Inspect windows monthly for damaged panes and failed thermal seals
- ✓ Repair and adjust automatic door closing mechanisms as needed.

Heating and Cooling

- ✓ Pilots lights on furnaces and boilers be turned off in summer
- ✓ All preventive maintenance should be performed on all furnaces and boilers, which would include cleaning of burners and heat exchanger tubes.
- ✓ Ensure that the combustion vents exhaust outside the conditioned space and the vent dampers are functional
- ✓ Ensure that the control valves are functioning properly before start of every season
- ✗ Ensure steam traps are functional before start of each heating season
- ✗ Ensure use of chemical treatment for boiler make up water
- ✗ Ensure boiler outside temperature re-set is set to 55F
- ✗ Ensure use of chemical treatment for Colling tower water to prevent corrosion
- ✓ Ensure the duct work in unconditioned space is un-compromised and well insulated
- ✓ Duct cleaning is recommended every 10 years. This should include sealing of ducts using products similar to 'aero-seal'
- ✗ Ensure use of economizer mode is functional and used
- ✗ Ensure that the outside air dampers actuators are operating correctly
- ✗ Ensure air coils in the AHU and FCA's are pressure washed annually
- ✓ Return vents should remain un-obstructed and be located centrally
- ✓ Temperature settings reduced in unoccupied areas and set points seasonally adjusted.
- ✓ Evaporator coils and condenser coils should be regularly cleaned to improve heat transfer
- ✓ Refrigerant pipes should be insulated with a minimum of ¾" thick Elastomeric Rubber Pipe Insulation
- ✓ Ensure refrigerant pressure is maintained in the condensers
- ✓ Change air filters on return vents seasonally. Use only filters with 'Minimum Efficiency Rating Value'(MERV) of 8

Central Domestic Hot Water Heater

- ✗ Never place gas fired water heaters adjacent to return vents so as to prevent flame roll outs
- ✓ Ensure the circulation system is on timer to reduce the losses through re-circulation
- ✓ Ensure all hot water pipes are insulated with fiberglass insulation at all times
- ✓ Replacement water heater should have Energy Factor (EF)>0.9
- ✓ Tank-type water heaters flushed monthly

Lighting Improvements

- ✓ Utilize bi-level lighting controls in stairwells and hallways.
- ✓ Use LED replacement lamps
- ✓ Clean lighting fixture reflective surfaces and translucent covers.
- ✓ Ensure that timers and/or photocells are operating correctly on exterior lighting
- ✓ Use occupancy sensors for offices and other rooms with infrequent occupancy

Existing Equipment and Replacements

- ✓ Ensure that refrigerator and freezer doors close and seal correctly
- ✓ Ensure kitchen and bathroom exhaust outside the building and the internal damper operates properly
- ✓ Ensure that bathroom vents exhaust out
- ✓ Office/ computer equipment either in the “sleep” or “off” mode when not used

7. Appendices

APPENDIX A: Glossary of Terms

APPENDIX B: Mechanical Equipment Inventory

APPENDIX C: Lighting System Schedule

APPENDIX D: ECM Checklist

APPENDIX E: ECM Calculations

APPENDIX F: Solar PV

APPENDIX A:

Glossary of Terms

Glossary of Terms and Acronyms

ECM – Energy Conservation Measures are projects recommended to reduce energy consumption. These can be No/Low cost items implemented as part of routine maintenance or Capital Cost items to be implemented as a capital improvement project.

Initial Investment – The estimated cost of implementing an ECM project. Estimates typically are based on R.S. Means Construction cost data and Industry Standards.

Annual Energy Savings – The reduction in energy consumption attributable to the implementation of a particular ECM. These savings values do not include the interactive effects of other ECMs.

Cost Savings – The expected reduction in utility or energy costs achieved through the corresponding reduction in energy consumption by implementation of an ECM.

Simple Payback Period – The number of years required for the cumulative value of energy or water cost savings less future non-fuel or non-water costs to equal the investment costs of the building energy or water system, without consideration of discount rates.

EUL – Expected Useful Life is the estimated lifespan of a typical piece of equipment based on industry accepted standards.

RUL – Remaining Useful Life is the EUL minus the effective age of the equipment and reflects the estimated number of operating years remaining for the item.

SIR – The savings-to-investment ratio is the ratio of the present value savings to the present value costs of an energy or water conservation measure. The numerator of the ratio is the present value of net savings in energy or water and non-fuel or non-water operation and maintenance costs attributable to the proposed energy or water conservation measure. The denominator of the ratio is the present value of the net increase in investment and replacement costs less salvage value attributable to the proposed energy or water conservation measure. It is recommended that energy-efficiency recommendations be based on a calculated SIR, with larger SIRs receiving a higher priority. A project typically is recommended only if the SIR is greater than or equal to 1.0, unless other factors outweigh the financial benefit.

Life Cycle Cost – The sum of the present values of (a) Investment costs, less salvage values at the end of the study period; (b) Non-fuel operation and maintenance costs; (c) Replacement costs less salvage costs of replaced building systems; and (d) Energy and/or water costs.

Life Cycle Savings – The sum of the estimated annual cost savings over the EUL of the recommended ECM, expressed in present value dollars.

Building Site Energy Use Intensity – The sum of the total site energy use in thousands of Btu per unit of gross building area. Site energy accounts for all energy consumed at the building location only not the energy consumed during generation and transmission of the energy to the site.

Building Source Energy Use Intensity – The sum of the total source energy use in thousands of Btu per unit of gross building area. Source energy is the energy consumed during generation and transmission in supplying the energy to your site.

Building Cost Intensity – This metric is the sum of all energy use costs in dollars per unit of gross building area.

Greenhouse Gas Emissions – Although there are numerous gases that are classified as contributors to the total for Greenhouse Emissions, the scope of this energy audit focuses on carbon dioxide (CO₂). Carbon dioxide enters the atmosphere through the burning of fossil fuels (oil, natural gas, and coal), solid waste, trees and wood products, and also as a result of other chemical reactions (e.g., manufacture of cement).

APPENDIX B:

Mechanical Equipment Inventory

Mechanical Inventory								
System	Make	Model	Serial Number	Input Capacity	Output Capacity	Room Number	Space Served	Quantity
Water Heater	A. O. Smith	Inaccessible	Inaccessible	6 GAL, 1.5kW	-	Toilet	006 Garage/Storage	1
Water Heater	Rheem	21V30-6N	RHLN 0101231442	30 GAL, 32 MBH	-	Mechanical M003	007 Classroom 26	1
Water Heater	Rheem	42VR50-40F	RHLN0806V17897	50 GAL, 40 MBH	-	Janitor - J037	004 Multipurpose, Kitchen	1
Water Heater	No tag/plate found	No tag/plate found	No tag/plate found	6 GAL, 1.5kW	-	Mechanical M005	005 Classroom 1	1
Wall Mounted Heat Pump	No tag/plate found	No tag/plate found	No tag/plate found	3.5 TON	-	Building exterior	P06 Portable 31	1
Wall Mounted Heat Pump	No tag/plate found	No tag/plate found	No tag/plate found	3.5 TON	-	Building exterior	P05 Portable 30	1
Wall Mounted Heat Pump	Bard Manufacturing Company	WH482-A05VX4	Inaccessible	4 TON	-	Building exterior	P04 Portable P1, P2, P3	1
Wall Mounted Heat Pump	Bard Manufacturing Company	No tag/plate found	No tag/plate found	4 TON	-	Building exterior	P01 Portable 27	1
Wall Mounted Heat Pump	Bard Manufacturing Company	Illegible	Illegible	4 TON	-	Building exterior	P02 Portable 28	1
Wall Mounted Heat Pump	Bard Manufacturing Company	WH482-A05VX4	Illegible	4 TON	-	Building exterior	P04 Portable P1, P2, P3	1
Wall Mounted Heat Pump	Bard Manufacturing Company	WH482-A05VX4	1499011579131-01	4 TON	-	P07	P07 Portable - Parker Family	1
Wall Mounted Heat Pump	Bard Manufacturing Company	No tag/plate found	No tag/plate found	4 TON	-	Building exterior	P03 Portable 29	1
Wall Mounted Heat Pump	Bard Manufacturing Company	WH482-A05VX4	No tag/plate found	4 TON	-	Building exterior	P04 Portable P1, P2, P3	1
Packaged Unit (RTU)	Johnson Controls	ZQG05D2B1AC1A324A2	N1H9170128	70 MBH	56 MBH	Roof	004 Multipurpose, Kitchen	1
Packaged Unit (RTU)	Johnson Controls	ZQG06D2B1AC1A324A2	N1H9170113	70 MBH	56 MBH	Roof -01A	001 Classrooms 18 to 25	1
Packaged Unit (RTU)	Johnson Controls	ZQG04D281AC1A324A2	N1H9153500	70 MBH	56 MBH	Roof	004 Multipurpose, Kitchen	1
Packaged Unit (RTU)	Johnson Controls	ZQG06D2B1AC1A324A2	N1H9170114	70 MBH	56 MBH	Roof 02C	002 Classrooms 9 to 17	1

Packaged Unit (RTU)	Johnson Controls	ZQG06D2B1AC1A324A2	N1H9170112	70 MBH	56 MBH	Roof -01A	001 Classrooms 18 to 25	1
Exhaust Fan	No tag/plate found	No tag/plate found	No tag/plate found	No tag/plate found	-	Roof -01A	001 Classrooms 18 to 25	1
Exhaust Fan	Penn Ventilation	DX06B	Illegible	50 - 500 CFM	-	Roof 02D	002 Classrooms 9 to 17	1
Exhaust Fan	PennBarry	DX11B	A08AN27048	50 - 500 CFM	-	Roof 02E	002 Classrooms 9 to 17	1
Exhaust Fan	Inaccessible	Inaccessible	Inaccessible	Inaccessible	-	Roof 03F	003 Classrooms 3 to 8	1
Exhaust Fan	No tag/plate found	No tag/plate found	No tag/plate found	50 - 500 CFM	-	Roof	004 Multipurpose, Kitchen	1
Domestic Circulation/Booster Pump	Berkeley	B2TPMS	I02566	7.5 HP	-	Site	Site	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1699401698	80 MBH	74.4 MBH	Mechanical M016	004 Multipurpose, Kitchen	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1399A01251	80 MBH	74.4 MBH	Building exterior 03G	003 Classrooms 3 to 8	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1899A01469	80 MBH	74.4 MBH	Building exterior 03F	003 Classrooms 3 to 8	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1699401692	80 MBH	74.4 MBH	Building exterior 03F	003 Classrooms 3 to 8	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1699A01697	80 MBH	74.4 MBH	Mechanical Room 02E	002 Classrooms 9 to 17	1
Central Split System Gas Furnace	Rheem	Inaccessible	Inaccessible	80 MBH	74.4 MBH	Mechanical M005	005 Classroom 1	1
Central Split System Gas Furnace	Carrier	58MXA080-20	2399A01237	80 MBH	74.4 MBH	Mechanical M017	004 Multipurpose, Kitchen	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1399401249	80 MBH	74.4 MBH	Furnace Room 02D	002 Classrooms 9 to 17	1
Central Split System Gas Furnace	Carrier	58MXA080-20	2399401256	80 MBH	74.4 MBH	Building exterior 03F	003 Classrooms 3 to 8	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1399A01258	80 MBH	74.4 MBH	Mechanical Room	001 Classrooms 18 to 25	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1699401691	80 MBH	74.4 MBH	Mechanical Room M009	002 Classrooms 9 to 17	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1399A01252	80 MBH	74.4 MBH	Building exterior 03F	003 Classrooms 3 to 8	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1399A91255	80 MBH	74.4 MBH	Mechanical M020	004 Multipurpose, Kitchen	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1699A01699	80 MBH	74.4 MBH	Mechanical Room M002	001 Classrooms 18 to 25	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1399A01257	80 MBH	74.4 MBH	Furnace Room 02D	002 Classrooms 9 to 17	1
Central Split System Gas Furnace	Carrier	58MXA080-20	Illegible	80 MBH	74.4 MBH	Mechanical M021	004 Multipurpose, Kitchen	1

Central Split System Gas Furnace	Carrier	58MXA080-20	1099A01155	80 MBH	74.4 MBH	Mechanical Room M024	001 Classrooms 18 to 25	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1399A01242	80 MBH	74.4 MBH	Mechanical Room 02E	002 Classrooms 9 to 17	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1099A01152	80 MBH	74.4 MBH	Furnace Room 02D	002 Classrooms 9 to 17	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1999A00938	80 MBH	74.4 MBH	Mechanical Room 02E	002 Classrooms 9 to 17	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1699A01696	80 MBH	74.4 MBH	Mechanical Room M025	001 Classrooms 18 to 25	1
Furnace	Carrier	58MXA080-20	1399A01253	80 MBH	74.4 MBH	Building exterior 03F	003 Classrooms 3 to 8	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1399A01256	80 MBH	74.4 MBH	Mechanical Room 02E	002 Classrooms 9 to 17	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1399A01248	80 MBH	74.4 MBH	Mechanical Room M004	001 Classrooms 18 to 25	1
Central Split System Gas Furnace	Carrier	58PAV070-12	4600A66918	66 MBH	53 MBH	Mechanical M003	007 Classroom 26	1
Central Split System Gas Furnace	Carrier	58MXA080-20	2299A02286	80 MBH	74.4 MBH	Mechanical M012	004 Multipurpose, Kitchen	1
Central Split System Gas Furnace	Carrier	58MXA080-20	1699A01693	80 MBH	74.4 MBH	Mechanical Room M003	001 Classrooms 18 to 25	1
Central Split System Condensing Unit	Carrier	38TRA048330	2099E02955	4 TON	-	Building Exterior	001 Classrooms 18 to 25	1
Central Split System Condensing Unit	Carrier	38TRA048330	2099E02992	4 TON	-	Building Exterior	001 Classrooms 18 to 25	1
Central Split System Condensing Unit	Carrier	38TRA048330	3098E01452	4 TON	-	Roof 03G	003 Classrooms 3 to 8	1
Central Split System Condensing Unit	Carrier	24ABR348A320	1408E02212	4 TON	-	Roof 03F	003 Classrooms 3 to 8	1
Central Split System Condensing Unit	Carrier	38TRA048330	1399E02505	4 TON	-	Roof 02D	002 Classrooms 9 to 17	1
Central Split System Condensing Unit	Carrier	38TRA048330	2099E02985	4 TON	-	Roof 02D	002 Classrooms 9 to 17	1
Central Split System Condensing Unit	Carrier	38TRA060330	2199E03630	5 TON	-	Roof	004 Multipurpose, Kitchen	1
Central Split System Condensing Unit	Carrier	38TRA048330	2099E02995	4 TON	-	Building Exterior	001 Classrooms 18 to 25	1
Central Split System Condensing Unit	Carrier	38TRA048330	0899E00887	4 TON	-	Roof 03F	003 Classrooms 3 to 8	1
Central Split System Condensing Unit	Carrier	38TRA048330	2099E02990	4 TON	-	Building Exterior	001 Classrooms 18 to 25	1
Central Split System Condensing Unit	Rheem	RAKA-036JAS	4955 F4093 8913	3 TON	-	Building exterior	005 Classroom 1	1
Central Split System Condensing Unit	Carrier	38TRA048330	2099E02999	4 TON	-	Building Exterior	001 Classrooms 18 to 25	1

Central Split System Condensing Unit	Carrier	38TRA060330	1699E04715	5 TON	-	Roof	004 Multipurpose, Kitchen	1
Central Split System Condensing Unit	Carrier	38TRA048330	1599E03982	4 TON	-	Roof 03F	003 Classrooms 3 to 8	1
Central Split System Condensing Unit	Carrier	38TRA048330	2099E03011	4 TON	-	Roof 02D	002 Classrooms 9 to 17	1
Central Split System Condensing Unit	Carrier	38TRA060330	2199E03579	5 TON	-	Building exterior	005 Classroom 1	1
Central Split System Condensing Unit	CAC/BDP	PA13NR048-J	0514X63841	4 TON	-	Building exterior 02E	002 Classrooms 9 to 17	1
Central Split System Condensing Unit	Inaccessible	Inaccessible	Inaccessible	2 TON	-	Roof	007 Classroom 26	1
Central Split System Condensing Unit	Carrier	38TRA048330	2099E02989	4 TON	-	Building Exterior	001 Classrooms 18 to 25	1
Central Split System Condensing Unit	Carrier	38TRA048330	2099E03605	4 TON	-	Building exterior 02E	002 Classrooms 9 to 17	1
Central Split System Condensing Unit	Carrier	38TRA060330	2199E03629	5 TON	-	Roof	004 Multipurpose, Kitchen	1
Central Split System Condensing Unit	CAC/BDP	PA13NR048-J	0514X63910	4 TON	-	Building exterior 02E	002 Classrooms 9 to 17	1
Central Split System Condensing Unit	Carrier	24ABR348A320	0108E11108	4 TON	-	Roof 03F	003 Classrooms 3 to 8	1
Central Split System Condensing Unit	Carrier	38TRA048330	1699E04780	4 TON	-	Roof 03F	003 Classrooms 3 to 8	1
Central Split System Condensing Unit	Carrier	38TRA036330	1899E02809	3 TON	-	Roof	004 Multipurpose, Kitchen	1
Central Split System Condensing Unit	Carrier	38TRA048330	2099E03040	4 TON	-	Roof 02D	002 Classrooms 9 to 17	1
Central Split System Condensing Unit	Carrier	38TRA048330	2099E02967	4 TON	-	Building exterior 02E	002 Classrooms 9 to 17	1

APPENDIX C:

Lighting System Schedule



										Lamp Details				Fixture Details				Existing Consumption	
Line No.	Building Name	Interior/ Exterior	Floor	Space Type	Room No.	Additional Area Description	LUX	Control Quantity	Existing Control	Technology	Sub-Technology	Lamp Type	Total Lamps	Fixture Type	Fixture Quantity	24x7 Fixture Count	Fixture Height	Annual Hours	Existing Annual kWh
1	Ethel Phillips Elementary School	Interior		CLASSROOM	110-001-0018		-	12	Light Switch	LED	-	-	96	Industrial	24	0	8	2,280	-
2	Ethel Phillips Elementary School	Interior		CLASSROOM	110-001-0018		-	12	Light Switch	LED	-	-	36	2x4 Prism Troffer	18	0	8	2,280	-
3	Ethel Phillips Elementary School	Interior		CLASSROOM	110-001-0024		-	5	Light Switch	LED	-	-	80	Industrial	40	0	8	2,280	-
4	Ethel Phillips Elementary School	Interior		CLASSROOM	110-002-0009		-	4	Light Switch	LED	-	-	64	Industrial	32	0	8	2,280	-
5	Ethel Phillips Elementary School	Interior		OFFICE	Po7		-	2	Light Switch	Linear Fluorescent	T8	4' 32W T8	48	2x4 Prism Troffer	16	0	8	2,280	3,502
6	Ethel Phillips Elementary School	Interior		STORAGE	Garage		-	1	Light Switch	Linear Fluorescent	T12	8' 96W T12	6	Strip Fixture	3	0	8	760	438
7	Ethel Phillips Elementary School	Interior		STORAGE	Garage		-	1	Light Switch	Linear Fluorescent	T12	4' 40W T12	4	2x4 Prism Troffer	2	0	8	760	122
8	Ethel Phillips Elementary School	Exterior		Walkway	Exterior		-	1	Timer	HID	MH	MH200	16	Wallpack-Horizontal	16	0	8	2,280	7,296
9	Ethel Phillips Elementary School	Exterior		Walkway	Exterior		-	1	Timer	CFL	CFL - 4 Pin	CFL42	19	Recessed Can-hor 10"	19	0	8	2,280	1,819
10	Ethel Phillips Elementary School	Exterior		Walkway	Exterior		-	1	Timer	HID	MH	MH400	4	Wallpack-Horizontal	4	0	8	2,280	3,648
Totals													373		174			19,760	16,825

APPENDIX D: ECM Checklist

NA	In Place	Evaluate	ECM Description
✓			Add Reflective Coating To Exterior Windows
		✓	Replace External Windows
	✓		Upgrade Insulation
✓			Control External Air Leakage In Commercial Buildings
✓			Install Reflective Insulation Between Radiators And External Wall
✓			Replace Existing Motors With High Efficiency Motors
✓			Install On-Demand Ventilation on Air Handlers
		✓	Reduce HVAC Hours of Operation
✓			Install Variable Frequency Drives (VFD)
✓			Install Outside Air Temperature Reset Controls For Hot Water Boilers
✓			Install Chilled Water Reset Control
		✓	Install Timers On Exhaust Fans
✓			Install Energy Savers on Vending, Snack Machines
✓			Install Building Energy Management System and Replace Terminal Units
✓			Re-Commission The Building & Its Control Systems
✓			Replace Inefficient Heating Plant
✓			Replace Inefficient Cooling Plant
✓			Replace Existing Air Conditioners with Energy Star Air Conditioners
		✓	Replace Unit Electric Heaters with Natural Gas Fired Unit Heaters
✓			Convert From Gas Pilot to Electronic Ignition for Boilers
	✓		Insulate Hot Water Pipes
	✓		Insulate Refrigerant Lines
	✓		Insulate Hot Surfaces And Tanks
✓			Insulate Air Ducts
✓			Replace Defective Steam Traps
✓			Upgrade Electric Heating System To Heat Pumps
		✓	Replace Inefficient Furnace System
		✓	Replace Rooftop Package Unit
✓			Install Energy Recovery Wheel on Air Handling Unit
		✓	Replace Existing Water Heater With New Energy Efficient Units
✓			Replace Incandescent/Halogen Lamps With Energy Efficient Lamps
✓			Upgrade Inefficient Linear Fluorescent Lamps And Fixtures
✓			Upgrade EXIT SIGNS With LED EXIT Signs
✓			Bilevel and Tandem Linear Fluorescent Lighting ECM
		✓	Replace High Intensity Discharge (HID) Lamps With Energy Efficient Lamps
✓			Replace Existing Refrigerator(s) With Energy Star Certified Refrigerator(s)
✓			Replace Existing Freezers With High Efficiency Freezers
✓			Install Low Flow Shower Heads
		✓	Install Low Flow Faucet Aerators
		✓	Install Low Flow Restroom Flush Tank Toilets
		✓	Install Low Flow Tankless Restroom Fixtures

APPENDIX E: ECM Calculations

UIC	Install Low Flow Faucet Aerators			
EAP2-b	Location: Restrooms and Classrooms			
Property Type:		Commercial	Estimated No. of Operational Weeks: 35	
			Number of Occupied Days/Week (Max 7): 5	
KITCHEN FAUCETS		BATHROOM FAUCETS		
Number of Occupants Affected By Retrofit: 580		Number of Occupants Affected by Retrofit: 580		
Do You Want To Replace Kitchen Faucets Aerators: Yes (Select)		Do You Want To Replace Bathroom Faucets Aerators: Yes (Select)		
Total Number of Faucet Aerators To Be Replaced: 18		Total Number of Faucet Aerators To Be Replaced: 18		
Total Number of Faucets To Be Replaced: 0		Total Number of Faucets To Be Replaced: 0		
GPM of Existing Faucet Aerators: 2.2 GPM		GPM of Existing Faucet Aerators: 2.2 GPM		
GPM of Proposed Faucet Aerator: 0.5 GPM		GPM of Proposed Faucet Aerator: 0.5 GPM		
Estimated Number of Uses Per Day: 2		Estimated Number of Uses Per Day: 4		
Annual Water Savings From Installing Low Flow Aerators:		99.39 kGal		
WATER & ENERGY SAVING CALCULATION		COST SAVING CALCULATION		
Select Type of Water Heater Fuel: Natural Gas (Select)		Property Location in United States: North Central Localities		
Energy Factor of Domestic Hot Water Heater: 0.54 EF		Heating Fuel Tariff: \$1.30 \$/Therm		
Hot Water Discharge Temperature at Faucet: 110.00 °F		Water Tariff (\$/1000 Gal): \$7.51 \$/kGal		
Equivalent Heating Fuel Savings: 783 Therms <small>Savings Discounted by 15% to Account For Cold Water Use</small>		Annual Cost Savings In Form of Water: \$746 \$		
Annual Water Savings: 99.39 kGal		Annual Energy Savings From Water Heater: \$1,019 \$		
COST BENEFIT ANALYSIS				
Estimated Total Annual Cost Savings: \$1,765 \$\$		Estimated Total Installation Cost: \$548 \$\$		
Simple Payback Period: 0.31 Years		Type of Recommendation: No/Low Cost ECM Recommendation		
<p>Disclaimer: PREPARED BY EMG. May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.</p> <p>ECM EXPLANATION: By reducing the flow of water coming from the restroom faucets, aerators can generate energy savings at low cost and with easy installation. The savings generated would be in the form of reduced water and sewer costs and at the same time aerators would save energy by reducing the demand for hot water. The average faucet has a flow rate of about 2 to 4 GPM. Adding a screw-in faucet aerator reduces the flow to 0.5 to 1.5 GPM in the bathroom and 2.2 GPM in the kitchen. In addition to saving energy and water, the "foamier" water that comes from faucet aerators wets objects better than water from a faucet with no aerator, which tends to bounce off the object rather than thoroughly wetting it. EMG recommends replacing the proposed faucet aerators with new low flow aerators as mentioned above. The proposed ECM shall also result in an annual energy saving in form of reduction in water heating bills.</p> <p>Summary: Initial Investment: \$548 Estimated Annual Cost Savings: \$1,765 Simple Payback Period (Yrs): 0.31</p>				

UIC		Reduce HVAC Hours of Operation	
EAC3		Location: Throughout	
No of Programmable Thermostats To Be Installed :		1	Qty.
Select Type of Programmable Thermostat Recommended: <small>(Selection Based on Type of Property)</small>		Centrally Controlled Thermostats For Multi-Unit Property -(BMS) <small>(Select)</small>	
Heating Load Calculation		Cooling Load Calculation	
Select Type of Heating Fuel	Natural Gas <small>(Select)</small>	Select Type of Cooling Fuel	Electric <small>(Default)</small>
Estimated Current Annual Energy Consumption For Winter Heating	3,870 Therms	Estimated Current Annual Energy Consumption For Summer Cooling	57,409 kWh
	Weekdays Weekends		Weekdays Weekends
Day Time Set Back Hours	6.00 10.00	Day Time Set Back Hours	6.00 10.00
Night Time Set Back Hours	8.00 10.00	Night Time Set Back Hours	8.00 10.00
Hours Without Set Back	10.00 4.00	Hours Without Set Back	10.00 4.00
Typical Indoor Temp	69.00 °F	Typical Indoor Temp	73.00 °F
Temp Set Point With Set Back During Day Time	60.00 °F	Temp Set Point With Set Back During Day Time	85.00 °F
Temp Set Point With Set Back During Night Time	60.00 °F	Temp Set Point With Set Back During Night Time	85.00 °F
Average Heating Set Point	63.11 °F	Average Cooling Set Point	80.86 °F
Savings Per Degree Set Back For Heating Season <small>(Industry Standard, 2004)</small>	3%	Savings Per Degree Set Back For Cooling Season <small>(Industry Standard, 2004)</small>	6%
Estimated Annual Heating Energy Consumption	387,000 kBtu	Estimated Annual Cooling Energy Consumption	195,880 kBtu
Estimated New Annual Heating Energy Consumption	318,584 kBtu	Estimated New Annual Cooling Energy Consumption	103,536 kbtu
Estimated Annual Heating Energy Savings	684 Therms	Estimated Annual Cooling Energy Savings	27,064 kWh
Cost Analysis			
Average Annual Cost of Heating Fuel:	\$1.30 \$/Therm	Estimated Installation Cost Per Thermostats: <small>(Includes Material, Labor & Installation Costs)</small>	\$1,070 \$\$
Average Annual Cost of Electricity:	\$0.17 \$/kWh	Total Estimated Cost For All Programmable Thermostats	\$1,597 \$\$
Estimated Annual Heating Cost Savings:	\$890 \$\$	Total Estimated Cost Savings From All Programmable Thermostats	\$5,531
Estimated Annual Cooling Cost Savings:	\$4,641 \$\$	Estimated Simple Pay Back Period	0.29 Yrs
Type of Recommendation	Capital Cost ECM Recommendation		

Disclaimer: PREPARED BY EMG. May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM DESCRIPTION:

Turning off energy-consuming systems when they are not needed is the most basic energy conservation technique. When a building is occupied intermittently, energy savings can be realized by minimizing the time the heating or cooling system is operated when the building is closed. Building control algorithms should be implemented to delay startup until the last moment and to shut down as early as possible. Because of the thermal inertia of both the building structure and its heating and cooling equipment, preheat or precool time is almost always required to raise or lower the space temperature to the desired level before the occupants return. This start-up time depends on the outdoor environment, the thermal response of the building, and the thermal performance of the space conditioning equipment. Similarly, the thermal inertia of the building maintains the indoor temperature at a comfortable level for a short period of time after the equipment is shut off. It allows the system to be turned off before the end of an occupied period. An optimum start/stop control accounts for these factors.

SUMMARY

Initial Investment:	\$1,597	Simple Payback Period:	0.29 Yrs
Annual Energy Cost Savings:	\$5,531		

UIC	Install Timers On Exhaust Fans			
EAC7A	Location: Throughout			
Type of Exhaust Fan: Rooftop Exhaust Fans				
EXISTING CONDITION				
No. of Timers to Be Installed:	3	Qty	HP of Individual Fan Motor:	0.25 HP
No. of Exhaust Fans:	5		Total kW:	0.93 kW
Existing Daily Hours of Operation/Exhaust Fan:	16.00	Hrs/Day	Annual kWh For All Fans:	5,446 kWh
PROPOSED CONDITION				
New Daily Hours With Timers/Exhaust Fan:	12.00	Hrs/Day	New Annual kWh For All Fans:	4,084 kWh
Type of Heating Fuel:	Natural Gas		Is The Property Cooled?	Yes
Only For Apt. Bathroom Exhaust Fans			Only For Roof Top Exhaust Fans- Commerical Spaces	
CFM for Individual Bathroom Exhaust Fans <i>(For bathrooms<100Sqft)</i>	90	CFM	No. of Water Closets In Building	31
Total Exhaust CFM From All Fans	450	CFM	No. of Urinals In Building	11
			Total CFM for All Restroom Exhaust	2,100 CFM
Annual Heating Energy Savings	0	kbtu	Annual Heating Energy Savings	36,288 kbtu
Annual Cooling Energy Savings	0	kbtu	Annual Cooling Energy Savings	18,144 kbtu
Energy & Cost Savings				
Estimated Annual Heating Plant Efficiency	79.00	%	Estimated Annual Cooling Plant Efficiency	7.00 EER
Annual Heating Energy Savings	459	Therms	Annual Cooling Energy Savings	2,592 kWh
Annual Electric Fan Motor Savings	1,361	kWh		
COST ANALYSIS				
Electric Rate:	\$0.17	\$/kWh	Total Annual Electric Savings	3,953 kWh
Material Cost For Timers:	\$508	\$	Total Annual Non Electric Savings	459 Therms
Total Cost for Installing Timers	\$1,062	\$	Annual Cost savings:	\$1,276 \$
Simple Payback:	0.83	Yrs		
Type of Recommendation	Capital Cost ECM Recommendation			

Disclaimer: PREPARED BY EMG. May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG Corp. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM DESCRIPTION:

Exhaust fans are generally used in areas with high concentrations of pollutants generated from occupants' activities. These exhaust requirements are rarely continuous, and the fans should operate only as needed. Continuous operations of bathroom exhaust fans results in exhausting conditioned air out. This causes low pressures in the conditioned space, which is filled up by infiltrated air from unconditioned spaces. Air infiltration leads to increase loads on heating and cooling system increasing the energy consumed to condition the space. In addition to this the fan motor is also consumes energy to operate, though insignificant as compared to the HVAC losses.

In case of the residential properties with individual exhaust fans in the bathrooms, EMG recommends installing timer switches on each bathroom fan to control the fan operations. Bathroom fans are essential to exhaust out the excess humidity and odor control. The timer switch will limit the operation time to 20 mins.

In case of central exhaust systems that have roof top or side wall mounted exhaust fans, EMG recommends a single electronic timer control to restrict the exhaust fan operations to typical building occupancy hours +/- 2 hrs. A single electronic timer would be able to control all the exhaust fans.

Summary:

Initial Investment:	\$508	Simple Payback:	0.83	Years
Energy Cost Savings:	\$1,276			

UIC	Install Low Flow Restroom Flush Tank Toilets		
EAP3	Location: Restrooms and Locker Rooms		
EXISTING CONDITION			
Total Occupants:	<input type="text" value="580"/>		
Number of Water Closets To Be Replaced	<input type="text" value="6"/>		
Number of Occupied Days Per Week (Max 7)	<input type="text" value="5"/>		
Number of Occupied Weeks/Year (Max 52)	<input type="text" value="35"/>		
Estimated Restroom Usage/Individual/Day	<input type="text" value="4"/>	(Select)	
<small>5.05 flushes/person/day@American Water Works Association (AWWA)</small>			
PROPOSED RETROFIT/REPLACEMENT			
Existing Gallons Per Flush Ratings For Water Closet Flushes	<input type="text" value="1.60"/> GPF		
Replace or Retrofit Toilets With Dual Flush Toilets	<input type="text" value="Replace"/>		
Replace			
Proposed Toilet	<input rough-in"="" type="text" value="0.8GPF -Floor Mount, 10"/>		
GPF of Proposed New Low Flow Water Closet Fixture*	<input type="text" value="0.80"/> GPF		
Retrofit			
Dual Flush - Retrofit Setup Valve for Flush Tank Toilet	<small>Solid Waste (20%)</small>	<input type="text" value="0.80"/>	GPF
	<small>Liquid Waste (80%)</small>	<input type="text" value="0.80"/>	GPF
<small>*(Federal Law Requires All Flushes Not To Exceed 1.6 GPF)</small>			
Water & Cost Saving Calculations			
Water Savings By The Use of Low Flow Water Closet Flush Valves/Day	<input type="text" value="1,856.00"/> gal		
Total Annual Water Savings in gallons	<input type="text" value="324.80"/> kgal		
Cost Savings Calculations			
Enter Water Tariff Rate (\$/1000Gal)	<input type="text" value="\$7.51"/> \$\$		
Estimated Cost Savings From Water	<input type="text" value="\$2,439"/> \$\$		
Estimated Cost of Retrofit			
Estimated Total Cost For Retrofit	<input type="text" value="\$5,692"/> \$\$		
Simple Pay Back Period	<input type="text" value="2.33"/> Yrs		
Type of Recommendation	<input type="text" value="Capital Cost ECM Recommendation"/>		

Disclaimer: PREPARED BY EMG. May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM EXPLANATION:

The highest water utilization at any home/office occurs in the restrooms. It is estimated that on an average a normal human being uses the restroom at least four times a day. Keeping with the global water conservation objectives, federal law prohibits use of any new water closet flushes over 1.6 GPF.

Existing toilets can be retrofitted with pressure-assisted flush technology to reduce the flush rate to 1.0 GPF or less. Though water efficient these toilets make considerable amount of noise as this involves release of pressurized air during the course of flushing. Thus making them unpopular among residential properties.

Thus EMG recommends replacing the existing high flow toilets with new low flow 1.28GPF rated flush tank toilets, which are comparatively more water efficient at the same time considerably quieter as compared to the pressure assisted technology retrofitted toilets.

Summary:

Initial Investment:	\$5,692	Simple Payback:	2.33	Years
Annual Cost Savings	\$2,439			

UIC	Upgrade Building Lighting to LED and Install Automatic Lighting Controls
EAL10	Location: Building Interior and Exterior

	No. of ECMs	No. of Fixtures	No. of Lamps	KWh Saved	Energy Cost Saving	O & M Savings
Upgrade Lighting to LED	5	41	78	9,705	\$1,664.44	\$244.49

Existing Technology	Sub- Technology	No. of ECMs	No. of Fixtures	No. of Lamps	KWh Saved	Energy Cost Saving	O & M Savings
CFL	CFL - 2 Pin	0	0	0	0	\$0	\$0
CFL	CFL - 4 Pin	0	0	0	0	\$0	\$0
CFL	CFL - Screw-in	0	0	0	0	\$0	\$0
Circiline	T9	0	0	0	0	\$0	\$0
Incan/H/MR	H	0	0	0	0	\$0	\$0
Incan/H/MR	Incan	0	0	0	0	\$0	\$0
Incan/H/MR	MR	0	0	0	0	\$0	\$0
HID	HPS	0	0	0	0	\$0	\$0
HID	MH	2	20	20	7,752	\$1,329	\$157
HID	MV	0	0	0	0	\$0	\$0
HID	QL	0	0	0	0	\$0	\$0
Linear Fluorescent	T8	1	16	16	1,642	\$282	\$74
Linear Fluorescent	T12	2	5	5	312	\$53	\$14
Linear Fluorescent	T8 U	0	0	0	0	\$0	\$0
Linear Fluorescent	T12 U	0	0	0	0	\$0	\$0
Linear Fluorescent	T5	0	0	0	0	\$0	\$0
Linear Fluorescent	T6	0	0	0	0	\$0	\$0
Linear Fluorescent	T10	0	0	0	0	\$0	\$0

Proposed Controls	No. of Controls		No. of Controls
Photo Sensor	2	Ceiling Mounted	4
Wall Mounted	0		

Initial Investment		Equipment Rentals	
Material Cost	\$7,509.28	Scissor Lift 26' - Interior Space	\$0.00
Labor Cost	\$2,659.01	Bucket Truck - Exterior Space:	\$0.00
Local Electric Rate:	\$0.17 \$/kWh	Estimated Annual Energy Savings:	9,705
Hourly Labor Rate For Electrician:	\$72.40	Estimated Annual Energy Cost Savings:	\$1,664
Budgeted Initial Investment:	\$10,168	Estimated Annual O&M Cost Savings:	\$244
Estimated Return on Investment: (Including O&M Savings)	5.33 Years	Estimated Annual Cost Savings:	\$1,909

UIC	Install Low Flow Tankless Restroom Fixtures		
EAP4	Location: Restrooms		
ECM FOR DETERMINING WATER SAVINGS IN COMMERCIAL PROPERTIES			
Number of Males	290		
Number of Females	290		
Number of Occupied Days Per Week (Max 7)	5		
Number of Occupied Weeks/Year (Max 52)	35		
Number of Urinals To Be Retrofitted	11		
Number of Water Closets To Be Retrofitted	31		
No. of Water Closets With Separate Flush Tank <small>(Typical Residential Type)</small>	6		
Estimated Restroom Usage/Individual/Day	4	(Select)	
<small>Default is 4 Uses/Day For Residential/Office</small>			
Urinal Water Savings			
Do you Want To Make Any Changes To The Urinals?	No		
Estimated Existing Use of Urinal/Day/Man	80%		
Existing Gallons Per Flush Ratings For Urinal Flushes	1.00	GPF	
Proposed Urinal	0.125 GPF-Wall Mount		
GPF of Proposed Urinal Flush Valve**	0.125	GPF	
<small>**1992 EpACT Energy Act Mandates 1.0GPF Max on Urinals</small>			
Estimated Annual Water Savings From Urinal	0.00	kGal	
Water Closet Water Savings			
Tankless Water Closets			
Do The Water Closet Need To Be Retrofitted?	(Select) Yes		
Existing Gallons Per Flush Ratings For Water Closet Flushes	1.60	GPF	
Are The Existing Water Closet Being Replaced?	(Select) No		
<small>(If No; Then Only The Flush Valve Would Be Replaced With Dual Flush Retrofit Kit)</small>			
No. of Tankless Water Closets	25		
GPF of Proposed Dual Flush- Water Closet Valve*	Solid Waste (20%) 1.60	GPF	
	Liquid Waste (80%) 0.48	GPF	
<small>*Federal Law Requires All Flushes Not To Exceed 1.6 GPF</small>			
Estimated Annual Water Savings From Male Users	181.89	kGal	
Estimated Annual Water Savings From Female Users	181.89	kGal	
Total Water Savings From Water Closets	363.78	kGal	
Water & Cost Saving Calculations			
Water Savings Calculation			
Water Savings By The Use of Low Flow Water Closet Flush Valves/Yr	363.78	kGal	
Water Savings By The Use of Low Flow Urinal Flush Valves/ Yr	0.00	kGal	
Total Annual Water Savings in kGal	363.78	kGal	
Cost Savings Calculations			
Enter Water Tariff Rate (\$/1000Gal)	\$7.51	\$	
Estimated Cost Savings From Water	\$2,732	\$	
Estimated Cost of Retrofit			
Cost For Replacing Existing Urinal Fixture With A Low Flow Fixture	\$0	\$	
<small>(Includes Labor)</small>			
Cost For Replacing Existing Flush Valves With Low Flow - Dual Flush Valves (\$80 Per Unit)	\$19,190	\$	
<small>(Up For Liquid Waste And Down For Solid Waste)</small>			
Estimated Total Cost For Retrofit	\$19,190	\$	
Simple Pay Back Period	7.02	Yrs	
Type of Recommendation	Capital Cost ECM Recommendation		

Disclaimer: PREPARED BY EMG, May2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM EXPLANATION:

The highest water utilization at any home/office occurs in the restrooms. It is estimated that on an average a normal human being uses the restroom at least four times a day. Keeping with the global water conservation objectives, federal law prohibits use of any new water closet flushes over 1.6 GPF. At the same time the '1992 EpACT' mandates all new Urinals to have a maximum 1.0 GPF flush valves on urinals.

EMG recommends replacing all urinals above 1.0 GPF with a new 0.5 GPF or lesser urinals. At the same time EMG also recommends replacing all the water closets having a GPF rating of 1.6 and over with low flow water closet fixtures equipped with dual flush valves.

In case the property doesn't wish to replace the entire water closet fixtures, EMG recommends retrofitting all the tankless water closet flush fixtures with new dual flush fixtures that would result in a 30% water savings per flush for liquid wastes, while retaining the same flush rate for solid wastes.

SUMMARY:

Initial Investment:	\$19,190	Simple Payback Period:	7.02 Yrs
Annual Cost Savings:	\$2,732		

UIC	Replace Existing Water Heater With New Energy Efficient Units				
EAD3	Location: Building 004				
Step 1	Existing Water Heater Details	Janitor -J037	Utility Closet	Utility Closet	Specify Location Here
	Number of Water Heaters Being Replaced:	1			
	Select Existing Hot Water Heater Fuel	Natural Gas	Natural Gas	Natural Gas	Electric
	Insert Energy Factor of Existing Water Heater	0.52 EF			
	Input Existing Water Heater Input Rating	40.00 kBTus			
	Select One Method For Calculation	Annual Heating Hours	Annual Heating Hours	Annual Heating Hours	Annual Heating Hours
	Insert Average Annual Hours of Operation	972 hrs			
	Annual Water Heater Energy Consumption/Heater	389 Therms	0 Therms	0 Therms	0 kWh
	Total Estimated Annual Energy Consumption For all Heaters	389 Therms	0 Therms	0 Therms	0 kWh
	Total Estimated Annual Operating Energy Costs For all Heaters	\$506 \$	\$0 \$	\$0 \$	\$0 \$
Step 2	Proposed New Water Heater				
	Proposed Hot Water Heater Fuel	Natural Gas	Natural Gas	Natural Gas	Natural Gas
	Capacity of the Proposed New Water Heater	50-Gal,40-kBTu			
	Energy Factor of Proposed Water Heater	0.70 EF	0.00 EF	0.00 EF	0.00 EF
	Proposed Water Heater Input Rating	40.00 kBTuh	0.00 kBTuh	0.00 kBTuh	0.00 kBTuh
	Annual kBTuh Consumption For All The Proposed Water Heaters	28,882 kBTuh	#DIV/0! kBTuh	#DIV/0! kBTuh	#DIV/0! kBTuh
	Estimated Annual Water Heater Fuel Consumption (All Heaters)	289 Therms	0 Therms	0 Therms	0 Therms
	Estimated Total Annual Energy Costs	\$376 \$	\$0 \$	\$0 \$	\$0 \$
Step 3	Energy & Cost Saving Calculation				
	Estimated Cost of New Water Heater/Unit	\$1,150 \$	\$0 \$	\$0 \$	\$0 \$
	Total Estimated Installation Cost	\$1,716 \$	\$0 \$	\$0 \$	\$0 \$
	Total Estimated Annual Cost Savings	\$130 \$	\$0 \$	\$0 \$	\$0 \$
	Total Annual Cost Savings:	\$130	Total Initial Investment::	\$1,716	
	Simple Pay Back Period	13.19			
	Type of Recommendation	Capital Cost ECM Recommendation			

Disclaimer: PREPARED BY EMG, DECEMBER 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM SUMMARY:

Electric resistance is the most expensive method for heating domestic hot water. A natural gas or propane fired water system provide more units of heat with direct burning of fuel while high wattage draw is required for electric water heaters to create resistance heat. This electric usage can be seen with the increase power demand for the site and the additional kWh consumption. The installation process of the gas/propane fired water heater requires additional measures with tying a gas line or fuel tank to the system along with installing an exhaust gas vent. This process is not a costly retrofit if a current gas line or tank is at the site. The hot water exhaust duct can be tied to the existing gas fired furnaces or boilers for an easy retrofit.

SUMMARY:

Initial Investment: \$1,716 Simple Payback: 13.19 yrs
Annual Cost Savings: \$130

UIC	Upgrade Electric Heating System To Heat Pumps
EAH11-A	Location: Portable Classrooms

ASHRAE Climatic Zone:	Zone-3	Portable Classrooms	Specify Location Here	Specify Location Here	Specify Location Here
Select Existing Heating System Type	Heat Pump - Split System	PTAC	PTAC	PTAC	PTAC
Number of Existing Systems:	7 Qty				
Output Capacity of Heating System/Unit:	17,065.00 btuh				
Output Capacity of Heating System:	17,065 Btuh	0 Btuh	0 Btuh	0 Btuh	
Existing COP of Heating System:	3.00 COP				
Estimated Annual Heating Hours:	950 Hrs				
Auxiliary Heating In Heatpumps:	5 kW				
Cooling Capacity of Each System:	48,000 Btuh				
Existing EER of Cooling System:	8.70 EER				
Estimated Annual Cooling Hours:	680 Hrs				
Install Programmable Thermostats With Heatpumps:	No	Yes	Yes	Yes	
Current Energy Consumption From Cooling:	26,262 kWh	0 kWh	0 kWh	0 kWh	
Current Energy Consumption From Heating:	15,519 kWh	0 kWh	0 kWh	0 kWh	
Total Existing Electric Consumption:	41,781 kWh	0 kWh	0 kWh	0 kWh	

Proposed System

Heat pump Type	Air-Source Split Heat Pump System	Air-Source PTHP System	Water-Source System	Water-Source System
Proposed Number of Systems:	7 Qty	1 Qty	2 Qty	
Proposed Heat pump Capacity:	42,000 Btuh	- Btuh	- Btuh	- Btuh
Proposed COP:	3.72 COP	- COP	- COP	- COP
Proposed Emergency Heat Rating:	12.31 kW	0.00 kW	0.00 kW	0.00 kW
Proposed Energy Consumption From Cooling:	15,757 kWh	0 kWh	0 kWh	0 kWh
Proposed Energy Consumption From Heating:	18,887 kWh	0 kWh	0 kWh	0 kWh
Total Proposed Electric Consumption:	34,645 kWh	0 kWh	0 kWh	0 kWh
Total Electric Savings:	7,137 kWh	0 kWh	0 kWh	0 kWh
Total Cost For Replacement:	\$24,366.96	\$0.00	\$0.00	\$0.00
Annual Energy Cost Savings:	\$1,224	\$0	\$0	\$0
Individual Simple Payback	19.91 Yrs	- Yrs	- Yrs	- Yrs
Total Initial Investment:	\$24,366.96	Total Annual Electric Savings		7,137 kWh
Total Annual Cost Savings	\$1,223.69	Overall Simple Payback Period:		19.91 Yrs

UIC		Replace External Windows	
EAE2		Location: Buildings 001, 002, 003, 004, 005, 007 & P01-P06	

ENTER EXISTING CONDITIONS			
Existing and Proposed Window Properties		Existing & Proposed Air Leakage Through Windows	
Total Sq.Ft window area:	10,536 sq.ft	Insert Existing Estimated Air Change Rate/Hr (ACH 1):	1.25
Approximate number of windows:	448	(Existing Air Changes Per Hour, 1.5 is very leaky and 0.35 ideal)	
Total existing window area:	10,536 Sq.Ft	Insert Proposed Estimated Air Change Rate/Hr (ACH 2):	0.88
Select The Existing Window Type	Metal Frame & Single Glazing (Select)	Estimated Space Volume Under Consideration	398,979.00 Cu. Ft
Existing U-value of window: (1/R)	1.31 Btu/ ft ² ·F·h		
ASHRAE Climatic Zone	Zone-3	Is the Property Cooled ?	Yes (Select)
New U-value with Double pane Low E window: (1/R)	0.35 Btu/ ft ² ·F·h		
ASHRAE 90.1 Recommended Value			
WINTER		SUMMER	
Select Type of Heating Fuel	Natural Gas (Select)	Select Type of Cooling Fuel:	Electric (Default)
Net heating plant & distribution system efficiency:	79.00 %	Cooling Plant Efficiency (EER):	7.00 EER
Annual Heating Hours:	2,963 HDD	Annual Cooling Hours:	1,407 CDD
Estimated Total Annual Input Heating Energy Savings By Replacing Windows	91.05 Therms	Annual Total Input Cooling Fuel Savings During Summer Season By Replacing Windows	48,793 kWh
Estimated Total Annual Input Heating Energy Savings Achieved By Controlling Air Leakage Through Windows	2,424 Therms	Estimated Total Annual Input Cooling Energy Savings Achieved By Controlling Air Leakage Through Windows	12,992 kWh
Estimated Total Input Heating Fuel Savings From Replacing Windows	2,515 Therms	Estimated Total Input Cooling Fuel Savings From Replacing Windows	61,784 kWh
ENERGY & COST ANALYSIS			
Insert Cost of Heating Fuel:	\$1.30 \$/Therm	Annual Heating Cost Savings:	\$3,273.39 \$\$
Insert Cost of Cooling Fuel:	\$0.17 \$/kWh	Annual Cooling Cost Savings:	\$10,593.96 \$\$
Total Annual Cost Savings	\$13,937	Total Annual Cost Savings From Heating & Cooling:	\$13,867 \$\$
Cost of window upgrade:	\$367,768	Estimated Annual O&M Savings	\$69 \$
Simple payback:	26.39 Yrs	Type of Recommendation	Capital Cost ECM Recommendation

Disclaimer: PREPARED BY EMG. May 2016, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.

ECM DESCRIPTION:											
<p>Windows play a major role in the energy use and comfort of an interior space. In the winter, heat in a room is lost when cold outside air infiltrates around the edges of windows. Heat also can be lost by conduction directly through the pane, even if the window fits tightly. Windows with insulated panes, such as those filled with Argon address this issue, while proper caulking and sealant address the infiltration issue. The cold drafts and the chilly windowpane make the room uncomfortable. Windows also can help to heat a room by letting the sun's rays enter. While this solar radiation is beneficial in the winter, it can be a major source of discomfort in hot, summer climates. Energy Star rated windows with Low-E glazing are designed to keep the solar heat gain minimized during the summer months. Choosing a replacement window that fits properly has the desired U-value, and proper glazing characteristics is critical to energy conservation through window upgrades.</p>											
<p>Summary:</p> <table> <tr> <td>Initial Investment:</td> <td>\$367,768</td> <td>Simple Payback</td> <td>26.39 Yrs</td> </tr> <tr> <td>Annual Energy Cost Savings:</td> <td>\$13,937</td> <td></td> <td></td> </tr> </table>				Initial Investment:	\$367,768	Simple Payback	26.39 Yrs	Annual Energy Cost Savings:	\$13,937		
Initial Investment:	\$367,768	Simple Payback	26.39 Yrs								
Annual Energy Cost Savings:	\$13,937										

UIC	Replace Inefficient Furnace and Air Conditioning System			
EAH12-A	Location: Throughout			
Estimated Annual Cooling Hours:		680	Hrs	Estimated Annual Heating Hours:
Are The Condensing Units Being Replaced		Yes		Replace Furnace? Yes Heating Fuel: Natural Gas
Existing Cooling System		Existing Heating System		
No. of Cooling Plants To Be Replaced:		26		No. of Furnaces To Be Replaced:
Input the Btu/Hr of the air conditioner:		48,000		Input the MBH Rating of the Furnace:
Input Existing EER of the Air Conditioner:		8.59		Input Existing AFUE for the Furnace:
Estimated Current Annual Energy Consumption For Cooling:		98,794	kWh	Estimated Annual Current Energy Consumption For Heating:
(For All Units)		(For All Units)		
Proposed Cooling System		Proposed Heating System		
Input the Btu/Hr of the Proposed Air Conditioner:		48,000	Btuh	Proposed Furnace: Gas Fired -75MBH
Input EER of the Proposed Air Conditioner:		12.00		Input AFUE for the Proposed Furnace:
Estimated Annual Energy Consumption With New AC's		2,720	kWh	Estimated Annual Energy Consumption With New Furnace
(For One Unit)		(For One Unit)		
Energy & Cost Savings From New Cooling System		Energy & Cost Savings From New Heating System		
Estimated Annual Energy Savings From New Cooling System:		28,074	kWh	Estimated Annual Energy Consumptions From New Heating System:
(Total)		(Total)		
Average Electric Rate:		\$0.17	\$/kWh	Average Heating Fuel Cost For New Furnace:
Estimated Annual Cost Savings From Cooling:		\$4,814		Estimated Annual Cost Savings From Heating:
Estimated Cost of New Condensing Unit:		\$87,100		Estimated Cost of New Furnace Unit:
(Material + Installation+Labor)		(Material + Installation+Labor)		
Estimated Cost of New Evaporator Coils In Furnace:		\$27,820		Estimated Total Cost of New Furnace Unit:
(Material + Installation+Labor)		(Material + Installation+Labor)		
Total Estimated Installed Cost For A New Air Conditioning System Setup + New High Efficiency Furnace :		\$222,038	\$\$	
(Includes Location Factor)				
Estimated Total Energy Cost Savings From New HVAC System:		\$4,899	\$\$	Estimated O&M Savings: \$245 Total Annual Savings: \$5,144
Estimated Simple Pay Back Period:		43.16	Years	
Type of Recommendation		Capital Cost ECM Recommendation		

UIC	Replace Rooftop Package Unit						
EAH12-B	Location: Building 001						
Estimated Annual Cooling Hours:		680	Hrs	Estimated Annual Heating Hours:	175	Hrs	
Units to Replace	Air Conditioning	Heating System	Existing Type of Heating Fuel:		Natural Gas		
	Yes	Yes					
Existing Package System							
Number of Package Units to be Replaced:		Cooling	Heating	Total Combined Units			
		5	5	5			
Capacity of the air conditioner:		4	Tons	EER of the Existing Air Conditioner:		12.25	
Capacity of Existing Heating System:		72	MBH	Input Existing AFUE for the Furnace:		80%	
Estimated Annual Cooling Consumption: <small>(For All Units)</small>		13,322	kWh	Estimated Annual Heating Consumption : <small>(For All Units)</small>		788	Therms
Proposed Package System							
Capacity of the Proposed Air Conditioner:		4	Tons	EER of the Proposed Air Conditioner:		12.25	EER
Capacity of Proposed Heating System:		Gas Fired -60MBH	MBH	AFUE of Proposed Heating System:		90%	%
Estimated Annual Energy Consumption With New Package Units							
Annual Electric Fuel Consumption:		13,322	kWh	Annual Heating Fuel Consumption:		583	Therms
Energy and Cost Analysis							
Average Electric Rate:		\$0.17	\$/kWh	Average Heating Rate:		\$1.30	\$/Therm
Estimated Annual Electric Savings : <small>From All New Package Systems</small>		0	kWh	Estimated Annual Heating Savings : <small>From All New Package Systems</small>		20,417	kBtus
Annual Electric Cost Savings: <small>From All New Package Systems</small>		\$0		Annual Electric Cost Savings: <small>From All New Package Systems</small>		\$266	\$
Proposed Type of System to be installed:		Package Heating and Cooling System					
Estimated Material and Labor Cost Including Overheads and Profits For All Units:						\$26,260.00	\$
Estimated Total Energy Cost Savings From New HVAC System:						\$266	\$
Estimated O&M Savings:						\$13	
Estimated Simple Pay Back Period:		94.1249916	Yrs	Capital Cost ECM Recommendation			

APPENDIX F:

Solar PV

UIC		Install Fixed Tilt Solar Photovoltaic System													
EAR-2		Details: Ethel Phillips Elementary													
Select State:		Northern California		Electric Rate:		\$0.17		\$/KWH		Annual Electric Consumption:		288,487		KWh	
Roof No.	Description	Number of Roofs	DC System Size Per Roof	PV System Sizing For All Roofs	Estimated Number of 315 Watt PV Panels:	Total Estimated Annual Electricity Generated/ Roof	Total Estimated Electricity Generated (All Roofs)	Total Cost Savings	Installation Cost: (\$3.5/Watt)	Simple Pay Back Period without Incentives	One Time Potential Utility or State Incentives	One Time Potential Federal Incentives	Annual Potential Incentives and Rebates		Simple Pay Back Period with All Incentives
			kW	kW		kWh	kWh			Yrs		Dept. of Treasury Renewable Grant (30%)	Federal REPI Incentive	Solar Renewable Certificates (SRECS)- (~\$0/MWH)	Years
												30%	\$0.02	\$0	
1	Building 1	1	15.50	16	49	24,084	24,084	\$4,130	\$54,250	13.1	\$0	\$16,275	\$530	\$0	7.9
2	Building 2	1	17	17	53	25,948	25,948	\$4,450	\$58,450	13.1	\$0	\$17,535	\$571	\$0	7.9
3	Building 3	1	38	38	121	59,044	59,044	\$10,126	\$133,000	13.1	\$0	\$39,900	\$1,299	\$0	7.9
4	Building 4	1	14	14	44	21,753	21,753	\$3,731	\$49,000	13.1	\$0	\$14,700	\$479	\$0	7.9
5				0	0		0	\$0	\$0		\$0	\$0	\$0	\$0	
6				0	0		0	\$0	\$0		\$0	\$0	\$0	\$0	
7				0	0		0	\$0	\$0		\$0	\$0	\$0	\$0	
8				0	0		0	\$0	\$0		\$0	\$0	\$0	\$0	
9				0	0		0	\$0	\$0		\$0	\$0	\$0	\$0	
10				0	0		0	\$0	\$0		\$0	\$0	\$0	\$0	
		4		84	267	130,829.0	130,829	\$22,437	\$294,700	13.13	\$0	\$88,410	\$2,878	\$0	7.91

Solar Rooftop Photovoltaic Analysis	
Total Number of Roofs	4
Estimated Number of Panels	267
Estimated KW Rating	84
Potential Annual KWh Produced	130,829
% of Current Electricity Load	45.4%

KW

KWh

Financial Analysis	
Investment Cost	\$294,700
Estimated Energy Cost Savings	\$22,437
Potential Rebates	\$88,410
Potential Annual Incentives	\$2,878
Payback without Incentives	13.1
Incentive Payback but without SRECS	7.9
Payback with All Incentives	7.9

years

years

years

Disclaimer: PREPARED BY EMG. JANUARY 2017, INFORMATION CONTAINED IN THIS DOCUMENT IS PRIVILEGED AND CONFIDENTIAL "TRADE SECRET" AND IS THE SOLE PROPERTY OF EMG CORP. THIS MATERIAL MUST BE CONSIDERED PRIVILEGED AND CONFIDENTIAL BY ALL PARTIES PRIVY.