DS SERIES PROBE DIMENSION

APPROVAL SHEET 5 TEMPERATURE LEVEL PROBE

97

CUSTOMER	Final Probe Tank Fitting 4" or 2" NPT (Black Cap shown)
PO#	4" Minimum Clearance Cable Assembly (shown disconnected)
ISS#	Riser Height Minimum 12"
SHIP DATE	Null Zone 8" See note 1 Spacer Brackets
QUANTITY	
PRODUCT	
FLOATS 1 Float (product only) 2 Floats (product and water)	*Overall Length
TANK OPENING 2 Inch 4 Inch	"D" (Horizontal tanks use tank dia. / Vertical tanks use tank
	height/fill height See note 2
	Water Float
D =	OMER Cathodic Boot Foot Adaptor
*Overall Length = "D" dimension + "	Tank Bottom Note 1: Level can not be detected within the dead band or null zone.
	Note 2: Temperature sensors are spaced equally over range specified.

 Name:
 Company:

 Signature:
 Date:

<u>IMPORTANT</u>: The signature above confirms the buyer's acceptance of all the dimensions contained in this document and authorizes OMNTEC to release order for production.

Note: Current published specifications are subject to change without notification. Verify specifications with manufacturer.