



## ADOPTION OF THE PROPOSED 2020 TIERED NATIONAL BUILDING CODE OF CANADA IN ONTARIO PART 9.36



[WWW.BUILDINGKNOWLEDGE.CA](http://WWW.BUILDINGKNOWLEDGE.CA)


1

### WHAT IS NBC 9.36 2020 ???

Think of it as the same as SB-12

Options for Compliance:

1. Prescriptive Minimums:
  - Building envelope, HVAC, Water heating
  - Different packages for HRV or not
  - Different packages for Climate Zones 3-8
2. Tiered Prescriptive – must achieve 'ECM' points (like EnergyStar BOP's)
3. Tiered Performance:
  - Proposed vs. reference house approach using simulation software such as HOT2000 or other software that is compliant with 9.36.5
  - EnerGuide Option – Use Hot2000 to confirm compliance (Code Compliance Tab)



[WWW.BUILDINGKNOWLEDGE.CA](http://WWW.BUILDINGKNOWLEDGE.CA)


3

# Overview of Proposed Adoption of NBC 9.36 in Ontario

1. Tiered **Prescriptive** Path
    - Must meet Tier 3 = **20** Energy Conservation Points (think ENERGYSTAR BOP)
  2. Tiered **Performance** Path
    - Must meet Tier 3 = **20%** Lower Energy, **10%** Lower Heat Loss, and same or lower design heat loss
  3. Tiered **Performance** w/ERS
    - Alignment with EnerGuide for Performance Modelling = Check target in Hot2000
- *Airtightness Testing as option in Performance and Prescriptive*
  - *Tier 4 and Tier 5 are not mentioned!*
  - *HRV/ERV's are not mandatory*
  - *Drainwater heat recovery is not mandatory*

## Climate Zones

- Reference minimums change with Climate Zone
- ECM Points change too
- See Division B - Appendix C – Table C-2 “Climatic Design Data for Selected Locations in Canada” for most cities in Canada



## OPTION #1: Tiered Prescriptive Path 9.36.7 : point based picklist

### Wall ECM Points

- Approach uses energy conservation measures which have energy conservation points.
- Similar to the ENERGY STAR for New Homes prescriptive BOPs, builders choose sufficient measures such that sum of points meets the Tier target.
- Approach enables flexibility and is easy to extend by including new measures in the future.
- HRVs are mandatory in this path, all other measures are optional

Energy Conservation Measures for Above-Ground Walls – Minimum Effective RSI Values, (m <sup>2</sup> ·K)/W	Heating Degree-Days of Building Location, in Celsius Degree-Days					
	Zone 4 ≤ 3000	Zone 5 3000 to 3999	Zone 6 4000 to 4999	Zone 7A 5000 to 5999	Zone 7B 6000 to 6999	Zone 8 ≥ 7000
	Energy Conservation Points					
2.97	2.0	=	=	=	=	=
3.08	3.2	1.4	1.6	2.1	=	=
3.69	7.4	5.4	6.2	6.7	5.4	5.2
3.85	8.2	6.0	6.9	7.4	6.2	6.0
3.96	8.9	6.8	7.7	8.2	7.0	6.8
4.29	10.2	8.1	9.2	9.7	8.6	8.4
4.40	10.8	8.7	9.9	10.3	9.3	9.1
4.57	11.4	9.3	10.6	11.1	10.1	9.9
4.73	11.9	9.7	11.1	11.5	10.6	10.4
4.84	12.3	10.2	11.6	12.1	11.2	10.9
5.01	12.9	10.7	12.2	12.7	11.8	11.6
5.45	14.0	11.9	13.6	14.0	13.3	13.1

## Window ECM Points

Energy Conservation Measures for Fenestration and Doors (1)		Heating Degree-Days of Building Location, in Celsius Degree-Days					
Energy Conservation Measures for Fenestration and Doors (2) – Maximum U-values, W/(m <sup>2</sup> ·K)	Minimum Energy Ratings (3)	Zone 4 < 3000	Zone 5 3000 to 3999	Zone 6 4000 to 4999	Zone 7A 5000 to 5999	Zone 7B 6000 to 6999	Zone 8 ≥ 7000
		Energy Conservation Points					
1.610	25	1.9	1.8	–	–	–	–
1.440	29	3.8	3.6	1.6	1.8	–	–
1.220	34	6.9	7.0	4.6	5.5	3.2	3.4

## Below Grade Wall ECM Points

Energy Conservation Measures for <i>Foundation</i> Walls – Minimum Effective RSI Values, (m <sup>2</sup> ·K)/W	Heating Degree-Days of <i>Building</i> Location, in Celsius Degree-Days					
	Zone 4 < 3000	Zone 5 3000 to 3999	Zone 6 4000 to 4999	Zone 7A 5000 to 5999	Zone 7B 6000 to 6999	Zone 8 ≥ 7000
	Energy Conservation Points					
2.98	1.7	–	–	–	–	–
3.09	1.8	0.2	0.2	0.2	0.2	–
3.46	2.2	0.6	0.8	0.6	0.7	–
3.90	2.6	1.2	1.4	1.1	1.3	–

8

## Airtightness ECM Points

- 9.36.6.3-**A**
- 9.36.6.3-**B**

Energy Conservation Measures for Airtightness – Airtightness Levels <sup>(1)</sup>	Heating Degree-Days of <i>Building</i> Location, in Celsius Degree-Days					
	Zone 4 < 3000	Zone 5 3000 to 3999	Zone 6 4000 to 4999	Zone 7A 5000 to 5999	Zone 7B 6000 to 6999	Zone 8 ≥ 7000
	Energy Conservation Points					
Airtightness Levels from Table 9.36.6.43.-A (PCF 1610)						
AL-1A	–	–	–	–	–	–
AL-2A	2.0	3.4	3.5	4.6	6.1	6.1
AL-3A	4.0	6.7	7.0	9.3	12.1	12.11
AL-4A	5.9	10.1	10.5	13.9	18.0	18.0
AL-5A	7.6	13.0	13.4	17.8	22.7	22.7
Airtightness Levels from Table 9.36.6.43.-B (PCF 1610)						
AL-1B	–	–	–	–	–	–
AL-2B	–	–	–	–	–	–
AL-3B	2.2	3.0	3.5	4.6	4.1	4.6
AL-4B	4.0	6.0	6.9	9.1	8.2	9.3
AL-5B	6.0	9.1	10.4	13.6	12.3	14.2
AL-6B	7.7	11.6	13.3	17.4	15.6	18.2

9

# Air Tightness Targets

Table [9.36.6.4.-A]

Air-Leakage-Rates Airtightness Levels for Single Zones Tested Using the Guarded or and Unguarded-Parameter-and-for Attached Zones Tested Determined Using the Guarded Parameter Method

Forming Part of Sentences 9.36.6.34.(1) and (3) and (5)

Airtightness Levels	ACH <sub>50</sub>	Air-Leakage Airtightness Metrics			
		NLA <sub>10</sub> , cm <sup>2</sup> /m <sup>2</sup>		NLR <sub>50</sub> , L/s × m <sup>2</sup>	
		cm <sup>2</sup> /m <sup>2</sup>	in. <sup>2</sup> /100-ft. <sup>2</sup>	L/s × m <sup>2</sup>	cfm <sub>50</sub> /ft. <sup>2</sup>
		Air-Leakage-Rates Maximum Airtightness Values			
AL-1A	2.5	1.20	1.73	0.89	0.17
AL-2A	2.0	0.96	1.38	0.71	0.14
AL-3A	1.5	0.72	1.04	0.53	0.10
AL-4A	1.0	0.48	0.69	0.35	0.070
AL-5A	0.6	0.29	0.42	0.21	0.042

Table [9.36.6.4.-B]

Air-Leakage-Rates Airtightness Levels for Attached Zones Tested Determined Using the Unguarded Parameter Method

Forming Part of Sentences 9.36.6.34.(1) and (34) and (6)

Airtightness Levels	ACH <sub>50</sub>	Air-Leakage Airtightness Metrics			
		NLA <sub>10</sub> , cm <sup>2</sup> /m <sup>2</sup>		NLR <sub>50</sub> , L/s × m <sup>2</sup>	
		cm <sup>2</sup> /m <sup>2</sup>	in. <sup>2</sup> /100-ft. <sup>2</sup>	L/s × m <sup>2</sup>	cfm <sub>50</sub> /ft. <sup>2</sup>
		Air-Leakage-Rates Maximum Airtightness Values			
AL-1B	3.0 <sup>(1)</sup>	1.92	2.76	1.17	0.23
AL-2B	2.5	1.6	2.3	0.98	0.19
AL-3B	2.0	1.28	1.84	0.78	0.15
AL-4B	1.5	0.96	1.38	0.59	0.12
AL-5B	1.0	0.64	0.92	0.39	0.077
AL-6B	0.6	0.38	0.55	0.23	0.046

- Guarded testing is not very common
- Consider Table –A for Detached testing and Table –B for Attached?

10

## Ventilation ECM Points

Energy Conservation Measures for Ventilation Systems – Sensible Heat-Recovery Efficiency, SRE (%)	Heating Degree-Days of Building Location, in Celsius Degree-Days					
	Zone 4	Zone 5	Zone 6	Zone 7A	Zone 7B	Zone 8
	≤ 3000	3000 to 3999	4000 to 4999	5000 to 5999	6000 to 6999	≥ 7000
	Energy Conservation Points					
60% ≤ SRE < 65%	0.7	0.7	0.7	0.6	0.8	0.4
65% ≤ SRE < 75%	2.1	2.1	2.2	1.7	2.3	1.2
75% ≤ SRE < 84%	3.4	3.2	3.5	2.7	3.7	1.8

11

## Water Heater ECM Points

- Also known as ‘Service Water Heating’

Type of Equipment	Energy Conservation Measures for Service Water Heating Equipment – Energy Efficiency, EF or UEF (1) (2)	Performance Testing Standard	Heating Degree-Days of Building Location, in Celsius Degree-Days					
			Zone 4 < 3000	Zone 5 3000 to 3999	Zone 6 4000 to 4999	Zone 7A 5000 to 5999	Zone 7B 6000 to 6999	Zone 8 ≥ 7000
			Energy Conservation Points					
<del>Gas or oil-fired</del> <del>Residential</del> tankless condensing water heater	EF ≥ 0.95 or UEF ≥ 0.92	CSA P.3	<del>1-38.9</del>	<del>0-95.4</del>	<del>0-84.9</del>	<del>0-73.1</del>	<del>0-73.1</del>	<del>0-73.1</del>
<del>Gas or oil-fired</del> <del>Residential</del> storage-type water heater	EF ≥ 0.80 or UEF ≥ 0.83		8.9	5.4	4.9	3.1	3.1	3.1
<del>Gas or oil-fired</del> <del>Residential</del> -duty commercial storage-type water heater	UEF ≥ 0.79		4.6	2.7	2.4	1.5	1.5	1.5
	UEF ≥ 0.85		6.0	3.6	3.2	2.0	2.0	2.0
Heat pump water heater	EF ≥ 2.35	CAN/CSA-C745	6.4	3.9	3.8	3.0	3.0	3.0

12

## Building Size (Volume) ECM Points

Table [9.36.6.11.] 9.36.6.11.  
Energy Conservation Points for Building Volume  
Forming Part of Sentence 9.36.6.11.(2)

<u>Building Volume (V), m<sup>3</sup></u>	<u>Energy Conservation Points</u>
<u>380 &lt; V ≤ 390</u>	<u>1</u>
<u>370 &lt; V ≤ 380</u>	<u>2</u>
<u>360 &lt; V ≤ 370</u>	<u>3</u>
<u>350 &lt; V ≤ 360</u>	<u>4</u>
<u>340 &lt; V ≤ 350</u>	<u>5</u>
<u>330 &lt; V ≤ 340</u>	<u>6</u>
<u>320 &lt; V ≤ 330</u>	<u>7</u>
<u>310 &lt; V ≤ 320</u>	<u>8</u>
<u>300 &lt; V ≤ 310</u>	<u>9</u>
<u>V ≤ 300</u>	<u>10</u>

13

# Heating and Cooling System ECM Points??

- NO
- Minimums are in table 9.36.3.10 and are different than current SB12
- AC – SEER 14.5
- ASHP – HSPF 7.1
- Gas Boiler - 90% AFUE
- Gas Furnace - 95% with ECM
- Combo - TPF 0.8

Type of Component or Equipment	Heating or Cooling Capacity, kW	Performance Testing Standard	Minimum Performance <sup>(1)</sup>
<b>Air-Cooled Unitary Air Conditioners and Heat Pumps – Electrically Operated</b>			
Split system	$\leq 19$	CSA C656	SEER = 14.5
			EER = 11.5
			HSPF $\geq 7.1$ (region 5-in standard)
Single-package system	$\leq 19$	CSA C656 (including General Instruction No. 2)	SEER = 14
			EER = 11
Heat pumps, split and single-package	$\geq 19$	See Table 5.2.12.1. of Division B of the NECB (PCF 1621)	HSPF $\geq 7.0$ (region 5-in standard)
			See Level 2 in standard
All systems	$> 19$	CAN/CSA-C746	See Level 2 in standard
Gas-fired boilers <sup>(3)</sup>	$\leq 88$	CSA P.2	AFUE $\geq 90\%$
	$> 88$ and $\leq 147.23$	AHRI BTSA/ANSI/AHRI 1500-2015 or DOE 10 CFR, Part 431, Subpart E, Appendix A	$E_f \geq 83\%$
<b>Warm-Air Furnaces, Combination Warm-Air Furnace/Air-conditioning Units, Duct Furnaces and Unit Heaters</b>			
Gas-fired warm-air furnaces <sup>(3)</sup>	$\leq 65.066$ using single-phase electric current	CSA P.2 CAN/CSA-P.8	AFUE $\geq 92\%$ and must be equipped with a high-efficiency constant torque or constant airflow fan motor

14

## Let's look at some packages that meet:

**Tiered Prescriptive Path 9.36.7** - Let's go find 20 ECM pts for Tier 3

**Performance Path 9.36.5** – Proposed design must meet the 3 targets (Overall Energy Consumption, Envelope Heat Loss and Heat Gain)

15