

PRÜFUNG DER WIRKSAMKEIT DER ACTIVEPURE® TECHNOLOGIE BEI DER DEKONTAMINATION VON SARS-COV-2 AUF OBERFLÄCHEN



Einleitung

Dieser Abschlussbericht wurde bei MRIGlobal (MRIGlobal) für die Untersuchungen erstellt, die unter der MRIGlobal Task Nr. 311624.01.001 „Überprüfung der Wirksamkeit der AktivePure Technologie bei der Dekontamination von SARS-CoV-2“ durchgeführt wurden.

Für die Durchführung des Programms wurden von Aerus LLC Testgeräte an MRIGlobal geliefert. Die Testphase dieser Aufgabe wurde von MRIGlobal am 18. Mai 2020 begonnen und endete am 19. Juni 2020.

Der Untersuchungsleiter des Programms war Rick Tuttle. Die Durchführung der Untersuchung wurde von Dr. Carl Gelhaus, Dr. Luca Popescu, Dr. Kristen Solocinski und Sam Humphries begleitet und von William Sosna geleitet.

Die Untersuchungen sind in Übereinstimmung mit den MRIGlobal Qualitätssicherungsverfahren durchgeführt worden. Alle Abläufe im Zusammenhang mit dieser Untersuchung wurden, sofern nicht ausdrücklich in diesem Protokoll definiert, gemäß der Standardvorgehensweise von MRIGlobal oder zugelassenen Laborverfahren durchgeführt, und etwaige Abweichungen sind dokumentiert worden.

Genehmigt von:


Ed Sistrunk
Abteilungsleiter
Medizinische Gegenmaßnahmen

MRIGlobal

Rick Tuttle
Untersuchungsleiter

15. Juli 2020

PRÜFUNG DER WIRKSAMKEIT DER ACTIVEPURE® TECHNOLOGIE BEI DER DEKONTAMINATION VON SARS-COV-2 AUF OBERFLÄCHEN



2017 Space Technology Hall
of Fame Inductee

Testeinheit Aerus Pure & Clean®

Sars- Cov-2 Virenreduktion in der Luft

Zusammenfassung

Die Aerus® Active Pure® Technologie deaktiviert das Sars-Cov-2 Virus in der Luft bis zu unmessbar niedrigen Werten.

Die Ergebnisse offenbaren, dass der Reduktions- Prozentsatz zwischen >99,87 und >99,96% liegt. Da jedoch kein messbarer Prozentsatz nach dem Einsatz der Testeinheit festgestellt werden konnte, ist davon auszugehen, dass der tatsächliche Reduktions-Prozentsatz des Virus über 99,9% hinausgeht. Der tatsächliche Prozentsatz konnte auf Grund der niedrigen Werte nicht gemessen werden. Weshalb zu dem Ergebnis gekommen wird, dass die reelle Reduktion bei über 99,9 % liegt.

Dieser Laborbericht wurde erstellt und angefertigt von:

William S. Lawrence,


Ph. D. Assistant Professor,
Microbiology & Immunology
University of Texas Medical Branch (UTMB)

Jennifer E. Peel,

B.S. Senior Research Associate,
Microbiology & Immunology
University of Texas Medical Branch (UTMB)

Testeinheit Aerus Pure & Clean®

Sars- Cov-2 Virenreduktion in der Luft



TESTEINHEIT PURE & CLEAN®

Die medizinische Abteilung der Texas University (UTMB) hat SARS-Cov-2-Viren in der Luft getestet und 99,9% weniger Viruspräsenz in nur 3 Minuten festgestellt. Diese Tests, wurden in den Biosicherheitsstufen 3 und 4 dreifach durchgeführt, gemäß der dafür vorgesehenen FDA-Protokolle.



Prüfungen/Tests

- University of Texas - Medical Branch (UTMB)
 - UNE Spanish Association for Standardization and Certification (AENOR)
 - DMT GmbH (TÜV NORD GRUPPE)
 - MRI Global, Kansas City
 - Danish Technological Institute
- 

Aerus Pure & Clean Unit with ActivePure® Technology Testing Airborne SARS-CoV-2 Virus Reduction

Executive Summary


The Aerus technology inactivated airborne SARS-CoV-2 to undetectable levels. The results show that, when accounting for the LLD, the percent reduction in virus was ≥ 99.87 to $\geq 99.96\%$; however, since no virus was detected after using the experimental device, the true percent reduction was likely greater than 99.99% in every case.

The true net reduction could not be determined due to the LLD of the quantitation assay, but this too was likely greater than 99.99%.

Report Prepared and Submitted by:

William S. Lawrence,
Ph.D. Assistant Professor,
Microbiology & Immunology
University of Texas Medical Branch (UTMB)

Jennifer E. Peel,
B.S. Senior Research Associate,
Microbiology & Immunology
University of Texas Medical Branch (UTMB)



Beyond Guardian Air and Pure & Clean Units with ActivePure® Technology Tested – No Ozone



DANISH
TECHNOLOGICAL
INSTITUTE

Executive Summary


Danish Technological Institute assess that neither of the tested Air Purification Systems give rise to ozone accumulation.

The background ozone concentration in the test chamber was measured to 7 ± 2 ppb prior to the tests.


The ozone concentration was continuously measured with a Teledyne API Ozone Analyzer model 430. The instrument can measure ozone concentration in the range from 0 - 20 000 ppb (20 ppm) with a precision of 0.5 ppb and a lower detection limit of 2 ppb. The measurement was performed with time resolution of 10 seconds.

Report Prepared and Submitted by:
Teknologisk Institut
Bioengineering and Environmental Technology

Author: Stig Koust Hansen, Ph.D., Consultant
Quality Assurance:
Thomas Nørregaard Jensen Consultant



Ozone concentration measured in test chamber during test of AERUS PURE & CLEAN with ActivePure



Ozone concentration measured in test chamber during test of BEYOND GUARDIAN AIR BY AERUS with ActivePure

The full testing procedures and results are presented in Report no. 946792



Verification of the Effectiveness of ActivePure® Technology in Decontamination of Sars-CoV-2 on Surfaces



This final report was prepared at MRIGlobal (MRIGlobal) for the work performed under MRIGlobal Task No. 311624.01.001, "Verification of the Effectiveness of ActivePure® Technology in Decontamination of SARS-CoV-2"

Test devices were supplied to MRIGlobal by Aerus, LLC for the conduct of the program. The experimental phase of this task was initiated by MRIGlobal on May 18, 2020 and ended on June 19, 2020.

The Study Director of the program was Rick Tuttle. Execution of the study was assisted by Carl Gelhaus, Ph.D., Luca Popescu, Ph.D., Kristen Solocinski, Ph.D., Sam Humphries, and managed by William Sosna.

The studies were performed in compliance with MRIGlobal QA procedures. All operations pertaining to this study, unless specifically defined in this protocol, were performed according to the Standard Operating Procedures of MRIGlobal or approved laboratory procedures, and any deviations were documented.

Approved by:

A handwritten signature in black ink, reading "Ed Sistrunk".


Ed Sistrunk
Division Director
Medical Countermeasures

MRIGlobal

A handwritten signature in black ink, reading "Rick Tuttle".

Rick Tuttle
Study Director

Test Results for ActivePure® SARS-CoV-2
Averaged Viable Reduction %



The Spanish Association for Standardization and Certification (UNE) has tested the air purifier Beyond Guardian Air by Aerus with ActivePure® Technology, for its efficiency to reduce the concentration of bacteria on surfaces.



Declaration of tests and assessments

The Spanish Association for Standardization and Certification has tested the air purifier Beyond Guardian Air by Aerus for both its capacity of distribution and the efficiency to reduce the concentration of bacteria, using the Euro Norm 17272-2020.



The test was conducted with the air purifier unit installed in a 4.55 m x 5.61 m room. The efficiency of the air purifier was tested by a method where several petri dishes were placed around the room. The Beyond Guardian Air is turned on and the testing on the petri dish samples takes place for a period of 24 hours.

The efficiency and distribution of the Beyond Guardian Air, according to both tests was declared as more than 5log.

Prepared by:

The Spanish Association for Standardization and Certification
AENOR
UNE

Author: Miguel Yuste



CONFIDENTIAL & PROPRIETARY INFORMATION - NOT FOR PUBLICATION

For Product Guide

The Spanish Association for Standardization and Certification (UNE) has tested the air purifier Beyond Guardian Air by Aerus with ActivePure® Technology, for its efficiency to reduce the concentration of fungi on surfaces.



Declaration of tests and assessments

The Spanish Association for Standardization and Certification has tested the air purifier Beyond Guardian Air by Aerus for both its capacity of distribution and the efficiency to reduce the concentration of fungi, using the Euro Norm 17272-2020.



The test was conducted with the air purifier unit installed in a 4.55 m x 5.61 m room. The efficiency of the air purifier was tested by a method where several petri dishes were placed around the room. The Beyond Guardian Air is turned on and the testing on the petri dish samples takes place for a period of 24 hours.

The efficiency and distribution of the Beyond Guardian Air, according to both tests was declared as more than 5log.

Prepared by:

The Spanish Association for Standardization and Certification
AENOR
UNE

Author: Miguel Yuste



CONFIDENTIAL & PROPRIETARY INFORMATION - NOT FOR RELEASE

111 Product Guide

Test Certificate for MPPS and Filter grade model “HEPA Guardian Air Filter – Part No. 49457”



Executive Summary

The tested filter model “HEPA Guardian Air Filter - Part No. 49457” has to be classified according ISO 16890-1 on base of the average fractional efficiency determined in new and in discharged condition as


„ISO ePM10 85%“

Obviously, the filter medium is strongly electrically charged. Separation performance decreases significantly after discharging procedure of the filter element in isopropanol vapor. Without this requirement to discharge synthetic filter media the filter element would be filter class E11 according EN 1822-1 or ISO 15Eacc . ISO 29463-1:2017.

Prepared by:
DMT GmbH & Co.KG

Author:
Dr. Dirk Renschen
Johannes Schamberg

Fractional Efficiency by Particle size



NOTE: The results of this test relate only to the test devise in the conditions stated herein. The performance results cannot by themselves be quantitatively applied to predict filtration performance in all "real life" environments.

classified according ISO16890-1
DIN EN ISO 9001 ZERTIFIZIERT

DIN EN ISO
9001
zertifiziert



Danish Technological Institute has tested the viral inactivation efficiency of Beyond Guardian Air by Aerus with ActivePure® Technology on aerosolized MS2 bacteriophage, a positive-stranded RNA virus



Declaration of test and assessment

The purpose of the test is to determine the efficiency of the air purifier to reduce the concentration active of aerosolized MS2 bacteriophages using a modified ISO 16000-36:2018 method. The tested air purifier is a Beyond Guardian Air by Aerus.


The significant and consistent difference between the Natural decay test and the Product test clearly shows a reduction of the concentration of active and airborne MS2 caused by the air purifier.

The measured decay of the concentration of active MS2 during the tests is attributed to a natural decay of the aerosol and an attribution of the air purifier. The determined attribution of the air purifier is >99.99% reduction in the 20 m³ room within 30 minutes. In addition, the calculated half time for active MS2 is determined to be 2.8 minutes.

Report Prepared and Submitted by:
Teknologisk Institut
Bioengineering and Environmental Technology

Author: Stig Koust Hansen, Ph.D., Consultant
Quality Assurance: Caster Laur Byg, Specialist

Test Results for Beyond Guardian Air® on MS2 bacteriophages
Averaged Viable Reduction %



The full testing procedures and results are presented in report no. 956985
Using ISO 16000-36:2018 method



CONFIDENTIAL & PROPRIETARY INFORMATION - NOT FOR RELEASE
31 Product Guide

Danish Technological Institute has tested the air purifier Beyond Guardian Air by Aerus with ActivePure® Technology, for its efficiency to reduce the concentration of particles and volatile organic compounds from cigarette smoke



DANISH
TECHNOLOGICAL
INSTITUTE

Declaration of test and assessment


Danish Technological Institute has tested the air purifier Beyond Guardian Air by Aerus, for its efficiency to reduce the concentration of particles and volatile organic compounds (VOC) from cigarette smoke using a modified ANSI/AHAM AC-1-2015 method.

The test was conducted with the air purifier unit installed in a 20 m³ sealed room. The efficiency of the air purifier was tested by a method, where particles and VOC were generated through a smoking phase consisting of sequential smoking of three cigarettes using a smoking robot over a period of 20-25 minutes. The smoking phase is immediately followed by a 10-minute period where the cigarette smoke is mixed, before the air purifier is turned on. This marks the beginning of the 30-minutes Product Test period.

The rate of reduction of the particles and VOC was determined as the difference between a reference experiment designed to measure the natural decay rate and reduction rate measure during the use of the Beyond Guardian Air.

Report Prepared and Submitted by:
Teknologist Institut
Bioengineering and Environmental Technology

Author: Stig Koust Hansen, Ph.D., Consultant
Quality Assurance: Caster Laur Byg, Specialist



Particle Number concentration measured over time. The smoke phase occurs during the initial 25 minutes, which is followed by a 10-minute mixing period. Hereafter the air purifier is turned on (only for product test) for 30 minutes.



CONFIDENTIAL & PROPRIETARY INFORMATION - NOT FOR RELEASE

44 Product Guide

Danish Technological Institute has tested the air purifier Beyond Guardian Air by Aerus with ActivePure® Technology, for its efficiency to reduce the concentration of particles and volatile organic compounds from cigarette smoke



DANISH
TECHNOLOGICAL
INSTITUTE

Declaration of test and assessment


Danish Technological Institute has tested the air purifier Beyond Guardian Air by Aerus, for its efficiency to reduce the concentration of particles and volatile organic compounds (VOC) from cigarette smoke using a modified ANSI/AHAM AC-1-2015 method.

The test was conducted with the air purifier unit installed in a 20 m³ sealed room. The efficiency of the air purifier was tested by a method, where particles and VOC were generated through a smoking phase consisting of sequential smoking of three cigarettes using a smoking robot over a period of 20-25 minutes. The smoking phase is immediately followed by a 10-minute period where the cigarette smoke is mixed, before the air purifier is turned on. This marks the beginning of the 30-minutes Product Test period.

The rate of reduction of the particles and VOC was determined as the difference between a reference experiment designed to measure the natural decay rate and reduction rate measure during the use of the Beyond Guardian Air.

Report Prepared and Submitted by:
Teknologist Institut
Bioengineering and Environmental Technology

Author: Stig Koust Hansen, Ph.D., Consultant
Quality Assurance: Caster Laur Byg, Specialist



Particle Mass concentration measured over time. The smoke phase occurs during the initial 25 minutes, which is followed by a 10-minute mixing period. Hereafter the air purifier is turned on (only for product test) for 30 minutes.

using ANSI/AHAM AC-1-2015 method
The full testing procedures and results are presented in report no. 956985



CONFIDENTIAL & PROPRIETARY INFORMATION - NOT FOR RELEASE

Product Guide

Danish Technological Institute has tested the air purifier Beyond Guardian Air by Aerus with ActivePure® Technology, for its efficiency to reduce the concentration of particles and volatile organic compounds from cigarette smoke



DANISH
TECHNOLOGICAL
INSTITUTE

Declaration of test and assessment


Danish Technological Institute has tested the air purifier Beyond Guardian Air by Aerus, for its efficiency to reduce the concentration of particles and volatile organic compounds (VOC) from cigarette smoke using a modified ANSI/AHAM AC-1-2015 method.

The test was conducted with the air purifier unit installed in a 20 m³ sealed room. The efficiency of the air purifier was tested by a method, where particles and VOC were generated through a smoking phase consisting of sequential smoking of three cigarettes using a smoking robot over a period of 20-25 minutes. The smoking phase is immediately followed by a 10-minute period where the cigarette smoke is mixed, before the air purifier is turned on. This marks the beginning of the 30-minutes Product Test period.

The rate of reduction of the particles and VOC was determined as the difference between a reference experiment designed to measure the natural decay rate and reduction rate measure during the use of the Beyond Guardian Air. The concentrations of particles and VOC were measured continuously with a time resolution of 10 seconds. We have previously performed proton transfer reaction mass spectrometry on cigarette smoke and found high concentrations of acetaldehyde, formaldehyde and various fragments of acetic acid the FDA list 33 different VOCs in mainstream cigarette smoke.

Report Prepared and Submitted by:
Teknologisk Institut
Bioengineering and Environmental Technology

Author: Stig Koust Hansen, Ph.D., Consultant
Quality Assurance: Caster Laur Byg, Specialist



VOC concentration measured over time. The smoke phase occurs during the initial 25 minutes, which is followed by a 10-minute mixing period. Hereafter the air purifier is turned on (only for product test) for 30 minutes

using ANSI/AHAM AC-1-2015 method
The full testing procedures and results are presented in report no. 956985



CONFIDENTIAL & PROPRIETARY INFORMATION - NOT FOR RELEASE

Product Guide

Zertifikate



CE Declaration of Conformity

We, on behalf of
Aerus LLC
14841 Dallas Parkway
The Aberdeen Bldg, Suite 500
Dallas, Texas 75254
USA

And in accordance with the following Directive(s):

EMC Directive 89/368/EEC amended by Council Directive 93/88/EEC
RoHS Directive 2002/95/EC
WEEE Directive 2002/96/EC

herby declare that the Portable Air Purification System:

Product Name: Aerus Mobile
Model Number: A1080

is in conformity with the applicable requirements of the following standards:

EN61000-3-2:2004 Electromagnetic compatibility
EN61000-3-3:2002 Electromagnetic compatibility
EN61000-4-2:2001 Electromagnetic compatibility
EN61000-4-3:2002 Electromagnetic compatibility
EN61000-4-4:2004 Electrical fast transients and bursts
EN61000-4-5:2001 Surge test
EN61000-4-6:2004 Conducted immunity
EN61000-4-11:2005 Voltage dips, short interruptions and voltage variations immunity test
EN61000-6-1:2005 Conducted Emissions
EN61000-6-2:2005 Radiated Emissions

I hereby declare that the product named above has been designed and manufactured to comply with the relevant sections of the above referenced standards. The product complies with applicable requirements of the Directives.

Lab Technician: Jamie Davis Jamie Davis

Reviewed and Approved by:

Name: Andrew Eide

Signature: Andrew Eide
Title: Vice President, Product Development and Manufacturing
Company: ActivePure Technology LLC
14841 Dallas Parkway
The Aberdeen Bldg, Suite 500
Dallas, Texas 75254 USA
Date: 01 March 2021



14841 Dallas Parkway
Suite 500, The Aberdeen Bldg.
Dallas, Texas 75254 USA

RoHS(2) Certificate of Compliance

Restriction of the use of certain Hazardous Substances

European Union Directives 2002/95/EC and 2011/65/EU, restricts the use of the hazardous substances listed below in electrical and electronic equipment

For these purposes, the maximum concentration values of the restricted by weight are:

Substance	Maximum Limit (ppm)
Cadmium (Cd)	100
Lead (Pb)	1000*
Mercury (Hg)	1000
Hexavalent Chromium (Cr6+)	1000
Poly Brominated Biphenyls (PBB)	1000
Poly Brominated Diphenyl Ethers (PBDE)	1000

*Maximum limit (ppm) on Lead (Pb) does not apply to applications for which exemptions have been granted by the RoHS Directive

Based on the information provided by our suppliers, and to the best of our knowledge, Aerus designates that the following products, are RoHS Compliant and conform to the stated EU Restrictions of the use of Hazardous Substances (RoHS).

- Lux Guardian Air Platinum
- Beyond Guardian Air (Models F155B, DEF G)

Confirmation of compliance status by our suppliers is either because the products do not contain any of the restricted substances referred to in Article 4(1) of the RoHS Directive at concentrations in excess of those permitted under the RoHS Directive or because removal of the restricted substances is not technically possible and their existence in the products at levels in excess of these concentrations is allowed as one of the particular applications listed in the Annex to the RoHS Directive.

To the best of our knowledge, none of our suppliers use these banned substances to manufacture their products. Our statements in this letter regarding RoHS compliance and lead content do not extend to, or apply to any product subjected to unintended contamination, misuse, neglect, accident, or improper installation.

Andrew Eide

Andrew Eide
VP, Product Development & Manufacturing



CE Declaration of Conformity

We, on behalf of
Aerus LLC
300 East Valley Drive
Bristoll, VA 24201
USA

And in accordance with the following Directive(s):

Low Voltage Directive 2014/35/EU
EMC Directive 2014/30/EU

herby declare that the Air Purification System:

Product Name: Aerus Pure and Clean
Model(s): A1040A
Rating: 100-240 VAC/50/60 Hz

is in conformity with the applicable requirements of the following standards:

EN55014 -1- 2017: Electromagnetic compatibility required for household appliances, electric tools and similar apparatus - Part 1: Emissions
EN55014 -2- 2015: Electromagnetic compatibility required for household appliances, electric tools and similar apparatus - Part 2: Immunity
EN61000-3-2-2014: Limits for harmonic current emissions
EN61000-3-2-2015: Limits for harmonic current emissions

I hereby declare that the product named above has been designed and manufactured to comply with the relevant sections of the above referenced standards. The product complies with applicable requirements of the Directives.

Lab Manager: Jamie Davis Jamie Davis

Reviewed and Approved: Andrew Eide

Signature: Andrew Eide
Title: Vice President, Product Development and Manufacturing
Company: Aerus LLC
14841 Dallas Parkway
The Aberdeen Bldg, Suite 500
Dallas, Texas 75254 USA
Date: 4 February 2021



14841 Dallas Parkway
Suite 500, The Aberdeen Bldg.
Dallas, Texas 75254 USA

RoHS Certificate of Compliance

Restriction of the use of certain Hazardous Substances

European Union Directives 2002/95/EC and 2011/65/EU, restricts the use of the hazardous substances listed below in electrical and electronic equipment

For these purposes, the maximum concentration values of the restricted by weight are:

Substance	Maximum Limit (ppm)
Cadmium (Cd)	100
Lead (Pb)	1000*
Mercury (Hg)	1000
Hexavalent Chromium (Cr6+)	1000
Poly Brominated Biphenyls (PBB)	1000
Poly Brominated Diphenyl Ethers (PBDE)	1000

*Maximum limit (ppm) on Lead (Pb) does not apply to applications for which exemptions have been granted by the RoHS Directive

Based on the information provided by our supplier, and to the best of our knowledge, Aerus LLC designates that the products, Aerus Pure & Clean model A1040A and Aerus Pure & Clean - model A1040A are RoHS Compliant and conform to the EU Restrictions of the use of Hazardous Substances (RoHS).

Confirmation of compliance status by our supplier is either because the product does not contain any of the restricted substances referred to in Article 4(1) of the RoHS Directive at concentrations in excess of those permitted under the RoHS Directive or because removal of the restricted substances is not technically possible and their existence in the products at levels in excess of these concentrations is allowed as one of the particular applications listed in the Annex to the RoHS Directive.

To the best of our knowledge, our supplier does not use these banned substances to manufacture their products. Our statements in this letter regarding RoHS compliance and lead content do not extend to, or apply to any product subjected to unintended contamination, misuse, neglect, accident, or improper installation.

Andrew Eide

Andrew Eide
VP, Product Development & Manufacturing



CE Declaration of Conformity

We, on behalf of
Aerus LLC
300 East Valley Drive
Bristol, VA 24201
USA

And in accordance with the following Directive(s):

Low Voltage Directive
EMC Directive

2014/39/EU
2014/53/EU

hereby declare that the Air Purification System:

Product Name: Beyond Guardian Air
Model(s): P150F
Rating: Z20240 VAC50/60 Hz 70 watts

is in conformity with the applicable requirements of the following standards:

EN60335-1: 2012 + A13:2017 Household and similar electrical appliances – Safety, Part 1: General requirements
EN60335-2-45: Ed 2.2, B:2015 Household and similar electrical appliances – Safety, Part 2-45: Particular requirements for air cleaning appliances
EN55014-1: 2017 Electromagnetic compatibility required for household appliances, electric tools and similar apparatus – Part 1: Emissions
EN55014-2: 2015 Electromagnetic compatibility required for household appliances, electric tools and similar apparatus – Part 2: Immunity

I hereby declare that the product named above has been designed and manufactured to comply with the relevant sections of the above referenced standards. The product complies with applicable requirements of the Directives.

Lab Manager: Jamie Davis

Reviewed and Approved: Andrew Eide

Signature:

Title: Vice President, Product Development and Manufacturing
Company: Aerus LLC
14841 Dallas Parkway
The Aberdeen Bldg, Suite 500
Dallas, Texas 75254 USA
Date: 4 June 2020



CE Declaration of Conformity

We, on behalf of
Aerus LLC
300 East Valley Drive
Bristol, VA 24201
USA

And in accordance with the following Directive(s):

Low Voltage Directive
EMC Directive

2014/39/EU
2014/53/EU

hereby declare that the Air Purification System:

Product Name: Guardian Angel
Model(s): P170C
Rating: Z20240 VAC50/60 Hz 220W class 1

is in conformity with the applicable requirements of the following standards:

EN60335-1: 2012 + A13:2017 Household and similar electrical appliances – Safety, Part 1: General requirements
EN60335-2-45: Ed 2.2, B:2015 Household and similar electrical appliances – Safety, Part 2-45: Particular requirements for air cleaning appliances
EN55014-1: 2017 Electromagnetic compatibility required for household appliances, electric tools and similar apparatus – Part 1: Emissions
EN55014-2: 2015 Electromagnetic compatibility required for household appliances, electric tools and similar apparatus – Part 2: Immunity

I hereby declare that the product named above has been designed and manufactured to comply with the relevant sections of the above referenced standards. The product complies with applicable requirements of the Directives.

Lab Manager: Jamie Davis

Reviewed and Approved: Andrew Eide

Signature:

Title: Vice President, Product Development and Manufacturing
Company: Aerus LLC
14841 Dallas Parkway
The Aberdeen Bldg, Suite 500
Dallas, Texas 75254 USA
Date: 4 June 2020



CE Declaration of Conformity

We, on behalf of
Aerus LLC
300 East Valley Drive
Bristol, VA 24201 USA

And in accordance with the following Directive(s):

EMC
RoHS Directive

EN 61000-3-2:2014
EN 61000-3-3:2013

hereby declare that the Water Based Cleaning System:

Product Name: Name: Laundry Pro 2.0, Euro

is in conformity with the applicable requirements of the following standards:

EN 61000-3-2:2014
EN 61000-3-3:2013
EN 61000-4-2:2009
EN 61000-4-3:2007
EN 61000-4-4:2012
EN 61000-4-5:2014
EN 61000-4-6:2013
EN 61000-4-8:2009
EN 61000-4-11:2004
EN 61000-6-2:2005
EN 61000-6-4:2007

I hereby declare that the product named above has been designed and manufactured to comply with the relevant sections of the above referenced standards. The product complies with applicable requirements of the Directives.

Lab Manager: Lester Wise

Reviewed and Approved by:

Name: Andrew Eide

Signature:

Title: Vice President, Product Development and Manufacturing
Company: Aerus LLC
4100 Alpha Rd, Suite 1100
Dallas, Texas 75244, USA
Date: 09 May 2017