

# CARBON DIOXIDE

## RUGGED

- 5-Year manufacturer's warranty
- All-metal valve construction
- Rust-free aluminum cylinders
- Durable high-gloss polyester powder paint
- Temperature range -22°F to 120°F

## USER-FRIENDLY

- Meets many hospital medical equipment requirements
- Large loop stainless steel pull pin
- QR coded and multilingual labels
- Leaves no residue

## OPTION

- USCG approved with bracket listed on UL label
- Model 322NM is independently tested and approved for use in MRI facilities to 11.7 Tesla
- Model 322NM has a sanitary white paint finish (easy to clean)



322NM



322



330



331



332



**AVAILABLE IN  
50 AND 100 LB. WHEELED  
EXTINGUISHERS**

**NONMAGNETIC MODEL AVAILABLE  
(MODEL 322NM—TESTED TO 11.7 TESLA)**

**322NM**  
MR CONDITIONAL  
THIS EXTINGUISHER HAS BEEN TESTED TO OPERATE PROPERLY AND POSE NO SAFETY HAZARD IN AN MRI ENVIRONMENT ASSOCIATED WITH MR SYSTEMS OPERATING AT 11.7 TESLA OR LESS.

**MANUFACTURED AND TESTED  
TO UL STANDARDS**  
COMPLIES WITH NFPA 10 STANDARD  
ISO-9001/ ISO-14001 CERTIFIED UL LISTED

**CONFORMS TO TEST STANDARDS:**  
CAN/ULC-S503 - UL 154 &  
CAN/ULC-S508 - UL 711

AGENT TYPE	CARBON DIOXIDE				
VALVE TYPE	Chrome-Plated Brass				
DESIGN	Tube & Horn		Hose & Horn		
MODEL NUMBER	322	322NM	330	331	332
UL & ULC RATING	5B:C	5B:C	10B:C	10B:C	10B:C
CAPACITY (LBS.)	5	5	10	15	20
SHIPPING WT. (LBS.)	13.1	13.1	28.25	37.75	50.75
HEIGHT (IN.)	17.75	17.75	24	30	30
WIDTH (IN.)	8.25	8.25	12	12	13
DEPTH (IN.)	5.25	5.25	7	7	8
RANGE (INITIAL- FT.)	3-8	3-8	3-8	3-8	3-8
DISCHARGE TIME (SEC.)	9	9	11	14.5	19.2
INCLUDED BRACKET	Wall	NM Wall	Wall	Wall	Wall



330.893.3139






www.holmesfireandsafety.com

















# WHERE TO USE

AMEREX manufactures a variety of hand-portable and wheeled fire extinguishers, both “compliance” (code required) and “specialty” types.

“Compliance” extinguishers are designed to meet and exceed state or local fire protection requirements. “Specialty” extinguishers are intended for use on particular types of hazards so they should be placed in close proximity to the specific hazard they are meant to protect. It is natural for a person to use the extinguisher located nearest to a fire. The most current issue of NFPA-10 should be consulted for minimum recommended fire extinguisher types, placement, and travel distances. Your local Amerex Fire Equipment

Distributor is professionally equipped to help you evaluate and implement these recommendations. All “Pictograms” are detailed below and should be reviewed with all who might be expected to use a fire extinguisher. Everyone should be familiar with these picture symbols that identify the types of fires on which they may be used. The international sign system diagonal red slash indicates a potential danger if the extinguisher is used on that particular type of fire.

TYPES OF FIRES			
<b>Class A</b>	Ordinary combustibles	Wood, paper, rubber, fabrics, and many plastics	
<b>Class B</b>	Flammable liquids & gases	Gasoline, oils, paint, lacquer, and tar	
<b>Class C</b>	Live electrical equipment	Fires involving live electrical equipment	
<b>Class D</b>	Combustible metals or combustible metal alloys	Magnesium, titanium, potassium	
<b>Class K</b>	Fires in cooking appliance that involve combustible cooking media	Vegetable or animal oils, and fats	

Types of Extinguishers	
<b>Class A</b>	  
<b>Class A:B</b>	  
<b>Class A:B:C</b>	  
<b>Class A:C</b>	 
<b>Class B:C</b>	 
<b>Class D</b>	
<b>Class A:K</b>	 

# HOW TO USE

All AMEREX extinguishers are furnished with a detailed “Owner’s Manual” containing valuable information on the installation, use, and maintenance of the extinguisher. The extinguisher nameplate contains specific information on “HOW TO USE” the particular extinguisher. The label instructions vary slightly according to type and size. Potential operators should be familiar with the instructions on any extinguisher they might be required to use.

