

TEST REPORT

Pull-out results in kilo-Newton (kn)

article group 22100

Multi plug without flange

material:

polypropylene

temperatur resistance:

from - 40° Celsius to + 70° Celsius



diameter in mm	length in mm	drill hole diameter	min. drill depth	min. ins. depth	max. pract. applic.		
5	32	5	40 mm	32 mm			
6	36	6	40 mm	36 mm	alaman alimana a		
8	50	8	60 mm	50 mm	depending on length of used		
10	60	10	70 mm	60 mm			
12	70	12	80 mm	70 mm	screw		
14	75	14	80 mm	75 mm			

Pull-out results in following building materials:

plug-Ø	5	6	8	10	12	14
screw-Ø	3,5	4,0	4,5	6,0	8,0	10,0
concrete B 25	0,8	1,0	1,6	1,9	2,5	3,8
hollow bricks	0,5	0,7	1,2	1,3	1,9	3,1
light concrete G2	0,2	0,3	0,6	1,1	1,1	2,2
light concrete G4	0,4	0,6	0,9	1,8	1,3	2,2

<u>attention:</u> The length of the screw has to be chosen in that way, that the screw penetrates the plug by its own diameter.

example .:	thickness of fixed object	:	20 mm
·	plug Ø 6 mm – length of plug	:	40 mm
	1 x screw Ø	:	<u>5 mm</u>
	min. length of screw	:	65 mm

Non-supporting material, plasterwork or insulation can not be regarded as anchorage ground.

These reports are basing on internal tests and can be regarded as general recommendations, though have to be tested at local facilities. A security coefficient has to be taken into account. These results are not valid for conditions of building authorities nor do they constitute any authorization.

Recommended security coefficient: 5-fold