

TEST REPORT

article 26500

light concrete plug

material: plastic

temperature resistance: from - 40° Celsius
to + 70° Celsius



diameter in mm	length in mm	drill hole diameter	min. drill depth	min. ins. depth	max. pract. applic.
10	50	10	60 mm	flushing with the building materials	depending on used screw

Pull-out results in following building materials:

Pull-out results in kilo-Newton (kn)

light concrete G2	1,0
light concrete G4	1,4

Non-supporting material, plasterwork or insulation can not be regarded as anchorage ground.

These reports are basing on internal tests and can be regarded as general recommendations, though have to be tested at local facilities. A security coefficient has to be taken into account. These results are not valid for conditions of building authorities nor do they constitute any authorization.

Recommended security coefficient: 5-fold